

- Infrastructure Design
- Development Planning
- Geotechnical & Environmental
- Structural Engineering
- Professional Advice
- Surveying



Our Ref: 10785G/ LJC / V01

Your Ref:

Date: 19<sup>th</sup> October 2020

**JPP Geotechnical & Environmental Ltd**  
4 Ironstone Way | Brixworth  
Northampton | NN6 9UD

T: 01604 781811  
E: mail@jppuk.net  
W: jppuk.net

Mr Tony Harding  
**Borras Construction Limited**  
1 Salar House  
Campfield Road  
St Albans  
Hertfordshire  
AL1 5HT

Dear Tony,

## **Re: Verification Report for New Sports Hall Construction at St John's School, Potter Street Hill, Northwood**

### **Introduction and background**

JPP have been appointed by Borras Construction to produce a verification report based on the works carried out in an area of the site where remediation requirements were identified due to the presence of asbestos fibres in a sample during the original ground investigation. This report has been produced to assist in discharge of the outstanding pre-occupation planning condition 18 part III.

This report has been produced for the benefit of Borras Construction, and JPP will not accept liability for third-party use of the information provided herein without prior reliance agreed. This report is valid for 6 years from the date of issue, however any significant changes to the proposals or followed legislation and guidance within this time could dictate review of our findings and recommendations.

JPP produced a remediation strategy for the site back in December 2018. This was based solely on the information obtained from the ground investigation carried out by GEA dated October 2018. The remediation relates to the identification of asbestos fibres within a sample of the arisings from a foundation exposure hand pit along the southern elevation of the former sports hall. Due to the unknowns of the potential extent in this area, outside of building and hardstanding, it was recommended that remediation comprised removal of the made ground or provision of a suitable capping where it remains. This only applied to any landscaping.

Interpretations and recommendations within the Remediation strategy report are based upon information drawn from 'Geotechnical & Environmental Associates Ltd (GEA) Desk Study & Ground Investigation Report J18164 Issue No. 1 dated 24<sup>th</sup> October 2018'. This report should be read in conjunction with this previous report. We do not accept liability or guarantee the authenticity or reliability of the information obtained or provided by others. There is a potential for ground conditions to vary from those encountered during previous investigations and may differ where not exposed by previous investigations.

JPP Geotechnical and Environmental Ltd Registered in England 11117245

#### **Registered office**

##### **NORTHAMPTON**

4 Ironstone Way | Brixworth  
Northampton  
NN6 9UD  
T: 01604 781811

##### **MANCHESTER**

3<sup>rd</sup> Floor | 82 King Street  
Manchester  
M2 4WQ  
T: 0161 682 2927

##### **MILTON KEYNES**


25 Linford Forum | Rockingham Drive  
Linford Wood | Milton Keynes  
MK14 6LY  
T: 01908 889433

##### **POOLE**

Suite 8 | Branksome Park House  
Branksome Business Park  
Bourne Valley Road | Poole | BH12 1ED  
T: 01202 540888


## Verification information

We have not visited site to carry out our own inspections during the course of the construction and therefore the following information and verification exercise is based solely on discussions with and information provided by Borras.



**Figure 1.1** Extract of Drawing 01 from our Remediation Strategy Report showing the site boundary (red), proposed building outline (blue) and the trial pit position TP1 with the asbestos fibres identified.

The sample within which the asbestos fibres were detected by the laboratory was from a depth of 0.5m and described as chrysotile loose fibrous debris with quantification analysis determining it to be 0.156%. The soil in this position and depth were described as dark brown sandy clay with frequent rootlets brick concrete and rare clinker. This is probably backfill around the original foundation excavation however without further sampling and testing away from this position it has not been possible to confirm that this is localised or isolated. It should be noted that borehole BH1 along the southern edge of the site did not encounter any made ground, only a covering of topsoil onto natural clay therefore not considered to extend this far.



**Figure 1.2** Extract from WEA Drawing 10709W-100 showing proposed and existing site levels with the outline added in green to indicate the extent of landscaping

We understand significant reduced level excavations were carried out over the entirety of this area including the area proposed to be landscaped (indicated by the green outline in Figure 1.2). An attenuation tank was also constructed in this area which required excavation of 1200-1500mm below original ground level together with all of the associated drainage runs. Essentially, all of this work has resulted in removal of any potentially impacted made ground. We have been advised that levels have been reduced by at least 900mm across the area and the material removed. This has made way for working platform comprised of imported hardcore material. This is based on anecdotal information provided by Borrás and the following photographic records.



**Photograph 1.1:** Looking south west from south west corner of proposed building showing the strip and reduced level excavations carried out. With arisings removed from site.

With reference to the Photograph 1.1, the reduced level strip appears to show only the natural clay across most of the area indicating further that the arising encountered in TP1 were localised to backfill around the original foundations.



**Photograph 1.2:** Looking south west from south west corner of proposed building showing reduced level and imported working platform placed.



**Photograph 1.3:** Southern area of the site taken week commencing 12<sup>th</sup> October 2020 showing the reinstatement of soils up to level in readiness for topsoil covering (100-150mm). Looking north west from the southern end of the site showing the south west corner of the new building (over the position of TP1).

We have been provided with a report for the imported topsoil placed across the landscaped areas which we are advised has been placed to provide a minimum covering of between 100-150mm. This analysis report is appended and confirms that the soils are suitable for use at the site based on concentrations of chemical contaminants.

The topsoil was placed on 19<sup>th</sup> October 2020 as confirmed by the following photograph provided by Borrás and a copy of the waste transfer note for the imported topsoil load also enclosed.



**Photograph 1.4:** Taken 19<sup>th</sup> October 2020 showing placed imported topsoil in subject area

### Summary

Based on the information provided and reviewed in the preceding, it is considered that the soils potentially containing asbestos fibres no longer remain within the landscaped areas and therefore do not present a risk to identified receptors as end users of the site.

Yours Sincerely,



**Lydia Crawford** BSc (Hons) CEnv MEnvSc FGS  
Director

Enclosed:  
Analysis report for imported topsoil  
Waste transfer note for load of imported topsoil 19/10/2020

# Site Analytical Services Ltd.



Site Investigations, Analytical & Environmental Chemists, Laboratory Testing Services.

Units 14 + 15, River Road Business Park,  
33 River Road, Barking, Essex IG11 0EA

Directors: J. S. Warren, M.R.S.C., P. C. Warren, J. I. Pattinson, BSc (Hons), MSc  
Consultants: G. Evans, BSc., M.Sc., P.G. Dip., FGS., MEnvSc, A. J. Kingston, BSc C.Eng. MIMM  
F. J. Gibbs, F.I.B.M.S. F.I.F.S.T., F.R.S.H. K. J. Blanchette

Tel: 0208 594 8134

Fax: 0208 594 8072

E-Mail: [services@siteanalytical.co.uk](mailto:services@siteanalytical.co.uk)

Your Ref:

ORDER NO. AWAITED

Our Ref:

19/31208

JSW/LB

## SAMPLE OF

'SOIL'

EX: RAINHAM, ESSEX RM13 9SB

## SUBMITTED BY

HODGE AND DEERY LIMITED

## RECEIVED ON

14<sup>th</sup> NOVEMBER 2019

## INTRODUCTION

A sample of the above material was received into the laboratory for chemical analysis in order to determine the degree of contamination by those parameters listed under results.

## RESULTS

| IS THE SOIL SUITABLE FOR USE?           | 'A' |
|-----------------------------------------|-----|
| RESIDENTIAL USE WITH PRIVATE GARDENS    | YES |
| RESIDENTIAL USE WITHOUT PRIVATE GARDENS | YES |
| ALLOTMENTS                              | NO  |
| PUBLIC OPEN SPACE                       | YES |
| COMMERCIAL / INDUSTRIAL SITES           | YES |



Reg. Office: Units 14 +15, River Road Business Park,  
33 River Road, Barking, Essex IG11 0EA  
Business Reg. No. 2255616





## **COMMENTS**

Concentrations of the zootoxic heavy metals Total Arsenic, Total Boron, Total Cadmium, Hexavalent Chromium, Trivalent Chromium, Total Mercury, Total Selenium, Total Copper, Total Nickel and Total Zinc in the sample analysed did not exceed the S4UL Generic Guideline Values for a residential scenario with home-grown produce. The concentration of Total Lead did not exceed the Category 4 Screening Level for residential use with home-grown produce of 200mg/kg.

The concentration of Total Cyanide was below the screening value of 20mg/kg and the concentration of Total Phenol was below the S4UL Generic Guideline Value for a residential scenario with home-grown produce.

The concentrations of individual Polycyclic Aromatic Hydrocarbons encountered did not exceed the S4UL Generic Guideline Values for a residential scenario with home-grown produce.

The concentrations of Total Petroleum Hydrocarbons encountered did not exceed the Screening Value of 500mg/kg.

The concentrations of the phytotoxic substances Total Copper, Total Zinc and Boron encountered in the sample were below the CIEH Generic screening values for residential use.

The concentration of Total Sulphate did not exceed the BRE guidance level of 2400mg/kg. From the water-soluble sulphate concentration BRE Special Digest 1 : 2005, Tables C1 and C2 would classify the sample submitted as Class DS-1.

Asbestos was not detected in the sample submitted.

The above conclusions have been drawn on the results of the tests carried out on the sample submitted and address remediation issues for the protection of the end-user only. The comments made in this report do not address any third-party liability.

**p.p. SITE ANALYTICAL SERVICES LIMITED**

25<sup>th</sup> November 2019

Aubrey Davidson BSc MSc DIC  
Environmental Engineer



Site Analytical Services Ltd.

## APPENDIX

### Laboratory Test Data

**Aubrey Davidson**

Site Analytical Services Ltd  
Units 14 -15  
River Road Business Park  
33 River Road  
Barking  
Essex  
IG11 0EA

t: 0208 5948134  
f: 0208 5948072  
e: SAS -

i2 Analytical Ltd.  
7 Woodshots Meadow,  
Croxley Green Business Park,  
Watford,  
Herts,  
WD18 8YS

t: 01923 225404  
f: 01923 237404  
e: reception@i2analytical.com

## **Analytical Report Number : 19-72185**

|                             |               |                               |            |
|-----------------------------|---------------|-------------------------------|------------|
| <b>Project / Site name:</b> | Rainham       | <b>Samples received on:</b>   | 15/11/2019 |
| <b>Your job number:</b>     | 19-31208      | <b>Samples instructed on:</b> | 15/11/2019 |
| <b>Your order number:</b>   | 6349          | <b>Analysis completed by:</b> | 22/11/2019 |
| <b>Report Issue Number:</b> | 1             | <b>Report issued on:</b>      | 22/11/2019 |
| <b>Samples Analysed:</b>    | 1 soil sample |                               |            |

**Signed:** *Karolina Marek*

Karolina Marek  
Technical Reviewer (Reporting Team)

**For & on behalf of i2 Analytical Ltd.**

Other office located at: ul. Pionierów 39, 41 -711 Ruda Śląska, Poland

Standard sample disposal times, unless otherwise agreed with the laboratory, are :

|           |                           |
|-----------|---------------------------|
| soils     | - 4 weeks from reporting  |
| leachates | - 2 weeks from reporting  |
| waters    | - 2 weeks from reporting  |
| asbestos  | - 6 months from reporting |

Excel copies of reports are only valid when accompanied by this PDF certificate.

Any assessments of compliance with specifications are based on actual analytical results with no contribution from uncertainty of measurement. Application of uncertainty of measurement would provide a range within which the true result lies. An estimate of measurement uncertainty can be provided on request.

Analytical Report Number: 19-72185

Project / Site name: Rainham

Your Order No: 6349

|                                         |  |  |  |               |                       |                         |      |  |
|-----------------------------------------|--|--|--|---------------|-----------------------|-------------------------|------|--|
| Lab Sample Number                       |  |  |  | 1363968       |                       |                         |      |  |
| Sample Reference                        |  |  |  | A             |                       |                         |      |  |
| Sample Number                           |  |  |  | None Supplied |                       |                         |      |  |
| Depth (m)                               |  |  |  | None Supplied |                       |                         |      |  |
| Date Sampled                            |  |  |  | 14/11/2019    |                       |                         |      |  |
| Time Taken                              |  |  |  | None Supplied |                       |                         |      |  |
| Analytical Parameter<br>(Soil Analysis) |  |  |  | Units         | Limit of<br>detection | Accreditation<br>Status |      |  |
| Moisture Content                        |  |  |  | %             | N/A                   | NONE                    | 12   |  |
| Total mass of sample received           |  |  |  | kg            | 0.001                 | NONE                    | 0.40 |  |

|                      |  |     |      |         |  |  |  |  |
|----------------------|--|-----|------|---------|--|--|--|--|
| Whole Sample Crushed |  | N/A | NONE | Crushed |  |  |  |  |
|----------------------|--|-----|------|---------|--|--|--|--|

|                         |      |     |           |              |  |  |  |  |
|-------------------------|------|-----|-----------|--------------|--|--|--|--|
| Asbestos in Soil Screen | Type | N/A | ISO 17025 | Not-detected |  |  |  |  |
|-------------------------|------|-----|-----------|--------------|--|--|--|--|

#### General Inorganics

|                                                                         |          |         |        |       |  |  |  |  |
|-------------------------------------------------------------------------|----------|---------|--------|-------|--|--|--|--|
| pH - Automated                                                          | pH Units | N/A     | MCERTS | 7.1   |  |  |  |  |
| Total Cyanide                                                           | mg/kg    | 1       | MCERTS | < 1   |  |  |  |  |
| Free Cyanide                                                            | mg/kg    | 1       | MCERTS | < 1   |  |  |  |  |
| Thiocyanate as SCN                                                      | mg/kg    | 5       | NONE   | < 5.0 |  |  |  |  |
| Total Sulphate as SO <sub>4</sub>                                       | mg/kg    | 50      | MCERTS | 440   |  |  |  |  |
| Water Soluble SO <sub>4</sub> 16hr extraction (2:1 Leachate Equivalent) | g/l      | 0.00125 | MCERTS | 0.018 |  |  |  |  |
| Sulphide                                                                | mg/kg    | 1       | MCERTS | 1.8   |  |  |  |  |
| Organic Matter                                                          | %        | 0.1     | MCERTS | 2.4   |  |  |  |  |

#### Total Phenols

|                            |       |   |        |       |  |  |  |  |
|----------------------------|-------|---|--------|-------|--|--|--|--|
| Total Phenols (monohydric) | mg/kg | 1 | MCERTS | < 1.0 |  |  |  |  |
|----------------------------|-------|---|--------|-------|--|--|--|--|

#### Speciated PAHs

|                        |       |      |        |        |  |  |  |  |
|------------------------|-------|------|--------|--------|--|--|--|--|
| Naphthalene            | mg/kg | 0.05 | MCERTS | < 0.05 |  |  |  |  |
| Acenaphthylene         | mg/kg | 0.05 | MCERTS | < 0.05 |  |  |  |  |
| Acenaphthene           | mg/kg | 0.05 | MCERTS | < 0.05 |  |  |  |  |
| Fluorene               | mg/kg | 0.05 | MCERTS | < 0.05 |  |  |  |  |
| Phenanthrene           | mg/kg | 0.05 | MCERTS | 0.39   |  |  |  |  |
| Anthracene             | mg/kg | 0.05 | MCERTS | < 0.05 |  |  |  |  |
| Fluoranthene           | mg/kg | 0.05 | MCERTS | 0.56   |  |  |  |  |
| Pyrene                 | mg/kg | 0.05 | MCERTS | 0.46   |  |  |  |  |
| Benzo(a)anthracene     | mg/kg | 0.05 | MCERTS | 0.41   |  |  |  |  |
| Chrysene               | mg/kg | 0.05 | MCERTS | 0.39   |  |  |  |  |
| Benzo(b)fluoranthene   | mg/kg | 0.05 | MCERTS | 0.19   |  |  |  |  |
| Benzo(k)fluoranthene   | mg/kg | 0.05 | MCERTS | 0.20   |  |  |  |  |
| Benzo(a)pyrene         | mg/kg | 0.05 | MCERTS | 0.18   |  |  |  |  |
| Indeno(1,2,3-cd)pyrene | mg/kg | 0.05 | MCERTS | < 0.05 |  |  |  |  |
| Dibenz(a,h)anthracene  | mg/kg | 0.05 | MCERTS | < 0.05 |  |  |  |  |
| Benzo(ghi)perylene     | mg/kg | 0.05 | MCERTS | < 0.05 |  |  |  |  |

#### Total PAH

|                             |       |     |        |      |  |  |  |  |
|-----------------------------|-------|-----|--------|------|--|--|--|--|
| Speciated Total EPA-16 PAHs | mg/kg | 0.8 | MCERTS | 2.78 |  |  |  |  |
|-----------------------------|-------|-----|--------|------|--|--|--|--|

#### Heavy Metals / Metalloids

|                                   |       |     |        |       |  |  |  |  |
|-----------------------------------|-------|-----|--------|-------|--|--|--|--|
| Arsenic (aqua regia extractable)  | mg/kg | 1   | MCERTS | 12    |  |  |  |  |
| Boron (total)                     | mg/kg | 1   | MCERTS | 7.7   |  |  |  |  |
| Cadmium (aqua regia extractable)  | mg/kg | 0.2 | MCERTS | 0.3   |  |  |  |  |
| Chromium (hexavalent)             | mg/kg | 4   | MCERTS | < 4.0 |  |  |  |  |
| Chromium (aqua regia extractable) | mg/kg | 1   | MCERTS | 22    |  |  |  |  |
| Copper (aqua regia extractable)   | mg/kg | 1   | MCERTS | 33    |  |  |  |  |
| Lead (aqua regia extractable)     | mg/kg | 1   | MCERTS | 200   |  |  |  |  |
| Mercury (aqua regia extractable)  | mg/kg | 0.3 | MCERTS | 1.0   |  |  |  |  |
| Nickel (aqua regia extractable)   | mg/kg | 1   | MCERTS | 12    |  |  |  |  |
| Selenium (aqua regia extractable) | mg/kg | 1   | MCERTS | < 1.0 |  |  |  |  |
| Zinc (aqua regia extractable)     | mg/kg | 1   | MCERTS | 80    |  |  |  |  |

#### Petroleum Hydrocarbons

|               |       |    |        |      |  |  |  |  |
|---------------|-------|----|--------|------|--|--|--|--|
| TPH C10 - C40 | mg/kg | 10 | MCERTS | < 10 |  |  |  |  |
|---------------|-------|----|--------|------|--|--|--|--|



**Analytical Report Number : 19-72185**

**Project / Site name: Rainham**

\* These descriptions are only intended to act as a cross check if sample identities are questioned. The major constituent of the sample is intended to act with respect to MCERTS validation. The laboratory is accredited for sand, clay and topsoil/loam soil types. Data for unaccredited types of solid should be interpreted with care.

| Lab Sample Number | Sample Reference | Sample Number | Depth (m)     | Sample Description *                            |
|-------------------|------------------|---------------|---------------|-------------------------------------------------|
| 1363968           | A                | None Supplied | None Supplied | Brown loam and clay with gravel and vegetation. |

**Analytical Report Number : 19-72185**

**Project / Site name: Rainham**

**Water matrix abbreviations: Surface Water (SW) Potable Water (PW) Ground Water (GW) Process Water (PrW)**

| Analytical Test Name                               | Analytical Method Description                                                                                                                                                              | Analytical Method Reference                                                                                                       | Method number | Wet / Dry Analysis | Accreditation Status |
|----------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------|---------------|--------------------|----------------------|
| Asbestos identification in soil                    | Asbestos Identification with the use of polarised light microscopy in conjunction with disperion staining techniques.                                                                      | In house method based on HSG 248                                                                                                  | A001-PL       | D                  | ISO 17025            |
| Crush Whole Sample                                 | Either: Client specific preparation instructions - sample(s) crushed whole prior to analysis; OR Sample unsuitable for standard preparation and therefore crushed whole prior to analysis. | In house method, applicable to dry samples only.                                                                                  | L019-UK       | D                  | NONE                 |
| Free cyanide in soil                               | Determination of free cyanide by distillation followed by colorimetry.                                                                                                                     | In-house method based on Examination of Water and Wastewater 20th Edition: Clesceri, Greenberg & Eaton (Skalar)                   | L080-PL       | W                  | MCERTS               |
| Hexavalent chromium in soil                        | Determination of hexavalent chromium in soil by extraction in water then by acidification, addition of 1,5 diphénylcarbazine followed by colorimetry.                                      | In-house method                                                                                                                   | L080-PL       | W                  | MCERTS               |
| Metals in soil by ICP-OES                          | Determination of metals in soil by aqua-regia digestion followed by ICP-OES.                                                                                                               | In-house method based on MEWAM 2006 Methods for the Determination of Metals in Soil.                                              | L038-PL       | D                  | MCERTS               |
| Moisture Content                                   | Moisture content, determined gravimetrically. (30 °C)                                                                                                                                      | In-house method based on BS1377 Part 2, 1990, Classification tests                                                                | L019-UK/PL    | W                  | NONE                 |
| Monohydric phenols in soil                         | Determination of phenols in soil by extraction with sodium hydroxide followed by distillation followed by colorimetry.                                                                     | In-house method based on Examination of Water and Wastewater 20th Edition: Clesceri, Greenberg & Eaton (skalar)                   | L080-PL       | W                  | MCERTS               |
| Organic matter (Automated) in soil                 | Determination of organic matter in soil by oxidising with potassium dichromate followed by titration with iron (II) sulphate.                                                              | BS1377 Part 3, 1990, Chemical and Electrochemical Tests""                                                                         | L009-PL       | D                  | MCERTS               |
| pH in soil (automated)                             | Determination of pH in soil by addition of water followed by automated electrometric measurement.                                                                                          | In-house method based on BS1377 Part 3, 1990, Chemical and Electrochemical Tests                                                  | L099-PL       | D                  | MCERTS               |
| Speciated EPA-16 PAHs in soil                      | Determination of PAH compounds in soil by extraction in dichloromethane and hexane followed by GC-MS with the use of surrogate and internal standards.                                     | In-house method based on USEPA 8270                                                                                               | L064-PL       | D                  | MCERTS               |
| Stones content of soil                             | Standard preparation for all samples unless otherwise detailed. Gravimetric determination of stone > 10 mm as % dry weight.                                                                | In-house method based on British Standard Methods and MCERTS requirements.                                                        | L019-UK/PL    | D                  | NONE                 |
| Sulphate, water soluble, in soil (16hr extraction) | Determination of water soluble sulphate by ICP-OES. Results reported directly (leachate equivalent) and corrected for extraction ratio (soil equivalent).                                  | In-house method based on BS1377 Part 3, 1990, Chemical and Electrochemical Tests, 2:1 water:soil extraction, analysis by ICP-OES. | L038-PL       | D                  | MCERTS               |
| Sulphide in soil                                   | Determination of sulphide in soil by acidification and heating to liberate hydrogen sulphide, trapped in an alkaline solution then assayed by ion selective electrode.                     | In-house method                                                                                                                   | L010-PL       | D                  | MCERTS               |
| Thiocyanate in soil                                | Determination of thiocyanate in soil by extraction in water followed by acidification followed by addition of ferric nitrate followed by discrete analyser (spectrophotometer).            | In-house method                                                                                                                   | L082-PL       | D                  | NONE                 |
| Total cyanide in soil                              | Determination of total cyanide by distillation followed by colorimetry.                                                                                                                    | In-house method based on Examination of Water and Wastewater 20th Edition: Clesceri, Greenberg & Eaton (Skalar)                   | L080-PL       | W                  | MCERTS               |
| Total sulphate (as SO4 in soil)                    | Determination of total sulphate in soil by extraction with 10% HCl followed by ICP-OES.                                                                                                    | In-house method based on BS1377 Part 3, 1990, Chemical and Electrochemical Tests                                                  | L038-PL       | D                  | MCERTS               |
| TPH Banding in Soil by FID                         | Determination of hexane extractable hydrocarbons in soil by GC-FID.                                                                                                                        | In-house method, TPH with carbon banding and silica gel split/cleanup.                                                            | L076-PL       | W                  | MCERTS               |

Iss No 19-72185-1 Rainham 19-31208

This certificate should not be reproduced, except in full, without the express permission of the laboratory.

The results included within the report are representative of the samples submitted for analysis.

Page 4 of 5

Analytical Report Number : 19-72185

Project / Site name: Rainham

Water matrix abbreviations: Surface Water (SW) Potable Water (PW) Ground Water (GW) Process Water (PrW)

| Analytical Test Name | Analytical Method Description | Analytical Method Reference | Method number | Wet / Dry Analysis | Accreditation Status |
|----------------------|-------------------------------|-----------------------------|---------------|--------------------|----------------------|
|----------------------|-------------------------------|-----------------------------|---------------|--------------------|----------------------|

For method numbers ending in 'UK' analysis have been carried out in our laboratory in the United Kingdom.

For method numbers ending in 'PL' analysis have been carried out in our laboratory in Poland.

Soil analytical results are expressed on a dry weight basis. Where analysis is carried out on as-received the results obtained are multiplied by a moisture correction factor that is determined gravimetrically using the moisture content which is carried out at a maximum of 30oC.

# H. SIVYER (TRANSPORT) LTD

ROADSTONE • AGGREGATES • BUILDING MATERIALS • CONCRETE  
TIPPERS • GRABS • PLANT & SITE CLEARANCE

Telephone 020 8778 1384

E-mail: info@hsivyer.com www.hsivyer.com

3 Herringham Road, London, SE7 8NJ

## DUTY OF CARE WASTE TRANSFER NOTE

Carrier's Registration No. CBDU96919 VAT Reg. No. 316 6900 61

Customer/Waste Producer

Site Address

Account: ☐

Cheque: ☐

Cash: ☐

Card: ☐

Amount: £

Date

Order No.

Transfer/Collection Point

Arrival Time:

Departure Time:

(Please note waiting time is chargeable after 30 minutes on site)

Driver:

(Full Name)

Vehicle Reg:

| PRIMARY PRODUCTS      | TIP | G/O | RECYCLED PRODUCTS   | WASTE / PLANT        |
|-----------------------|-----|-----|---------------------|----------------------|
| 100 PRIMARY TYPE 1    |     |     | 600 RECYCLED TYPE 1 | 800 MUCK AWAY        |
| 200 SHINGLE *         |     |     | 610 RECYCLED TYPE 2 | 810 GRAB MUCK AWAY   |
| 300 BALLAST *         |     |     | 620 RECYCLED TYPE 4 | 820 RUBBISH AWAY     |
| 400 SHARP SAND        |     |     | 640 HARDCORE        | 830 GRAB RUBBISH     |
| 410 REJECT SAND       |     |     | 650 ENVIROBLEND     | 840 SKIP CLEARED     |
| 420 BUILDING SAND     |     |     | MISCELLANEOUS       | 850 CONTAMINATED M/A |
| 430 WESTERHAM SAND *  |     |     | 710 WAITING TIME    | 860 TIP CHARGE       |
| 500 VERSATEX TARMAK   |     |     | 720 WASTED JOURNEY  | 900 DAYWORK          |
| 760 TOPSOIL (GRADE) * |     |     | 730 HAULAGE ONLY *  | 910 PLANT HIRE *     |
| JUMBO BAG             |     |     | 750 GRAB - OFF FEE  | 920 SWEEPER HIRE *   |

\*Additional Information:

Waste Description

E.W.C. CODE

TONNES

GROSS

TARE

NETT

LOOSE QUANTITY  
LOAD

CUBIC METRES

The above job has been completed satisfactorily. All materials supplied conform to the required standards.

Signed

Print Name

CUSTOMERS ORDERING VEHICLES OFF THE PUBLIC HIGHWAY DO SO AT THEIR OWN RISK.  
WHITE COPY - CUSTOMER PINK, BLUE - OFFICE YELLOW - DISPOSAL POINT