

1.18 Mechanical Ventilation Heat Recovery

Reference/ Item No.	Location	System	Model/Type	SFP	Air	Static	Fan	Electrical Supply					Comments	
								Quantity	Vol.	Flow	Speed	kW		V
				w/l/s	I/s	Pa	rpm							
MVHR	Plots	Heat Recovery Ventilation	TITUS HRV1 Q PLUS	76	60			0.08	230	1	50			Heat Exchange Efficiency: 91%