

## Meadow High School (Harefield), Northwood Road

### Conditions 13



Revision: P01

*13. Notwithstanding the plans hereby approved and prior to commencement of development above ground, a revised internal layout and/or a detailed scheme to mitigate against the fire safety risks of dead-end corridors and inner rooms shall be submitted to and approved in writing by the Local Planning Authority.*

**Dead-end corridors** at ground and first floor (2.96m & 4m):

Mitigation of this is proposed as L2 category fire detection and alarm system, 30min containing corridor separation from adjacent accommodation and sprinkler protection to the building.

A suitably vision panel not less than 0.1m<sup>2</sup> is provided in the door to enable occupants of the room to see if a fire has started.

This justification is covered in the Fire Report and the principle is agreed with the Approving Authority.

**Inner Rooms:**

As covered in the Fire Report, page 13.

*Additional Drawings:*

*TVC0024-NOV-V1-00-DR-A-PL12*

*TVC0024-NOV-V1-01-DR-A-PL13*