



Grosvenor House 11 St Paul's Square Birmingham B3 1RB

PORTABLE APPLIANCE TESTING (PAT) CERTIFICATE FOR HMO

Original Certificate

Certificate
reference

: 0803

DETAILS OF CLIENT/LANDLORD

Client/
Address: HAPPYHOME INVESTMENT LTD
141 Cleave Avenue Hayes Middlesex UB34HD

TEST EQUIPMENT DETAILS

Test Equipment used	Pat 3	Serial Number	37812		
Tested by	Gurdip Notay	Date	03/10/25	Retest Date	Oct 2026

Serial Number	Make and model	Location	240	Class 1,2,3	Fuse rating (A)	Insulation resistance MΩ	Earth continuity Ω	Plug, flex and body	OK to use ?
1	Fridge	Kitchen	240	1		>20MΩ	Yes	Good	Yes
2	Microwave	Kitchen	240	1		>20MΩ	Yes	Good	Yes
3	Washing Machine	Kitchen	240	1		>20MΩ	Yes	Good	Yes
4	Toaster	Kitchen	240	1		>20MΩ	Yes	Good	Yes
5	Lamps x 8	Bedrooms	240	1		>20MΩ	Yes	Good	Yes
6	TV x 8	Bedrooms	240	1		>20MΩ	Yes	Good	Yes
7	Kettle	Kitchen	240	1		>20MΩ	Yes	Good	Yes

□