


# Shelter



# FIELD END RD

184

184a

181

Fire Appliance

1:200



20 Meter



Assembly Point



Escape route

The existing partitions forming the protected staircase must provide one hour fire resistance. They must be lined with 2 layers 12.5mm plasterboard with staggered joints and skim.

The doors to bedrooms and any habitable room and the final exit door must not be fitted with a key on the inside. Thumbturns are acceptable,

SITE PLAN 1:200

Project:	186 Field End road Pinner HA5 1RF				
Title:	Site plan				
Scale:	1:200@A4	Date:	Feb 2023	Drawing No.:	HH06/101/SP
REVISION					
*					
***					