Richard Phillips

Anna Russell-Smith <anna.russell-smith@montagu-evans.co.uk> From:

Sent: 25 August 2021 14:13 Richard Phillips To:

RE: Northwood & Pinner Cottage Hospital & Northwood Health Centre, Pinner Subject:

Road - 23658/APP/2021/1296

Attachments: 17115_05_PLANNING DRAWING LIST WITH REVs.pdf

Richard

See attached updated plans and drawing schedule https://we.tl/t-Sz2s5fvav5

In terms of a Daylight and Sunlight update regarding the proposed units this will be with you later today in addition an updated addendum DAS

I note the timescales for the September committee are tight – can you confirm if we are still on track? Is there anything still outstanding?

Kind regards

Anna

Please note I am on leave from COP Friday 03 September until Monday 13 September 2021.

ANNA RUSSELL-SMITH PARTNER

Montagu Evans LLP, 70 St Mary Axe, London, EC3A 8BE d: 020 7312 7498 m: 07818 012 498 e: anna.russell-smith@montagu-evans.co.uk Property Week Best Places to Work 2018, 2019 and 2020



THINK BEFORE YOU PRINT OR POST. PLEASE CONSIDER THE ENVIRONMENT.

From: Richard Phillips [mailto:RPhillips@Hillingdon.Gov.UK]

Sent: 24 August 2021 14:16

To: Anna Russell-Smith <anna.russell-smith@montagu-evans.co.uk>

Subject: RE: Northwood & Pinner Cottage Hospital & Northwood Health Centre, Pinner Road -

23658/APP/2021/1296

Anna,

Thanks for the update.

From: Anna Russell-Smith <anna.russell-smith@montagu-evans.co.uk>

Sent: 24 August 2021 13:31

To: Richard Phillips <RPhillips@Hillingdon.Gov.UK>; Nadine James <nadine.james@montagu-evans.co.uk>

Subject: RE: Northwood & Pinner Cottage Hospital & Northwood Health Centre, Pinner Road -

23658/APP/2021/1296

Afternoon Richard, I hope you are well

I am pulling together a response to the below questions which I will issue over shortly.

However as an update with regards to the design I hope to submit to you revised plans by COP today to enable you to go out to re-consultation.

In the meantime if you have any comments or questions please do not hesitate to get in touch

Kind regards

Anna

Please note I am on leave from COP Friday 03 September until Monday 13 September 2021.

ANNA RUSSELL-SMITH PARTNER

Montagu Evans LLP, 70 St Mary Axe, London, EC3A 8BE d: 020 7312 7498 m: 07818 012 498 e: anna.russell-smith@montagu-evans.co.uk Property Week Best Places to Work 2018, 2019 and 2020





This e-mail is intended solely for the person to whom it is addressed. It may contain confidential or privileged information. If you have received it in error, please notify the sender immediately and destroy the transmission. You must not copy, distribute or take any action in reliance on it.

BEWARE OF CYBER-CRIME: Our banking details will not change during the course of a transaction. Should you receive a notification which advises a change in our bank account details, it may be fraudulent and you should notify Montagu Evans who will advise you accordingly.

Montagu Evans LLP is a limited liability partnership registered in England and Wales. Registered number OC312072. A list of members' names is available for inspection at the registered office 70 St Mary Axe, London EC3A 8BE.

From: Richard Phillips [mailto:RPhillips@Hillingdon.Gov.UK]

Sent: 20 August 2021 14:40

To: Nadine James < nadine.james@montagu-evans.co.uk >; Anna Russell-Smith < anna.russell-smith@montagu-

evans.co.uk>

Subject: Northwood & Pinner Cottage Hospital & Northwood Health Centre, Pinner Road - 23658/APP/2021/1296

Nadine / Anna,

My apologies, but not sure if you have seen the Access Officer's comments which will need to be addressed:-

Access Officer:

This proposal is for redevelopment of the former Cottage Hospital along Pinner Road comprising of two plots to include the relocation of the current Northwood Health Centre and two new buildings for 31 one bed units, 34 two-bed units, 5 three bed units, and associated amenities. In assessing this application, reference is made to London Plan policy D5, D7, D12, S4 and T6.1. The following observations are provided:

- 1. It is noted from the submitted DAS that seven accessible parking spaces will be provided for the residential element: one parking space for each required M4(3) unit. Additional accessible spaces should be provided for the M4(2) units and for visitors in accordance with policy T6.1.
- 2. A drop off point/facility should be provided for Dial a Ride, accessible taxis, ambulances and other door to door transport providers to board and alight passengers with ease. Such provision should be conveniently located within 50m of the principal entrances.
- 3. 10% of new residential units would need to meet the standards for M4(3) Category 3 wheelchair user dwelling. The units should be interspersed throughout the development, to include all typologies and tenures.
- 4. To meet the requirement set out in point 3 above, the preferred split would be for 2, one bed, 4, two bed, and 1, three bed units to meet M4(3) standards. 10% of Affordable Housing units would be required to satisfy the design standards for an M4(3) Wheelchair Accessible unit.
- 5. The accessible, affordable units should be suitable for 'day one occupation' by a wheelchair user. These units should be designed and fitted as per the prescribed standards for a Wheelchair Accessible M4(3) unit, as set out in ADM 2015. No details appear to have been submitted.
- 6. Where lift access is necessary to achieve a step free approach to the principal private entrance, all M4(3) units should be served by at least two lifts. It is unclear from the submitted plans where these wheelchair accessible/adaptable units would be located. Further clarity is requested.
- 7. A floor plan at no less than 1:100 should be submitted for each of the different M4(3) units. All details, to include transfer zones, wheelchair storage area, and other spatial requirements within bedrooms, bathrooms, living and dining areas, should be shown on a separate plan for every different unit type.
- 8. All remaining units must be designed to the standards for Category 2 M4(2) Accessible and Adaptable dwellings, as set out in Approved Document M 2015.
- 9. Details should be required on the accessible play equipment for disabled children, including those with a sensory impairment, or complex multiple disabilities. Provisions could include outdoor sound tubes, colour and lighting canopies, and other play equipment that could stimulate the olfactory senses. Inclusive play is a key requirement of any new residential development.
- 10. The development should include a minimum of one fire evacuation lift in accordance with London Plan policy D5 (B5) designed to meet the technical standards set out in BS EN 81-76, BS 9991 and/or BS 9999.

CONCLUSION: unacceptable. Further details should be submitted to address the above issues. Hillingdon Council routinely monitors the content of emails sent and received via its network for the purposes of ensuring compliance with its policies and procedures. The contents of this message are for the attention and use of the intended addressee only. If you are not the intended recipient or addressee, or the person responsible for sending the message you may not copy, forward, disclose or otherwise use it or any part of it in any way. To do so may be unlawful. If you receive this email by mistake please advise the

sender immediately. Where opinions are expressed they are not necessarily those of the London Borough of Hillingdon. Service by email is not accepted unless by prior agreement.

Hillingdon Council routinely monitors the content of emails sent and received via its network for the purposes of ensuring compliance with its policies and procedures. The contents of this message are for the attention and use of the intended addressee only. If you are not the intended recipient or addressee, or the person responsible for sending the message you may not copy, forward, disclose or otherwise use it or any part of it in any way. To do so may be unlawful. If you receive this email by mistake please advise the sender immediately. Where opinions are expressed they are not necessarily those of the London Borough of Hillingdon. Service by email is not accepted unless by prior agreement.