



LEGEND

X1	4M COLUMN MOUNTED LED LUMINAIRE	X	SINGLE PHASE ISOLATOR
X3	IP65 RATED WALL MOUNTED ARCHITECTURAL FLOODLIGHT	PR	PROXIMITY (FOB) READER
X4	IP64 RATED WALL MOUNTED BULKHEAD	EB	EGRESS BUTTON
X5	IP65 IN-GROUND UPLIGHTER	EB	EMERGENCY EXIT BREAK GLASS
X6	LIGHTING BOLLARD		
X7	IP65 MAINTAINED LED EMERGENCY LIGHTING BULKHEAD		
X8	EXTERNAL FEEDER PILLAR		
X9	ELECTRIC VEHICLE CHARGE POINT. 'X' DENOTES TYPE:		
	FC - FAST CHARGE POINT		
	RC - RAPID CHARGE POINT		
	F - FUTURE		
X10	BRACKET MOUNTED EXTERNAL CCTV CAMERA		
X11	COLUMN MOUNTED EXTERNAL CCTV CAMERA (ANPR DENOTES SEPARATE CAMERA SUPPLIED AS PART OF ANPR SYSTEM)		
X12	CABLE ACCESS BOXES AND/OR CABLE PITS TO BE DESIGN / SELECTED BY CONTRACTOR COVER PLATES TO BE PROVIDED TO MATCH LOCATION		
HV	125MM DIA DUCTING FOR HV INCOMER		
LV	125MM DIA DUCTING FOR LV INCOMER		
SUB	150MM DIA LV RIDGICOL DUCTING - FEEDER PILLAR SUB-MANS		
EVC	150MM DIA LV RIDGICOL DUCTING - ELECTRIC VEHICLE CHARGING		
LAP	110MM DIA / 94MM DIA ID LV RIDGICOL DUCTING FOR LIGHTING AND POWER		
SEC	63MM DIA / 50MM DIA ID EXTERNAL CCTV / SECURITY LV RIDGICOL DUCTING		

NOTES:

- CONTRACTOR SHALL PROVIDE PASSIVE DUCTS AND CHAMBERS FOR EVC NETWORK REQUIRED TO SERVE REMAINING PARKING BAYS FROM CURRENT 2 NO. EVCS BEING PROVIDED:
 - 1 NO. 50KW TWIN RAPID CHARGER
 - 1 NO. 22KW TWIN FAST CHARGER
- ALL EVC UNITS TO BE PROVIDED WITH PROTECTIVE HOOPS/BARRIERS.
- FINAL SETTING OUT OF EVC UNITS TO BE AS PER THE LANDSCAPE ARCHITECTS REQUIREMENTS.

03/09/24	PRELIMINARY ISSUE	P1	PC
Date	Description	Rev	By

Revision Description

Rev	Description

hulley & kirkwood
 consulting engineers
 London Office
 Castle House Horizon Centre
 28-38 Upper High Street
 Epsom
 Surrey
 KT17 4RS
 Tel No: 01372 747 047
 E: hk.london@hulley.co.uk

...Making Buildings Work

Project:
 NORTHWOOD & PINNER HEALTH CENTRE P23

Drawing Title:
 EXTERNAL SERVICES LAYOUT
 SHEET 2 OF 3
 CENTRAL

Drawing Number:
 41935(60)903

Revision: P1
Date: 03/07/2024
Scale: 1:100
Drawn By: PC
CAD Dwg File: 41935(60)903.dwg
Arch. Base Dwg:

Issue Status:
 PRELIMINARY