



41-67 High Street  
Yiewsley

GLA Energy Comments  
Supplemental Information



**Client Name:** Harbourside Investments Limited and WM Morrison Supermarkets Plc

**Client Address:** c/o Citygrove  
10 Albemarle  
London  
W1S 4HH

**Property:** 43-67 High Street  
Yiewsley  
West Drayton  
UB7 7QQ

**Project Reference:** 5343

**Issue:** Issue 1:

**Date:** March 2025

**Prepared by:** AJ / MC

**Checked by:** MDC

**Validated by:** MDC



The supplemental information contained in this document is referenced and numbered in the same manner as per the GLA queries and comments.

GLA Comment Reference	Supporting Information
<b>General compliance comments</b>	
1	No associated supporting evidence required.
2	Updated GLA spreadsheets will be submitted as part of the proposed planning condition discharge.
<b>Be Lean</b>	
3	Wall build-ups and U valves will be submitted as part of the proposed planning condition discharge.
4	Updated supermarket unit lean BRUKL.
5	No associated supporting evidence required.
<b>Overheating</b>	
6	The manufacturer's detail for the acoustic ventilator incorporating an EMV fan will be submitted as part of the proposed planning condition discharge.
7	No associated supporting evidence required. Item Closed.
<b>Be Clean</b>	
8	The DEN correspondence
9	No associated supporting evidence required.
10	No associated supporting evidence required.
11	Updated PV layout.
12	No associated supporting evidence required.
13	No associated supporting evidence required.
14	No associated supporting evidence required.
15	No associated supporting evidence required.
16	No associated supporting evidence required. Item Closed.
17	No associated supporting evidence required.
18	The updated carbon reduction modelling results will be submitted as part of the proposed planning condition discharge.
19	No associated supporting evidence required. Item Closed.



GLA Comment Reference	Supporting Information
4	Updated supermarket unit lean BRUKL.



### Project name

**Supermarket Lean**

**As designed**

**Date:** Fri Feb 21 12:54:47 2025

### Administrative information

#### Building Details

**Address:** Supermarket, High St, PFC, AP 2.5, PV 48, Yiewsley,

#### Certifier details

**Name:** Jeremy Holgate

**Telephone number:** 01932 781 641

**Address:** 51 Staines Road West, Sunbury-on-Thames, TW16 7AH

#### Certification tool

**Calculation engine:** TAS

**Calculation engine version:** "v9.5.6"

**Interface to calculation engine:** TAS

**Interface to calculation engine version:** v9.5.6

**BRUKL compliance module version:** v6.1.e.0

**Foundation area [m<sup>2</sup>]:** 1836

### The CO<sub>2</sub> emission and primary energy rates of the building must not exceed the targets

Target CO <sub>2</sub> emission rate (TER), kgCO <sub>2</sub> /m <sup>2</sup> :annum	3.28
Building CO <sub>2</sub> emission rate (BER), kgCO <sub>2</sub> /m <sup>2</sup> :annum	2.71
Target primary energy rate (TPER), kWh <sub>PE</sub> /m <sup>2</sup> :annum	35.84
Building primary energy rate (BPER), kWh <sub>PE</sub> /m <sup>2</sup> :annum	29.43
Do the building's emission and primary energy rates exceed the targets?	BER <= TER    BPER <= TPER

### The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Fabric element	U <sub>a</sub> -Limit	U <sub>a</sub> -Calc	U <sub>i</sub> -Calc	First surface with maximum value
Walls*	0.26	0.16	0.26	External Wall (BMT)
Floors	0.18	0.18	0.18	Exposed Floor (to carpark)
Pitched roofs	0.16	-	-	No pitched roofs in project
Flat roofs	0.18	0.14	0.14	Roof - Supermarket Retail
Windows** and roof windows	1.6	1.42	1.42	Morr_wind 1
Rooflights***	2.2	-	-	No rooflights in project
Personnel doors <sup>^</sup>	1.6	1.53	2	ware door
Vehicle access & similar large doors	1.3	1.3	1.3	vehicle door
High usage entrance doors	3	-	-	No high usage entrance doors in project

U<sub>a</sub>-Limit = Limiting area-weighted average U-values [W/(m<sup>2</sup>K)]

U<sub>i</sub>-Calc = Calculated maximum individual element U-values [W/(m<sup>2</sup>K)]

U<sub>a</sub>-Calc = Calculated area-weighted average U-values [W/(m<sup>2</sup>K)]

\* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

\*\* Display windows and similar glazing are excluded from the U-value check.      \*\*\* Values for rooflights refer to the horizontal position.

^ For fire doors, limiting U-value is 1.8 W/m<sup>2</sup>K

NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

Air permeability	Limiting standard	This building
m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa	8	2.5

## Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

<b>Whole building lighting automatic monitoring &amp; targeting with alarms for out-of-range values</b>	YES
<b>Whole building electric power factor achieved by power factor correction</b>	>0.95

1- Oven Fresh Extract 10ACH (Preparation Oven Fresh)

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0	-	-	-	-
<b>Standard value</b>	N/A	N/A	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES

2- Prep and Bake Off extract 5ACH (2 Zones)

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0	-	-	-	-
<b>Standard value</b>	N/A	N/A	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES

3- Retail - MV Recirc

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0	-	-	1.13	-
<b>Standard value</b>	N/A	N/A	N/A	1.9 <sup>^</sup>	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES

<sup>^</sup> Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

4- Office/Staff - MVHR VRF (2 Zones)

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0	5	-	-	0.85
<b>Standard value</b>	N/A	5	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES

5- Warehouse - ASHP HeatOnly NV (Warehouse 1)

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	2.64	-	-	-	-
<b>Standard value</b>	N/A	N/A	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES

1- Domestic hot water ASHP

	Water heating efficiency	Storage loss factor [kWh/litre per day]
<b>This building</b>	2.86	0
<b>Standard value</b>	1	N/A

## Zone-level mechanical ventilation, exhaust, and terminal units

ID	System type in the Approved Documents
A	Local supply or extract ventilation units
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal balanced supply and extract ventilation system
E	Local balanced supply and extract ventilation units
F	Other local ventilation units
G	Fan assisted terminal variable air volume units
H	Fan coil units
I	Kitchen extract with the fan remote from the zone and a grease filter

NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

Zone name	SFP [W/(l/s)]									HR efficiency	
	A	B	C	D	E	F	G	H	I		
ID of system type	0.3	1.1	0.5	2.3	2	0.5	0.5	0.4	1	Zone	Standard
Ware office 1	-	-	-	1	-	-	-	-	-	-	N/A
Staff Room 1	-	-	-	1	-	-	-	-	-	-	N/A
Preparation Oven Fresh	-	-	-	-	-	-	-	-	1	-	N/A
Preparation Bake off	-	-	-	-	-	-	-	-	1	-	N/A
Preparation Fresh Prep	-	-	-	-	-	-	-	-	1	-	N/A

General lighting and display lighting		General luminaire	Display light source	
Zone name	Standard value	Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m <sup>2</sup> ]
Staircase	95	95	95	-
Retail Sales 1	120	110	110	-
Retail Sales 2	120	110	110	-
Warehouse 1	140	-	-	-
Plant 1	105	-	-	-
Electric Supply	105	-	-	-
Ware office 1	110	-	-	-
Lobby	95	95	95	-
Staff Room 1	105	95	95	-
Lockers 1	105	-	-	-
WCs 1	105	-	-	-
Preparation Oven Fresh	110	-	-	-
Retail Sales 3	120	110	110	-
Preparation Bake off	110	-	-	-
Preparation Fresh Prep	110	-	-	-

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
Staircase	NO (-29%)	NO
Retail Sales 1	NO (-85%)	NO
Retail Sales 2	NO (-90%)	NO
Ware office 1	N/A	N/A
Lobby	NO (-60%)	NO
Staff Room 1	N/A	N/A
Retail Sales 3	YES (+28%)	NO

Regulation 25A: Consideration of high efficiency alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	YES
Is evidence of such assessment available as a separate submission?	YES
Are any such measures included in the proposed design?	YES

# Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters		Building Use		
	Actual	Notional	% Area	Building Type
Floor area [m <sup>2</sup> ]	1838	1838	100	<b>Retail/Financial and Professional Services</b>
External area [m <sup>2</sup> ]	4614	4614		Restaurants and Cafes/Drinking Establishments/Takeaways
Weather	LON	LON		Offices and Workshop Businesses
Infiltration [m <sup>3</sup> /hm <sup>2</sup> @ 50Pa]	3	3		General Industrial and Special Industrial Groups
Average conductance [W/K]	923	937		Storage or Distribution
Average U-value [W/m <sup>2</sup> K]	0.2	0.2		Hotels
Alpha value* [%]	21.58	6.58		Residential Institutions: Hospitals and Care Homes
				Residential Institutions: Residential Schools
				Residential Institutions: Universities and Colleges
				Secure Residential Institutions
				Residential Spaces
				Non-residential Institutions: Community/Day Centre
				Non-residential Institutions: Libraries, Museums, and Galleries
				Non-residential Institutions: Education
				Non-residential Institutions: Primary Health Care Building
				Non-residential Institutions: Crown and County Courts
				General Assembly and Leisure, Night Clubs, and Theatres
				Others: Passenger Terminals
				Others: Emergency Services
				Others: Miscellaneous 24hr Activities
				Others: Car Parks 24 hrs
				Others: Stand Alone Utility Block

\* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

## Energy Consumption by End Use [kWh/m<sup>2</sup>]

	Actual	Notional
Heating	1.21	0.07
Cooling	0.71	1.25
Auxiliary	5.98	7.97
Lighting	10.92	13.68
Hot water	1.09	1.35
Equipment*	165.51	165.51
<b>TOTAL**</b>	<b>19.91</b>	<b>24.31</b>

\* Energy used by equipment does not count towards the total for consumption or calculating emissions.

\*\* Total is net of any electrical energy displaced by CHP generators, if applicable.

## Energy Production by Technology [kWh/m<sup>2</sup>]

	Actual	Notional
Photovoltaic systems	0	0
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0
<i>Displaced electricity</i>	<i>0</i>	<i>0</i>

## Energy & CO<sub>2</sub> Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m <sup>2</sup> ]	25.56	21.6
Primary energy [kWh <sub>PE</sub> /m <sup>2</sup> ]	29.43	35.84
Total emissions [kg/m <sup>2</sup> ]	2.71	3.28

## HVAC Systems Performance

System Type	Heat dem MJ/m <sup>2</sup>	Cool dem MJ/m <sup>2</sup>	Heat con kWh/m <sup>2</sup>	Cool con kWh/m <sup>2</sup>	Aux con kWh/m <sup>2</sup>	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER
<b>[ST] Constant volume system (variable fresh air rate), [HS] ASHP, [HFT] Electricity, [CFT] Electricity</b>									
Actual	0	0	0	0	57	0	0	0	0
	Notional	0	0	0	33.6	0	0	----	----
<b>[ST] Constant volume system (variable fresh air rate), [HS] ASHP, [HFT] Electricity, [CFT] Electricity</b>									
Actual	0	0	0	0	31.5	0	0	0	0
	Notional	0	0	0	18.3	0	0	----	----
<b>[ST] Central heating using air distribution, [HS] ASHP, [HFT] Electricity, [CFT] Electricity</b>									
Actual	0	0	0	0	5.1	0	0	0	0
	Notional	0	0	0	6.8	0	0	----	----
<b>[ST] Split or multi-split system, [HS] ASHP, [HFT] Electricity, [CFT] Electricity</b>									
Actual	0	449.2	0	25	3.6	0	5	0	5
	Notional	0	699.8	0	44.2	6.4	0	4.4	----
<b>[ST] Split or multi-split system, [HS] ASHP, [HFT] Electricity, [CFT] Electricity</b>									
Actual	0	0	0	0	0	0	0	0	0
	Notional	3.8	0	0.4	0	10.4	2.64	0	----

### Key to terms

Heat dem [MJ/m <sup>2</sup> ]	= Heating energy demand
Cool dem [MJ/m <sup>2</sup> ]	= Cooling energy demand
Heat con [kWh/m <sup>2</sup> ]	= Heating energy consumption
Cool con [kWh/m <sup>2</sup> ]	= Cooling energy consumption
Aux con [kWh/m <sup>2</sup> ]	= Auxiliary energy consumption
Heat SSEFF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type



GLA Comment Reference	Supporting Information
8	The DEN correspondence

<https://maps.london.gov.uk/heatmap/projects/5343-yiewsley-1>

**Source**

E.ON

**Energy Centre name**

DGV

**Network Operator**

E.ON

**Network operator contact details**

Mike Wake districtheating@eonenergy.com

**Year of construction (if applicable)**

2017

**Current network peak demand (kW)**

--

**Other notes**

--

**Network LZC technologies**

CHP

**Heat network name**

DGV

**Network peaking plant technologies**

Gas Boilers

**LZC technology capacity (kW)**

650

**Peaking plant capacity (kW)**

4,200

**Information last updated**

Sep-23

**Network supply temperature**

--


**Status**

Existing - Not Fully Built Out

**Name**

DGV

## MAYOR OF LONDON Heat Map




## Jeremy Holgate

**From:** Jeremy Holgate  
**Sent:** 28 February 2024 18:06  
**To:** districtheating@eonenergy.com  
**Cc:** Mike Cousins  
**Subject:** Enquiry re DHN (district heat networks)

FAO Mike Wake

We are working on behalf of a developer for the proposed development of the 43-67 High Street, Yiewsley site in the London Borough of Hillingdon. We are currently looking to fulfil our obligations under local and GLA policy which requires us to investigate and demonstrate that connection to an existing or planned district heating network has been investigated within our design.

The London Heat Map has been reviewed and we have identified that there is a decentralised energy scheme (DES) operated by EON in Drayton. I sourced your email from this site. The below image taken from the London Heat Map identifies the DGV Network on the other side of the railway line in West Drayton in excess of 1.2 km away at its nearest point.



Please can you confirm if there are any further plans for expansion of this district heating infrastructure above what is indicated on the London Heat Map? If you have any queries in regards to the above, please let me know.

Thanks

**Jeremy Holgate**  
Senior Building Performance Engineer



t: 01932 781 641  
m: 07801 206 441

w: [www.watkinspayne.co.uk](http://www.watkinspayne.co.uk)  
e: [jholgate@watkinspayne.co.uk](mailto:jholgate@watkinspayne.co.uk)




## Jeremy Holgate

**From:** Jeremy Holgate  
**Sent:** 28 February 2024 17:53  
**To:** planning@hillingdon.gov.uk  
**Cc:** Mike Cousins  
**Subject:** Hillingdon - Enquiry for planned DHN (district heat networks)

To Whom it May Concern,

We are working on behalf of Harbourside Investments Limited and WM Morrison Supermarkets Plc for the proposed development of the 43-67 High Street, Yiewsley site in the London Borough of Hillingdon. We are currently looking to fulfil our obligations under local and GLA policy which requires us to investigate and demonstrate that connection to an existing or planned district heating network has been prioritised within our design. Please could this email be forwarded to the energy officer in the planning team.

The London Heat Map has been reviewed and it is our conclusion that there is not a suitable decentralised energy scheme (DES) available within a reasonable distance from the proposed development site. The below image taken from the London Heat Map identifies the DGV Network operated by EON on the other side of the railway line in West Drayton but this is in excess of 1.2 km away at its nearest point. Therefore, the DES is not a viable option for the proposed development, however it is intended that the development will be future proofed such that it can connect to a district energy network in the future should one become available.



Please can you confirm that you are in agreement with the above analysis and that there are no further plans for additional district heating infrastructure above what is indicated on the London Heat Map. If you have any queries in regards to the above, please let me know.

Thanks

**Jeremy Holgate**  
Senior Building Performance Engineer




t: 01932 781 641  
m: 07801 206 441

w: [www.watkinspayne.co.uk](http://www.watkinspayne.co.uk)  
e: [jholgate@watkinspayne.co.uk](mailto:jholgate@watkinspayne.co.uk)





GLA Comment Reference	Supporting Information
11	Updated PV layout.



1. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE SPECIFICATION AND LEGEND DRAWING.  
2. DO NOT SCALE FROM THIS DRAWING.

Ref.	Revision	Date
<b>PLANNING</b>		
<b>Watkins Payne</b>  info@watkinspayne.co.uk   www.watkinspayne.co.uk <small>LONDON OFFICE 5th FLOOR 20 STAMFORD STREET LONDON W1D 2SP TEL: 020 763 322</small>		
<b>Client</b> <b>HARBOURSIDE INVESTMENTS LIMITED AND WM MORRISON SUPERMARKETS PLC</b>		
<b>Project</b> <b>MORRISONS HIGH STREET YIEWSLEY</b>		
<b>Title</b> <b>ROOF PHOTOVOLTAIC LAYOUT</b>		
Date	MARCH 2023	Scale of A0 1:100
Drawn By	JH	Validated
Checked		
Drawing Number	5343-E-999	
Revision	2	