

0m 1m 2m 3m 4m 5m

VISUAL SCALE 1:50 @ A1

0m 2m 4m 6m 8m 10m

VISUAL SCALE 1:100 @ A1

BENJAMIN
ASSOCIATES LTD
31 Danemead Grove
Northolt
Middlesex
UB5 4NX

Tel 0208 423 0608
Fax 0208 357 9714

www.benjaminassociates.co.uk

CIOB Chartered
Building
Consultants



GENERAL
ALL WORK TO BE CARRIED OUT TO LOCAL AUTHORITY APPROVAL AND IN ACCORDANCE WITH THE CURRENT BUILDING REGULATIONS AND CODES OF PRACTICE
ALL DIMENSIONS AND LEVELS TO BE CHECKED ON SITE AND ANY DISCREPANCIES TO BE REPORTED IMMEDIATELY
CONTRACTOR IS RESPONSIBLE FOR SETTING OUT THE WORKS
ALL STYLING WORK TO BE CARRIED OUT IN ACCORDANCE WITH ENGINEER'S DESIGN AND DETAILS
DO NOT SCALE DRAWINGS
DRAWINGS PRODUCED FOR THE PURPOSE OF OBTAINING BUILDING REGULATIONS APPROVALS ONLY AND DO NOT CONSTITUTE FULL WORKING DRAWINGS

ALL DRAWINGS ARE THE COPYRIGHT OF BENJAMIN ASSOCIATES LTD THIS DRAWING MAY NOT BE COPIED BY ANY THIRD PARTIES WITHOUT PRIOR PERMISSION

Foundations: concrete strip foundation to be 100mm width/conc. mix 1:2:4. Foundation depth to be 1200mm below lowest ground level or to level of adjacent drains whichever is deeper. All drains below ground level to be 100mm dia. Conc. to be 100mm dia w/c to be 100mm dia pipe. All traps to be 75mm deep. Provide discharge eye at change of direction, floor w/c to have silt stack. Silt terminal to be higher than any overflow of sanitary drainage system. All drains to be 100mm dia. Conc. to be 100mm dia w/c to be 100mm dia pipe. All drains below ground level to be 100mm dia. Replaster similar clay pipes laid to min 1:40 Fall and in accordance manufacturers instructions.

Drainage: All internal pipes above ground level to be PVC sink to have 50mm dia. up to 4m length, basis to have 25mm dia up to 1.7m Length, shower to have 50mm dia w/c to have 100mm dia pipe. All traps to be 75mm deep. Provide discharge eye at change of direction, floor w/c to have silt stack. Silt terminal to be higher than any overflow of sanitary drainage system. All drains to be 100mm dia. Conc. to be 100mm dia w/c to be 100mm dia pipe. All drains below ground level to be 100mm dia. Replaster similar clay pipes laid to min 1:40 Fall and in accordance manufacturers instructions.

Existing position of drainage & manholes to be investigated on site during the construction. The new drainage laid to suit position of MH and invert level and to be approved by building control surveyor. Internal manhole to be completely removed.

Drainage: All internal pipes above ground level to be PVC sink to have 50mm dia. up to 4m length, basis to have 25mm dia up to 1.7m Length, shower to have 50mm dia w/c to have 100mm dia pipe. All traps to be 75mm deep. Provide discharge eye at change of direction, floor w/c to have silt stack. Silt terminal to be higher than any overflow of sanitary drainage system. All drains to be 100mm dia. Conc. to be 100mm dia w/c to be 100mm dia pipe. All drains below ground level to be 100mm dia. Replaster similar clay pipes laid to min 1:40 Fall and in accordance manufacturers instructions.

Existing position of drainage & manholes to be investigated on site during the construction. The new drainage laid to suit position of MH and invert level and to be approved by building control surveyor. Internal manhole to be completely removed.

Ventilation: Rapid ventilation to all habitable rooms and sanitary accommodation if separate from bathroom to be minimum 1/20th of floor area.

Background ventilation to all habitable rooms to have 8000 sq mm kitchen to have 4000sq mm sanitary accommodation to have 4000 sq mm.

Mechanical extract ventilation: Kitchen to have 30 litres/sec. in adjacent to hob. 60 litres/sec down stairs and up stairs. Extract fan capable of extracting 15 litres/sec with 15 minutes overrun connected to light switch.

Doors and windows: all new external doors and windows to be aluminium double glazed with night ventilation of min area 100sq mm.

All new doors & side panels to have safety laminated glazing between finished floor level and 1500mm above that level. Windows and partitions to have laminated safety glazing between finished floor level and 800mm above that level.

Habitable room must have emergency egress window of opening minimum 450mm wide and 700mm high. All double glazed windows to be 28mm with 6.4mm outer laminated glass and inner 4mm clear glass. 17.8mm air gap, argon filled and a "soft" low-E coating double glazed unit to achieve "U" value of at least 1.6W/m².K. Windows to comply with L1: 2006.

Flor: 75mm thick 1:4 cement/sand screed with 10mm crack width. 200kg bags perlite, aggregate 10mm PVA and 10mm mineral aggregate. 100mm thick 0.8m wide 150mm thick RC (A142 mesh) FND2 conc. slab on 1200 gauge polythene P.M on 50mm sand bedding on compacted DOT Type 1 granular fill hardcore. Slab to be screeded below internal walls. 25mm thickness of 1:10 cement/sand screed with 10mm crack width. 200kg bags perlite, aggregate brought up to edges of slab to LAP DPC in walls and all joints lapped and sealed.

Wall: To achieve minimum U value of 0.28W/m²K. New cavity wall to comprise of 10mm facing brick to match existing. Fill the cavity with 100mm Rockwool Cavity insulation as manufacturer's details. Inner leaf to be 100mm lightweight block, K value 0.16. (Aercrete, Celcon solar, Topblock triple standard). Internal finish to be 12.5mm plasterboard on dabs. Walls to be built with 1:1.6 cement mortar.

Wall ties to be single stainless steel evenly spaced at 750mm centres horizontally staggered in alternate courses an 450mm centres vertically. Provide additional tie beneath the lowest row of insulation bats and double at reveals.

Callouts to be to external openings and filled with insulation. Wall connector new wall connected to existing wall with 'T'fix steel connector or similar. Polyisoprene sealant pointing to external joints.

Stud partition to 50 x 100 studs at 400cc with 12.5mm plaster board skin finished. 50x100mm base plate of stud partition supported on floors with 50 x 100 nogging@ 400 c/c void with partition filled with rockwool rollbatts.

Damp Proof Course: Hessian based felt or similar horizontal and vertical D.P.C. to walls D.P.C. 150mm minimum above all adjoining ground level, D.P.C under window cill and reveals. All damp proof elements to be lapped and bonded with existing D.P.C.

Flat Roof (Warm): (imposed load max 1.0 kN/m², dead load max 0.75 kN/m²) 12.5mm screed U value 0.18 W/m²K. 12.5mm screed reflector battings to achieve as designated fire rating for surface spread of flame bedded in bitumen on three layer felt to BS 6229:2003 on 22mm external quality (ply optional, see manufacturer's details) over 120mm Celotex Crown-U. Insulation board to VCL (see manufacturer's details) over 120mm Celotex Crown-U. 12.5mm screed reflector battings to give 1:60 fall on 47 x 150mm C24 timber joists at 400 cts to give a max span of 4.5m (see engineer's details for sizes). Ceilings to be 12.5mm plasterboard over vapour barrier with skim plaster finish. Provide restraint to flat roof by fixing 30 x 5 x 100mm ms galvanised lateral restraint straps at maximum 200mm centres fixed to 100 x 50mm walls and anchored to wall.

Electrical: PVC cables should be fixed to the structure. All cables must be in accordance with BS 6000. PVC must not be cut through or in direct contact with any expanded polystyrene insulation. recessed fittings designed for compact fluorescent or low voltage tungsten halogen lamps should only be used within enclosure, set between the joists, to dissipate heat. If recessed light fittings are used, ensure that the floor maintains a full half hour period of fire resistance.

All electrical works required to meet the provision of part P (electrical safety) must be designed, installed, inspected and tested by a person competent to do so.

Prior to electrical completion the council should be satisfied that the part P has been compiled with the relevant regulations and that the electrical installation certificate to be issued by a person competent to do so.

Lighting and electrical works: Lighting to new extension and loft conversion to be efficient lighting that only take lamps luminous of efficiency greater than 40 luminous per circuit-watts. All electrical works must be designed, installed, inspected and tested by a competent person.

Client Mr Anthony Strachan

Address 15 Kewferry Road
Northwood
Middlesex
HA6 2NS

Project name First floor rear extension

Project number 15KEW/020



Date March 2024

Drawn by Author

Checked by Checker

Sheet number A112

Scale 1 : 50



Proposed first Floor

1 : 50

19