

General Information

Location	West Dublin
Number of Units	110
Apartment size	72 m ²
No. of Wetrooms	K + 2
Product Status	Victorum 150L

Floor U-value (W/m ² K)	NA
Roof U-value (W/m ² K)	NA
Wall U-value (W/m ² K)	0.18
Window U-value (W/m ² K)	1.2
Window G-value	NA
Thermal Bridging (W/m ² K)	0.15
Air Permeability (m ³ /hr/m ²)	3



January
February
March
April
May
June
July
August
September
October
November
December
Total
Sum Total
Total SCOP

Load		Usage Heating (kWh's)		Usage DHW (kWh's)	
Heating	DHW	Heat Pump	Back Up Elec	Heat Pump	Back Up Elec
260	337	54	4	67	32
216	304	40	2	62	24
159	339	48	2	67	24
84	296	20		60	8
15	261	3		51	
68	278	16	3	57	14
177	328	40	4	67	37
242	313	55	7	67	31
1220	2456	276	23	498	170
3676		299		669	
		4,08		3,67	

Overall System SCOP: 3,80

For more information visit:



www.joule.ie




www.jouleuk.co.uk

System Selection

Selection of houses, duplexes & apartments all built and finished to the highest standards.

Address

Lucan, Co. Dublin



For more information visit:



www.joule.ie



www.jouleuk.co.uk