

DELEGATED DECISION

- Please select each of the categories that enables this application to be determined under delegated powers
 - Criteria 1 to 5 or criteria 7 to 9 must be addressed for all categories of application, except for applications for Certificates of Lawfulness, etc.

APPROVAL RECOMMENDED: GENERAL

Select Option

- | | |
|--|--------------------------|
| 1. No valid planning application objection in the form of a petition of 20 or more signatures, has been received | ☐ |
| 2. Application complies with all relevant planning policies and is acceptable on planning grounds | ☐ |
| 3. There is no Committee resolution for the enforcement action | ☐ |
| 4. There is no effect on listed buildings or their settings | ☐ |
| 5. The site is not in the Green Belt (but see 11 below) | ☐ |

REFUSAL RECOMMENDED: GENERAL

- | | |
|--|--------------------------|
| 6. Application is contrary to relevant planning policies/standards | ☐ |
| 7. No petition of 20 or more signatures has been received | ☐ |
| 8. Application has not been supported independently by a person/s | ☐ |
| 9. The site is not in Green Belt (but see 11 below) | ☐ |

RESIDENTIAL DEVELOPMENT

- | | |
|--|--------------------------|
| 10. Single dwelling or less than 10 dwelling units and/or a site of less than 0.5 ha | ☐ |
| 11. Householder application in the Green Belt | ☐ |

COMMERCIAL, INDUSTRIAL AND RETAIL DEVELOPMENT

- | | |
|--|--------------------------|
| 12. Change of use of retail units on site less than 1 ha or with less than 1000 sq m other than a change involving a loss of A1 uses | ☐ |
| 13. Refusal of change of use from retail class A1 to any other use | ☐ |
| 14. Change of use of industrial units on site less than 1 ha or with less than 1000sq.m. of floor space other than to a retail use. | ☐ |

CERTIFICATE OF LAWFULNESS

- | | |
|---|--------------------------|
| 15. Certificate of Lawfulness (for proposed use or Development) | ☐ |
| 16. Certificate of Lawfulness (for existing use or Development) | ☐ |
| 17. Certificate of Appropriate Alternative Development | ☐ |

CERTIFICATE OF LAWFULNESS

- | | |
|---|--------------------------|
| 18. ADVERTISEMENT CONSENT (excluding Hoardings) | ☐ |
| 19. PRIOR APPROVAL APPLICATION | ☐ |
| 20. OUT-OF-BOROUGH OBSERVATIONS | ☐ |
| 21. CIRCULAR 18/84 APPLICATION | ☐ |
| 22. CORPSEWOOD COVENANT APPLICATION | ☐ |
| 23. APPROVAL OF DETAILS | ☐ |
| 24. ANCILLARY PLANNING AGREEMENT (S.106 or S.278) where Heads of Terms have already received Committee approval | ☐ |
| 25. WORKS TO TREES | ☐ |
| 26. OTHER (please specify) | ☐ |

The delegation powers schedule has been checked. Director of Residents Services can determine this application.

Case Officer

Signature:

Date:

A delegated decision is appropriate and the recommendation, conditions/reasons for refusal and informatives are satisfactory.

Team Manager:

Signature:

Date:

The decision notice for this application can be issued.

Director / Member of Senior Management Team:

Signature:

Date:

NONE OF THE ABOVE DATES SHOULD BE USED IN THE PS2 RETURNS TO THE ODPM

Report of the Head of Planning, Sport and Green Spaces

Address 80 BEDFORD ROAD RUISLIP

Development: Single storey rear extension, single storey side extension and conversion of roof space to habitable use to include a rear dormer, 2 front rooflights and conversion of roof from hip to gable end with a new gable end window (Application for a Certificate of Lawful Development for a Proposed Development)

LBH Ref Nos: **34610/APP/2015/2778**

Drawing Nos: Drawing No. 11
Drawing No. 10A
Drawing No. 09
Drawing No. 08
Drawing No. 07
Drawing No. 06B
Drawing No. 05
Drawing No. 04
Drawing No. 03
Drawing No. 01
Drawing No. 02
Drawing No. 12

Date Plans Received: 24/07/2015 **Date(s) of Amendment(s):**

Date Application Valid: 24/07/2015

1. RECOMMENDATIONS

1.1 Recommendations

That a certificate of lawful use or development be **GRANTED** for the proposed development described above in respect of the land edged red on the attached plans for the following reasons:

The proposed development constitutes permitted development by virtue of the provisions of Schedule 2, Part 1, Class A, Class B and Class C of the Town and Country Planning (General Permitted Development) (England) Order 2015.

This determination is based on your submitted plans. All measurements are taken from existing ground level.

INFORMATIVES

- 1 The Council will recover from the applicant the cost of highway and footway repairs, including damage to grass verges.

Care should be taken during the building works hereby approved to ensure no damage occurs to the verge or footpaths during construction. Vehicles delivering materials to this development shall not override or cause damage to the public

footway. Any damage will require to be made good to the satisfaction of the Council and at the applicant's expense.

For further information and advice contact - Highways Maintenance Operations, Central Depot - Block K, Harlington Road Depot, 128 Harlington Road, Hillingdon, Middlesex, UB3 3EU (Tel: 01895 277524).

Part 1 Policies:

Part 2 Policies:

2.0 Planning Considerations

A Certificate of Lawful Development is sought for the construction of a single storey rear extension, single storey side extension and the conversion of roof space to habitable use to include a rear dormer and a side gable end and 3 front roof lights (Application for a Certificate of Lawful Development for a Proposed Development).

The application site is the eastern half of a pair of two storey semi-detached dwellings situated on the north side of the road..

The proposed dormer would be sited to the rear elevation of the main dwelling and would measure a total of 26.25 cubic metres. The side gable would measure 15.4 cubic metres. The combined volume would be 41.65 cubic metres less than the 50 cubic metres allowance and meets the criteria of Class B.

The two proposed rooflights would be sited along the front facing roofslope and would not project higher than 150mm beyond the original roof plane and meets the relevant criteria within Class C.

The single-storey rear extension measures 3.6m to the ridge height and 2.2m to the eaves height. It would extend 3m deep. The rear extension meets the relevant criteria within Class A.

The single-storey side extension does not project beyond the front or rear walls of the original dwelling house and does not form a boundary that fronts a highway. The side extension would not exceed a height of over 4m or have a width greater than half the width of the original dwelling house. Thus the side extension satisfies the relevant criteria within Class A

The proposal complies with Part 1, Class A, B & C of the amended 2015 GPDO and is recommended for approval.

3.0 Relevant Planning History

CLASS A - Proposed Extension

The height of the part of the dwellinghouse enlarged, improved or altered would exceed the height NO

The height of the eaves of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the eaves of the existing dwellinghouse;
NO

The enlarged part of the dwellinghouse would extend beyond a wall which-
(i) fronts a highway, and

(ii) forms either the principal elevation or a side elevation of the original dwellinghouse;

NO

The enlarged part of the dwellinghouse would have a single storey and-

(i) extend beyond the rear wall of the original dwellinghouse by more than 4 metres in the case of a detached dwellinghouse, or 3 metres in the case of any other dwellinghouse, or

(ii) exceed 4 metres in height;

NO

The enlarged part of the dwellinghouse would have more than one storey and-

(i) extend beyond the rear wall of the original dwellinghouse by more than 3 metres, or

(ii) be within 7 metres of any boundary of the curtilage of the dwellinghouse opposite the rear wall of the dwellinghouse;

NO

The enlarged part of the dwellinghouse would be within 2 metres of the boundary of the curtilage of the dwellinghouse, and the height of the eaves of the enlarged part would exceed 3 metres;

NO

The enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse, and would-

(i) exceed 4 metres in height,

(ii) have more than one storey, or

(ii) have a width greater than half the width of the original dwellinghouse; or

NO

it would consist of or include-

(i) the construction or provision of a veranda, balcony (means a platform with a height greater than 300 millimetres) or raised platform,

(ii) the installation, alteration or replacement of a microwave antenna,

(iii) the installation, alteration or replacement of a chimney, flue or soil and vent, pipe, or

(iv) an alteration to any part of the roof of the dwellinghouse.

NO

The property is not within a Conservation Area.

Conditions of Class A: Development is NOT permitted if you answer NO to any of the following questions - Development is permitted by Class A, subject to the following conditions:

A. Are the materials used similar to those of the existing dwellinghouse?

YES

B(i). Are any new side facing windows obscurely glazed?

YES

B(ii). Are any new side facing windows non - opening, or any parts of the window which do open 1.7m above the floor of the room?

NO

C. Does the roof pitch of the extension match, so far as practicable, the roof pitch of the original dwellinghouse?

YES

CLASS B - Proposed Roof Alterations

Does the volume of the proposed, and any existing roof extensions, exceed the permitted development allowance?

NO

Does any part of the dormer project forward of the plane of a roof which forms a principle elevation and fronts a highway?

NO

Does any part of the extension encroach on the neighbouring property - including eaves and foundations?

NO

Would the dormer be higher than the highest part of the roof?

NO

Is the building listed?

NO

Does the roof alteration include a Veranda, balcony or raised platform?

NO

Conditions to Class B: (If the answer to any of these questions is NO then planning permission is required):

Are the materials proposed similar in appearance to the property?

YES

Is the enlargement/dormer set in 20cm (200mm) from the roof margins?

YES

Are any side facing windows obscurely glazed?

YES

CLASS C - Any Other Alt. to the Roof of a Dwellinghouse

Would the alteration protrude more than 150 millimetres beyond the plane of the slope of the original roof when measured from the perpendicular with the external surface of the original?

NO

Would it result in the highest part of the alteration being higher than the highest part of the original roof?

NO

Would it consist or include the installation, alteration or replacement of a chimney, flue or soil and vent pipe?

NO

Would it involve the installation, alteration or replacement of solar photovoltaics or solar thermal equipment?

NO

NOTE: Installation of solar photovoltaics may fall within permitted development under Part 40

of Class A

5.0 Other including Measurements

rear dormer: $2.5\text{m (h)} \times 3.75\text{m (d)} \times 5.6\text{m (w)} / 2 = 26.25\text{m}^3$

gable end: $4\text{m W} \times 2.75\text{m (h)} \times 8.4\text{m (d)} / 6 = 15.4\text{m}^3$

combined roof alterations = 41.65m^3

**The height and width restrictions for the rear and side extensions have been met.
The proposals can be constructed as permitted development.**

Contact Officer: Carol Grant

Telephone No: 01895 250230