



Environmental Equipment Corporation Ltd
Richmond House, Churchfield Road
Walton on Thames
Surrey. KT12 2TP
t 01932 230940
e: info@eccc.co.uk

Project:

Waitrose Ruislip

Title:

Plant Noise Impact Assessment

quietly moving forward



Registered Address: Environmental Equipment Corporation Ltd., Richmond House, Churchfield Road,
Walton on Thames, Surrey, KT12 2TP. Company Registration No: 2568740

| Report Title | Waitrose Ruislip Plant Noise Impact Assessment | | |
|--------------|--|--------|---------|
| Reference | EEC/EC21511-2 | | |
| Version | 0 | | |
| Issue Date | 11 September 2025 | | |
| Client | John Lewis Partnership | | |
| Author | Iyiola Bamgbose MEng(Hons) Acoustic Engineer  | | |
| Checked | Jon Mudd BEng(Hons) MIOA Director  | | |
| Revision | Date | Author | Checked |
| | | | |
| | | | |
| | | | |
| | | | |

CONTENTS:

| | | |
|---|------------------|---|
| 1 | INTRODUCTION | 1 |
| 2 | SITE | 2 |
| 3 | GUIDANCE | 3 |
| 4 | MEASUREMENTS | 3 |
| 5 | EQUIPMENT | 3 |
| 6 | RESULTS | 5 |
| 7 | PLANT ASSESSMENT | 5 |
| 8 | CONCLUSIONS | 8 |

APPENDIX A:
 APPENDIX B:
 APPENDIX C:
 APPENDIX D:
 APPENDIX E:
 APPENDIX F:

Glossary of Technical Terms
 Proposed Plant Layout
 Planning Policy & Guidance
 Survey Results (Tabular)
 Survey Results (Graphical)
 Published Plant Noise Data



1 INTRODUCTION

- 1.01 Environmental Equipment Corporation Limited has been commissioned by John Lewis Partnership to undertake a noise assessment of new plant at roof level to serve the existing Waitrose & Partners at 9 Kingsend, Middlesex HA4 7DS.
- 1.02 This noise assessment has been conducted in accordance with the policies and requirements of London Borough of Hillingdon (LBH) and is based on a noise survey carried out at the site over a typical weekend period.
- 1.03 This assessment includes:
 - the setting of plant noise limits in accordance with the requirements of local authority and national planning policy, standards and guidance; and
 - the prediction of noise impacts at the worst affected noise sensitive receptors based on the proposed items of plant and their location.
- 1.04 This report is prepared solely for John Lewis Partnership. Environmental Equipment Corporation Limited accepts no responsibility for its use by any third party. Note that the contents contained herein are produced for the purposes of review by relevant Planning Authority departments and do not constitute a detailed design or specification document to be used for the purposes of construction. Subsequent development of noise mitigation schemes shall engage EEC Ltd and John Lewis Partnership so as to support the conclusions of this report.
- 1.05 Whilst every effort has been made to ensure that this report is easy to understand, it is necessarily technical in nature. To assist the reader, an explanation of the terminology used in this report is contained in Appendix A.

2 SITE

2.01 The Waitrose supermarket is located at 9 Kingsend in Ruislip, in a predominantly residential area.

2.02 The following Google Maps image has been annotated to identify the Waitrose store along with the location of the new plant at roof level. We have also annotated the nearest residential properties that could be most affected by the proposed new replacement plant and the measurement locations used for the noise survey.



Figure 1: Site layout and nearest dwelling

2.03 The new plant will consist of:

- 2 No. dry air coolers (DAC), 6 No. refrigeration condenser units, 2 No air source heat pumps (ASHP) and 1No. AC condenser unit which are to be located at roof level within a well.
- 1 No. condenser unit and 1 No. extract fan located at first floor roof level.

The detailed proposed plant layouts are presented in Appendix B.

2.04 The proposed new plant will replace existing refrigeration and ventilation plant already installed on the roof of the store with the 2 No. ASHPs considered to be new items that are replacing existing boiler plant within the store.

2.05 The closest noise sensitive receptors to the proposed plant items are the following:

- Receptor R1, the attic window of 7 Kingsend located approximately 50m from the closest plant area with no line of sight to any of the proposed plant areas.
- Receptor R2, top floor flats at Kings Lodge along Pembroke Road, with partial line of sight to the proposed plant area on the upper roof of the store.

2.06 All other noise sensitive receptors are at a greater distance from the proposed location of the units, or are protected by more screening by the intervening structures, and as such will be subject to lower levels of noise.

3 GUIDANCE

3.01 Guidance on noise management, control and rating pertinent to this application is provided by the local Planning Policy of LBH, National Planning Policy Framework (NPPF), the Noise Policy Statement for England (NPSE) and British Standard 4142:2014 'Methods for rating and assessing industrial and commercial sound' (BS4142:2014). The relevant parts of these documents are presented in Appendix C.

3.02 London Borough of Hillingdon (LBH) does not provide noise requirements within their local policy but a review of similar new fixed plant installations indicates that they would seek for new plant to be 5dB below the representative background noise level as assessed under the methodology outlined in BS4142. Designing to these levels would ensure noise from the operation of the plant would have no significant adverse impact.

4 MEASUREMENTS

4.01 Environmental noise measurements were carried out over a weekday period, between 19.30 hours on Friday 5th September 2025 and concluded 12.30 hours on Monday 8th September 2025, to establish the existing noise levels at the site. The survey methodology and results are set out below.

4.02 Noise measurements have been carried out at the following position, as shown in Appendix B and described as:

- Position 1: located on the roof (east of plant area) at a height of approximately 6 metres above ground level. The measurement was not located within 3.5 metres of any reflecting surfaces, other than the mounting surface.
- Position 2: located on the roof (west of plant area) at a height of approximately 6 metres above ground level. The measurement was not located within 3.5 metres of any reflecting surfaces, other than the mounting surface.

4.03 This position is considered to be representative of the nearest windows to the proposed plant area.

5 EQUIPMENT

5.01 The equipment used for the survey **position 1** was as follows:-

- 01dB Fusion Integrating Sound Level Meter conforming to Class 1 BS EN 61672, Type 1 BS EN 60804 & BS EN 60651: 1994;

- GRAS 40CD Condenser Microphone, PRE22 S Pre-amp and Connecting Leads;
- Tripod.

5.02 The equipment holds current UKAS or equivalent accreditation and serial numbers as follows:

| | | |
|----------------------------------|----------------------|------------------------------|
| Sound Level Meter 01dB Fusion | Serial No. | 15002 |
| | Calibration Date | 18 th August 2025 |
| | Cal. Certificate No. | U51909 |
| ½" Condenser Mic. GRAS 40CD | Serial No. | 545348 |
| | Calibration Date | 18 th August 2025 |
| | Cal. Certificate No. | U51908 |
| Calibrator CAL 31 | Serial No. | 94723 |
| | Calibration Date | 7 th May 2025 |
| | Cal. Certificate No. | U50914 |

N.B. Copies of calibration certificates are available upon request.

5.03 The equipment used for the survey **position 2** was as follows:-

- 01dB Fusion Integrating Sound Level Meter conforming to Class 1 BS EN 61672, Type 1 BS EN 60804 & BS EN 60651: 1994;
- GRAS 40CD Condenser Microphone, PRE22 S Pre-amp and Connecting Leads;
- Tripod.

5.04 The equipment holds current accreditation and serial numbers as follows:

| | | |
|----------------------------------|-----------------------------|------------------------------|
| Sound Level Meter 01dB Fusion | Serial No. | 14666 |
| | Calibration Date | 18 th August 2025 |
| | Calibration Certificate No. | U51904 |
| ½" Condenser Mic. GRAS 40CD | Serial No. | 470803 |
| | Calibration Date | 15 th August 2025 |
| | Calibration Certificate No. | U51903 |
| Calibrator CR 515 | Serial No. | 99534 |
| | Calibration Date | 15 th August 2025 |
| | Cal. Certificate No. | U51902 |

N.B. Copies of calibration certificates are available upon request.

5.05 The equipment was calibrated both before and after the survey with no difference noted in the levels.

6 RESULTS

- 6.01 The weather during the survey was suitable for noise measurement, it being dry with little wind for the duration of the survey.
- 6.02 Noise sources at the site include local road and rail traffic and at measurement position 2 some noise from the operation of existing plant local to the measurement location. There were no other significant sources of noise during the survey.
- 6.03 A list of the levels measured is included in Appendix D and represented graphically in Appendix E.
- 6.04 A summary of the time averaged ambient levels and lowest measured background levels over the measurement periods are shown in Table 6.1. The minimum L_{A90} is the lowest fifteen-minute measurement in the specified period.

| Position | Period | Average $L_{Aeq,T}$ – dB | Minimum L_{A90} – dB |
|-------------|-------------------------------|--------------------------|------------------------|
| 1 (East) | Day time (0700-1900 hrs) | 58 | 43 |
| | Evening (1900-2300 hrs) | 57 | 43 |
| | Night-time (2300-0700 hrs) | 53 | 36 |
| 2 (West) | Day time (0700-1900 hrs) | 53 | 46 |
| | Evening (1900-2300 hrs) | 53 | 45 |
| | Night-time (2300-0700 hrs) | 50 | 42 |

Table 6.1: Free-Field Measured Ambient and Lowest Background Noise Levels

7 PLANT ASSESSMENT

- 7.01 This application is for the installation new and replacement plant to be located at roof level at Waitrose, Ruislip.
- 7.02 Background noise measurement results from Position 1 have been selected as the representative background level, as this position recorded the lower noise levels and is considered to be most representative of the conditions at the nearest noise-sensitive receptors without the influences from any existing plant serving the Waitrose store.
- 7.03 Based on the standard requirements of London Borough of Hillingdon and the lowest measured background noise level in each time period, Table 7.1 sets out the recommended noise limits that the proposed items of plant should meet.
- 7.04 In accordance with the requirements of LBH, the proposed noise limits are based on being 5dB below the measured background noise level.

| Receptor | Period | Measured Existing $L_{A90,T}$ | Proposed Noise Limit L_{Ar} |
|-------------|---------|----------------------------------|----------------------------------|
| Residential | Day | 43 dB | 38 dB |
| | Evening | 43 dB | 38 dB |
| | Night | 36 dB | 31 dB |

Table 7.1: Suggested Plant Noise Emission Limits Based on Lowest Measured L_{A90} , Free-field dB

7.05 Note that the limits suggested above are rating levels and as such any design should take into account the acoustic characteristics of the plant. In this instance the proposed units display none of the characteristics whereby the acoustic correction should be applied.

7.06 Assuming the proposed items meet the noise limits set out in Table 7.1 noise will be below the LOAEL with respect to the NPPF.

7.07 The details of the proposed units and their stated manufacturers sound power level are shown in Table 7.2. Copies of the manufacturer's plant data sheets are included in Appendix F.

| Item | Make / Model | Operating period | Quantity | Noise Level | Notes |
|-----------|-----------------------------------|------------------|----------|-------------|---------------------------|
| DAC1-2 | Clade / ASL-ZAP-EC-243-ECMP-448-H | 24 hours | 2 | 35 dB(A) | Sound pressure level @10m |
| ASHP01-02 | GalxC / PLN154HS | 0700-2300hrs | 2 | 50 dB(A) | |
| LT1-2 | SCM Frigo / WG T067 BTDX | 24 hours | 2 | 41 dB(A) | |
| HT1-4 | SCM Frigo / WG T067 MTDX | 24 hours | 4 | 41 dB(A) | |
| COND1 | Daikin / RZAG125NV1 | 0700-2300hrs | 1 | 68 (49 Lp) | L_w |
| COND2 | Daikin / RZAG35B | 0700-2300hrs | 1 | 62 (48 Lp) | |
| EF01 | Systemair / MUB 025 315EC | 0700-2300hrs | 1 | 70 dB(A) | Outlet, L_w |
| | | | | 41 dB(A) | Casing, L_w |

8 Table 7.2: Proposed plant and published source noise levels

8.01 The refrigeration plant will be required to run at any period over 24 hours, however the ASHPs and the AC condensers and extract fan will only run during the store trading hours for the store so will not run during the night time.

8.02 Predicted noise levels have been calculated at the closest noise sensitive windows.

8.03 The windows of receptor R1, 7 Kingsland will be exposed to noise from all three plant areas, whereas the flats of Kings Lodge will only be exposed to noise from plant on the upper level roof. Noise from the plant on the lower roof on the west side will be screened by the Waitrose building such that this plant will have no effect on the noise incident on the windows of Kings Lodge.

8.04 Other residential receptors located further from the site will be subject to lower noise levels than those predicted at the above locations.

8.05 Table 7.3-7.5 presents the results of worst-case plant noise predictions at the worst-case locations.

| Item | Noise Level | | Notes |
|--|-----------------|-----------------|--|
| | Day | Night | |
| All plant equipment at all three locations | 57 dB(A) | 49 dB(A) | Cumulative sound pressure level at 10m |
| Reflections | 0 dB | 0 dB | No additional reflections – plant is on an open area of roof |
| Barrier Effect | - 10 dB | - 10 dB | No line of sight to proposed plant location |
| Point losses over 50 metres | - 14 dB | - 14 dB | Distance to closest window |
| Resultant Noise Level | 33 dB(A) | 25 dB(A) | At R1 – 7 Kingsland attic window |

Table 7.3: R1 Plant Noise Calculation

| Item | Noise Level | | Notes |
|------------------------------------|-----------------|-----------------|--|
| | Day | Night | |
| All plant equipment | 53 dB(A) | 49 dB(A) | Cumulative sound pressure level at 10m |
| Reflections | 0 dB | 0 dB | No additional reflections – plant is on an open area of roof |
| Barrier Effect | 0 dB | 0 dB | line of sight to proposed plant location (well) |
| Point Source losses over 80 metres | - 18 dB | - 18 dB | Distance to closest window |
| Resultant Noise Level | 36 dB(A) | 31 dB(A) | At R2 – Flats at Kings Lodge |

Table 7.4: R2 Plant Noise Calculation

| Receptor | Period | Proposed Noise Limit L_{Ar} | Predicted $L_{Aeq,T}$ | Exceedance of noise limit |
|----------|------------|-------------------------------|-----------------------|---------------------------|
| R1 | Daytime | 38 dB | 33 dB | -5 dB |
| | Evening | 38 dB | 33 dB | -5 dB |
| | Night-time | 31 dB | 25 dB | -6 dB |
| R2 | Daytime | 38 dB | 36 dB | -2 dB |
| | Evening | 38 dB | 36 dB | -1 dB |
| | Night-time | 31 dB | 31 dB | 0 dB |

Table 7.5: Assessment of Predicted Noise Levels Based on Proposed Noise Limit, Free-field dB(A)

- 8.06 It can be seen from the above tables that the noise limits are not exceeded during all periods of operation at the closest noise sensitive receptors.
- 8.07 With respect to the NPPF, achieving the noise limits would be classified as being below the LOAEL.

9 CONCLUSIONS

- 9.01 John Lewis Partnership has appointed Environmental Equipment Corporation Limited to undertake a noise assessment of new plant at roof level to serve the existing Waitrose & Partners at 9 Kingsend, Middlesex HA4 7DS.
- 9.02 The assessment has been carried out in accordance with national planning guidance and the requirements of the local authority, and is based on an environmental noise survey conducted at the site over a weekend period.
- 9.03 A noise assessment has been undertaken to evaluate the potential noise impact of the proposed condensers at the closest existing residential receptors.
- 9.04 Plant noise limits have been set based on the methodology contained in BS4142 and the results of a background noise survey, to ensure noise from the proposed plant has no adverse impact. In accordance with the NPPF, the noise limit has been 5dB below the lowest measured background noise level.
- 9.05 Predictions have shown that the noise criteria are met at the nearest, most affected dwellings during all periods of the plants proposed operation.
- 9.06 Assessing the site in accordance with the principles of the National Planning Policy Framework has shown that predicted noise levels would be below the level at which no effects are observed to occur, the LOAEL.
- 9.07 On the basis of this assessment, it is considered that noise does not pose a material constraint to the operation of the proposed plant.

APPENDIX A


GLOSSARY OF TECHNICAL TERMS

ACOUSTIC TERMINOLOGY

| | |
|---------------------------------|---|
| Absorption Classes | The sound absorption of a material is rated from Class A to Class E, where Class A materials provide the highest level of sound absorption. |
| Ambient Noise Levels | Noise levels measured in the absence of noise requiring control, frequently measured to determine the situation prior to the addition of a new noise source. |
| dB | Decibel. The logarithmic unit of sound level. |
| dB(A) | A-weighted decibel. The A-weighting approximates the response of the human ear. |
| $D_{nT,w}$ | Weighted standardized level difference. A single number quantity of the sound level difference between two rooms. $D_{nT,w}$ is typically used to measure the on-site sound insulation performance of a building element such as a wall, floor or ceiling. Measured in accordance with BS EN ISO 16283-1 and weighted in accordance with BS EN ISO 717-1. |
| $D_{n,e,w}$ | The weighted element-normalized level difference. A single number rating of the sound reduction provided by a sound passing through an individual element. $D_{n,e,w}$ is typically used to define the sound insulation provided by ventilators. Measured in accordance with BS EN ISO 10140-2:2010 and rated in accordance with BS EN ISO 717-1. |
| Flanking | Transmission of sound energy through paths adjacent to the building element being considered. For example, sound may be transmitted around a wall by travelling up into the ceiling space and then down into the adjacent room. |
| Frequency | Sound can occur over a range of frequencies extending from the very low, such as the rumble of thunder, up to the very high such as the crash of cymbals. Sound is generally described over the frequency range from 63Hz to 4kHz, roughly equal to the range of frequencies on a piano. |
| Impact Sound | Sound produced by an object impacting directly on a building structure, such as footfall noise or chairs scrapping on a floor. |
| $L_{Aeq,t}$ | The equivalent continuous sound level measured in dBA. This is commonly referred to as the average noise level. 't' is the interval time for the measurement. Typically 't' of 16hrs and 8hrs is used for day and night time ambient noise respectively or 't' is defined by the period of interest in BS4142 assessments. |
| $L_{A90,t}$ | The noise level exceeded for 90% of the measurement period, measured in dBA. This is commonly referred to as the background noise level. |
| $L'_{nT,w}$ | Weighted, standardized impact sound pressure level. A single number rating of the impact sound insulation of a floor/ceiling when impacted on by a standard "tapper" machine. The lower the $L'_{nT,w}$, the better the acoustic performance. Measured in accordance with BBS EN ISO 140-7 and rated in accordance with BS EN ISO 717-2. |
| NR | Noise Rating. A single number rating which is based on the sound level in the octave bands 31.5Hz – 8kHz inclusive, generally used to assess noise from mechanical services in buildings. |
| Octave Band | Frequencies are often grouped together into octaves for analysis. Octave bands are labelled by their centre frequency which are: 63Hz, 125Hz, 250Hz, 500Hz, 1kHz, 2kHz and 4kHz. |
| Reverberation Time (T_{mf}) | Reverberation time is used for assessing the acoustic qualities of a space. It is defined as the time it takes for an impulse to decay by 60dB. T_{mf} is the arithmetic average of the reverberation time in the mid frequency bands (500Hz, 1kHz and 2kHz). |
| R_w | Weighted sound reduction index. A single number rating of the sound insulation performance of a specific building element. R_w is measured in a laboratory. R_w is commonly used by manufacturers to describe the sound insulation performance of building elements such as plasterboard and concrete. Measured in accordance with BS EN ISO 10140-2:2010 and rated in accordance with BS EN ISO 717-1. |
| Sound Absorption | When sound hits a surface, some of the sound energy is absorbed by the surface material. Sound absorption refers to the ability of a material to absorb sound, rated from 0, complete reflection, to 1, complete absorption. |
| Sound Insulation | When sound hits a surface, some of the sound energy travels through the material. 'Sound insulation' refers to the ability of a material to prevent the travel of sound. |
| Structure-borne transmission | Transmission of sound energy as vibrations via the structure of a building. |

APPENDIX B


**PROPOSED
PLANT LAYOUT**



Waitrose Ruislip

11 September 2025





APPENDIX C

**PLANNING POLICY
AND GUIDANCE**

PLANNING POLICY AND GUIDANCE

National Planning Policy Framework and the Noise Policy Statement for England

The Department for Communities and Local Government published the National Planning Policy Framework (NPPF) on 27th March 2012 (as amended on 12th December 2024) and upon its publication, the majority of planning policy statements and guidance notes were withdrawn, including Planning Policy Guidance 24 Planning and Noise, which previously presented the government's overarching planning policy on noise.

Paragraph 187 in Section 15 of the NPPF, entitled Conserving and enhancing the natural environment, states that:

"Planning policies and decisions should contribute to and enhance the natural and local environment by:

e) preventing new and existing development from contributing to, being put at unacceptable risk from, or being adversely affected by, unacceptable levels of soil, air, water or noise pollution or land instability..."

Paragraph 198 in Section 15 also states that:

"Planning policies and decisions should also ensure that new development is appropriate for its location taking into account the likely effects (including cumulative effects) of pollution on health, living conditions and the natural environment, as well as the potential sensitivity of the site or the wider area to impacts that could arise from the development. In doing so they should:

a) mitigate and reduce to a minimum potential adverse impacts resulting from noise from new development – and avoid noise giving rise to significant adverse impacts on health and the quality of life;

b) identify and protect tranquil areas which have remained relatively undisturbed by noise and are prized for their recreational and amenity value for this reason..."

The Department for Environment Food and Rural Affairs published the Noise Policy Statement for England (NPSE) in March 2010. The explanatory note of NPSE defines the following terms used in the NPPF:

"NOEL – No Observed Effect Level

This is the level below which no effect can be detected. In simple terms, below this level, there is no detectable effect on health and quality of life due to the noise.

LOAEL – Lowest Observed Adverse Effect Level

This is the level above which adverse effects on health and quality of life can be detected.

2.21 Extending these concepts for the purpose of this NPSE leads to the concept of a significant observed adverse effect level.

SOAEL – Significant Observed Adverse Effect Level

This is the level above which significant adverse effects on health and quality of life occur."

The NPSE does not define any of the above effect levels numerically.

The NPSE presents the Noise Policy Aims as:

*"Through the effective management and control of environmental, neighbour and neighbourhood noise within the context of Government policy and sustainable development:
 avoid significant adverse impacts on health and quality of life;
 mitigate and minimise adverse impacts on health and quality of life; and
 where possible, contribute to the improvement of health and quality of life."*

It can be seen that the first two bullet points are similar to Section 11 of the NPPF, with a third aim that seeks to improve health and quality of life. The NPSE later expands on the Noise Policy Aims, stating:

2.23 The first aim of the NPSE states that significant adverse effects on health and quality of life should be avoided while also taking into account the guiding principles of sustainable development (paragraph 1.8).

2.24 The second aim of the NPSE refers to the situation where the impact lies somewhere between LOAEL and SOAEL. It requires that all reasonable steps should be taken to mitigate and minimise adverse effects on health and quality of life while also taking into account the guiding principles of sustainable development (paragraph 1.8). This does not mean that such adverse effects cannot occur.

2.25 This aim (the third aim), seeks where possible, positively to improve health and quality of life through the pro-active management of noise while also taking into account the guiding principles of sustainable development (paragraph 1.8), recognising that there will be opportunities for such measures to be taken and that they will deliver potential benefits to society. The protection of quiet places and quiet times as well as the enhancement of the acoustic environment will assist with delivering this aim."

It is clear that noise described in the NPSE as SOAEL that would lead to significant adverse effects should be avoided, although there is no definition as to what constitutes a significant adverse effect. Similarly, noise should be mitigated where it is high enough to lead to adverse effects, termed the LOAEL, but not so high that it leads to significant adverse effects.

British Standard 4142

To assess the acceptability of the resultant noise levels we have consulted the relevant standards. BS 4142:2014 'Methods for rating and assessing industrial and commercial sound' has been used to assess the likelihood any adverse impacts based on the resultant noise level from the new plant item, including any corrections for the character of the noise against the existing background noise level.

BS4142 gives guidance on assessing the likelihood of adverse impacts by calculating a 'rating level' of the new noise source and comparing its magnitude at noise sensitive locations to the existing or underlying background noise level. The background noise level is subtracted from the 'rating level' to assess the likelihood of complaints:

- The greater the difference the greater the likelihood of complaints.
- A difference of around +10dB or more is an indication of a significant adverse impact, depending on the context.
- A difference of +5dB is likely to be an indication of an adverse impact, depending on the context.

- The lower the rating level is relative to the measured background noise level, the less likely it is that the specific sound source will have an adverse impact or significant adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low sound impact, depending on the context.

This assessment is carried out over a one hour period for the daytime and a fifteen minute period for the night-time. For the purposes of the standard it states that daytime and night-time are typically 07:00 to 23:00 hours and 23:00 to 07:00 hours respectively.

The 'rating level' of the noise source is obtained taking the following factors into consideration:

- The new plant noise (the specific noise) is measured or predicted in terms of L_{Aeq} .
- An additional correction shall be included if the noise contains a distinguishable, discrete continuous note, if the noise contains distinct impulses or if the noise is irregular enough to attract attention. The value for any tonal noise can be an addition of up to 6dB and for impulsive noise of up to 9dB.

BS 4142 goes onto state that:

'The significance of sound of an industrial and/or commercial nature depends upon both the margin by which the rating level of the specific sound source exceeds the background sound level and the context in which the sound occurs. An effective assessment cannot be conducted without an understanding of the reason(s) for the assessment and the context in which the sound occurs/will occur. When making assessments and arriving at decisions, therefore, it is essential to place the sound in context.'

BS4142 has been referenced in setting noise limits for any fixed plant proposed as part of the proposed development.

APPENDIX D

**SURVEY RESULTS
(TABULAR)**

Waitrose Ltd

Tabulated Noise data

Sheet 1 of 3

| Time | L _{Aeq} | L _{AMax} | L _{A90} |
|-------|------------------|-------------------|------------------|
| 19:30 | 66 | 75 | 54 |
| 19:45 | 58 | 84 | 48 |
| 20:00 | 56 | 68 | 48 |
| 20:15 | 56 | 65 | 49 |
| 20:30 | 59 | 80 | 49 |
| 20:45 | 57 | 77 | 47 |
| 21:00 | 57 | 73 | 48 |
| 21:15 | 60 | 80 | 47 |
| 21:30 | 57 | 71 | 47 |
| 21:45 | 59 | 84 | 46 |
| 22:00 | 57 | 80 | 47 |
| 22:15 | 55 | 68 | 46 |
| 22:30 | 55 | 69 | 45 |
| 22:45 | 58 | 80 | 47 |
| 23:00 | 57 | 77 | 46 |
| 23:15 | 57 | 79 | 46 |
| 23:30 | 56 | 79 | 43 |
| 23:45 | 53 | 67 | 42 |
| 00:00 | 53 | 68 | 41 |
| 00:15 | 53 | 71 | 42 |
| 00:30 | 54 | 68 | 43 |
| 00:45 | 52 | 68 | 40 |
| 01:00 | 53 | 69 | 40 |
| 01:15 | 54 | 74 | 40 |
| 01:30 | 52 | 64 | 38 |
| 01:45 | 54 | 77 | 38 |
| 02:00 | 51 | 64 | 37 |
| 02:15 | 51 | 69 | 36 |
| 02:30 | 51 | 69 | 37 |
| 02:45 | 50 | 63 | 36 |
| 03:00 | 48 | 64 | 37 |
| 03:15 | 48 | 65 | 37 |
| 03:30 | 47 | 62 | 36 |
| 03:45 | 49 | 65 | 36 |
| 04:00 | 50 | 70 | 37 |
| 04:15 | 48 | 64 | 37 |
| 04:30 | 50 | 69 | 38 |
| 04:45 | 50 | 66 | 38 |
| 05:00 | 51 | 67 | 39 |
| 05:15 | 51 | 66 | 40 |
| 05:30 | 55 | 72 | 40 |
| 05:45 | 54 | 69 | 49 |
| 06:00 | 56 | 70 | 45 |
| 06:15 | 56 | 76 | 44 |
| 06:30 | 56 | 69 | 46 |
| 06:45 | 55 | 68 | 46 |
| 07:00 | 56 | 68 | 44 |
| 07:15 | 55 | 68 | 46 |

| Time | L _{Aeq} | L _{AMax} | L _{A90} |
|-------|------------------|-------------------|------------------|
| 07:30 | 57 | 74 | 47 |
| 07:45 | 57 | 71 | 48 |
| 08:00 | 57 | 70 | 47 |
| 08:15 | 57 | 69 | 48 |
| 08:30 | 58 | 69 | 49 |
| 08:45 | 58 | 74 | 48 |
| 09:00 | 57 | 69 | 48 |
| 09:15 | 57 | 67 | 47 |
| 09:30 | 58 | 70 | 48 |
| 09:45 | 58 | 73 | 48 |
| 10:00 | 59 | 76 | 49 |
| 10:15 | 59 | 79 | 48 |
| 10:30 | 65 | 90 | 49 |
| 10:45 | 58 | 68 | 48 |
| 11:00 | 58 | 76 | 48 |
| 11:15 | 58 | 78 | 48 |
| 11:30 | 57 | 68 | 49 |
| 11:45 | 59 | 86 | 49 |
| 12:00 | 57 | 73 | 48 |
| 12:15 | 58 | 71 | 50 |
| 12:30 | 57 | 78 | 48 |
| 12:45 | 57 | 68 | 48 |
| 13:00 | 60 | 77 | 49 |
| 13:15 | 59 | 75 | 49 |
| 13:30 | 57 | 72 | 50 |
| 13:45 | 57 | 75 | 49 |
| 14:00 | 56 | 69 | 49 |
| 14:15 | 58 | 79 | 48 |
| 14:30 | 60 | 79 | 49 |
| 14:45 | 57 | 76 | 49 |
| 15:00 | 59 | 79 | 49 |
| 15:15 | 56 | 66 | 48 |
| 15:30 | 61 | 80 | 48 |
| 15:45 | 59 | 79 | 48 |
| 16:00 | 57 | 80 | 49 |
| 16:15 | 56 | 68 | 48 |
| 16:30 | 59 | 79 | 48 |
| 16:45 | 57 | 69 | 48 |
| 17:00 | 60 | 79 | 48 |
| 17:15 | 57 | 68 | 48 |
| 17:30 | 57 | 69 | 48 |
| 17:45 | 57 | 68 | 49 |
| 18:00 | 57 | 66 | 49 |
| 18:15 | 58 | 75 | 48 |
| 18:30 | 58 | 69 | 48 |
| 18:45 | 58 | 79 | 47 |
| 19:00 | 57 | 68 | 47 |
| 19:15 | 57 | 75 | 48 |

quietly moving forward

Waitrose Ltd

Tabulated Noise data

Sheet 2 of 3

| Time | L _{Aeq} | L _{AMax} | L _{A90} |
|-------|------------------|-------------------|------------------|
| 19:30 | 63 | 88 | 47 |
| 19:45 | 58 | 76 | 47 |
| 20:00 | 57 | 73 | 47 |
| 20:15 | 58 | 79 | 48 |
| 20:30 | 57 | 75 | 47 |
| 20:45 | 56 | 78 | 47 |
| 21:00 | 56 | 66 | 48 |
| 21:15 | 59 | 82 | 46 |
| 21:30 | 56 | 68 | 46 |
| 21:45 | 56 | 75 | 46 |
| 22:00 | 56 | 72 | 46 |
| 22:15 | 55 | 68 | 46 |
| 22:30 | 55 | 70 | 45 |
| 22:45 | 55 | 65 | 45 |
| 23:00 | 55 | 69 | 45 |
| 23:15 | 54 | 72 | 44 |
| 23:30 | 54 | 65 | 45 |
| 23:45 | 54 | 66 | 46 |
| 00:00 | 53 | 68 | 42 |
| 00:15 | 55 | 70 | 44 |
| 00:30 | 54 | 67 | 43 |
| 00:45 | 53 | 66 | 42 |
| 01:00 | 53 | 66 | 43 |
| 01:15 | 52 | 68 | 39 |
| 01:30 | 51 | 64 | 39 |
| 01:45 | 50 | 65 | 38 |
| 02:00 | 52 | 74 | 38 |
| 02:15 | 50 | 68 | 37 |
| 02:30 | 48 | 63 | 37 |
| 02:45 | 49 | 64 | 37 |
| 03:00 | 46 | 61 | 36 |
| 03:15 | 51 | 72 | 37 |
| 03:30 | 49 | 63 | 36 |
| 03:45 | 50 | 69 | 37 |
| 04:00 | 53 | 80 | 37 |
| 04:15 | 54 | 81 | 37 |
| 04:30 | 51 | 70 | 38 |
| 04:45 | 48 | 65 | 37 |
| 05:00 | 52 | 75 | 38 |
| 05:15 | 55 | 76 | 39 |
| 05:30 | 53 | 72 | 39 |
| 05:45 | 50 | 66 | 39 |
| 06:00 | 52 | 69 | 40 |
| 06:15 | 54 | 71 | 42 |
| 06:30 | 54 | 70 | 43 |
| 06:45 | 54 | 70 | 44 |
| 07:00 | 53 | 65 | 43 |
| 07:15 | 54 | 68 | 44 |

| Time | L _{Aeq} | L _{AMax} | L _{A90} |
|-------|------------------|-------------------|------------------|
| 07:30 | 54 | 66 | 44 |
| 07:45 | 54 | 68 | 44 |
| 08:00 | 55 | 69 | 44 |
| 08:15 | 56 | 73 | 46 |
| 08:30 | 56 | 69 | 45 |
| 08:45 | 56 | 72 | 45 |
| 09:00 | 58 | 78 | 46 |
| 09:15 | 60 | 84 | 47 |
| 09:30 | 59 | 83 | 47 |
| 09:45 | 58 | 71 | 49 |
| 10:00 | 58 | 72 | 48 |
| 10:15 | 58 | 74 | 49 |
| 10:30 | 57 | 70 | 47 |
| 10:45 | 59 | 80 | 47 |
| 11:00 | 57 | 73 | 47 |
| 11:15 | 59 | 80 | 48 |
| 11:30 | 57 | 75 | 49 |
| 11:45 | 56 | 67 | 49 |
| 12:00 | 60 | 86 | 48 |
| 12:15 | 58 | 73 | 49 |
| 12:30 | 56 | 70 | 48 |
| 12:45 | 56 | 68 | 48 |
| 13:00 | 61 | 85 | 49 |
| 13:15 | 56 | 68 | 48 |
| 13:30 | 56 | 69 | 48 |
| 13:45 | 57 | 74 | 50 |
| 14:00 | 57 | 77 | 48 |
| 14:15 | 58 | 78 | 48 |
| 14:30 | 58 | 75 | 48 |
| 14:45 | 59 | 84 | 49 |
| 15:00 | 57 | 69 | 48 |
| 15:15 | 58 | 81 | 48 |
| 15:30 | 56 | 69 | 48 |
| 15:45 | 57 | 74 | 48 |
| 16:00 | 58 | 79 | 49 |
| 16:15 | 59 | 81 | 48 |
| 16:30 | 58 | 80 | 49 |
| 16:45 | 56 | 67 | 49 |
| 17:00 | 58 | 82 | 48 |
| 17:15 | 57 | 71 | 49 |
| 17:30 | 56 | 67 | 49 |
| 17:45 | 65 | 91 | 48 |
| 18:00 | 57 | 70 | 49 |
| 18:15 | 57 | 69 | 47 |
| 18:30 | 56 | 68 | 47 |
| 18:45 | 56 | 70 | 48 |
| 19:00 | 56 | 69 | 47 |
| 19:15 | 56 | 66 | 47 |

quietly moving forward

Waitrose Ltd

Tabulated Noise data

Sheet 3 of 3

| Time | L _{Aeq} | L _{AMax} | L _{A90} |
|-------|------------------|-------------------|------------------|
| 19:30 | 56 | 69 | 47 |
| 19:45 | 56 | 65 | 47 |
| 20:00 | 55 | 67 | 48 |
| 20:15 | 55 | 64 | 46 |
| 20:30 | 55 | 68 | 46 |
| 20:45 | 58 | 77 | 49 |
| 21:00 | 57 | 77 | 47 |
| 21:15 | 55 | 66 | 44 |
| 21:30 | 55 | 71 | 46 |
| 21:45 | 55 | 69 | 45 |
| 22:00 | 55 | 68 | 44 |
| 22:15 | 54 | 72 | 45 |
| 22:30 | 52 | 65 | 43 |
| 22:45 | 54 | 70 | 43 |
| 23:00 | 52 | 64 | 41 |
| 23:15 | 51 | 65 | 39 |
| 23:30 | 54 | 82 | 41 |
| 23:45 | 62 | 92 | 40 |
| 00:00 | 52 | 65 | 39 |
| 00:15 | 54 | 77 | 38 |
| 00:30 | 49 | 64 | 39 |
| 00:45 | 52 | 68 | 38 |
| 01:00 | 50 | 67 | 37 |
| 01:15 | 47 | 66 | 37 |
| 01:30 | 54 | 79 | 37 |
| 01:45 | 50 | 72 | 36 |
| 02:00 | 50 | 72 | 37 |
| 02:15 | 45 | 63 | 37 |
| 02:30 | 46 | 64 | 37 |
| 02:45 | 47 | 69 | 37 |
| 03:00 | 46 | 64 | 38 |
| 03:15 | 53 | 78 | 38 |
| 03:30 | 47 | 63 | 37 |
| 03:45 | 48 | 65 | 37 |
| 04:00 | 46 | 64 | 37 |
| 04:15 | 49 | 70 | 38 |
| 04:30 | 49 | 66 | 39 |
| 04:45 | 51 | 67 | 40 |
| 05:00 | 53 | 68 | 40 |
| 05:15 | 54 | 69 | 43 |
| 05:30 | 55 | 70 | 44 |
| 05:45 | 57 | 72 | 46 |
| 06:00 | 57 | 68 | 47 |
| 06:15 | 57 | 69 | 49 |
| 06:30 | 58 | 71 | 50 |
| 06:45 | 58 | 71 | 50 |
| 07:00 | 59 | 73 | 50 |
| 07:15 | 59 | 76 | 50 |

| Time | L _{Aeq} | L _{AMax} | L _{A90} |
|-------|------------------|-------------------|------------------|
| 07:30 | 61 | 86 | 50 |
| 07:45 | 60 | 68 | 51 |
| 08:00 | 59 | 68 | 50 |
| 08:15 | 59 | 74 | 49 |
| 08:30 | 59 | 69 | 51 |
| 08:45 | 59 | 78 | 50 |
| 09:00 | 58 | 79 | 50 |
| 09:15 | 59 | 74 | 49 |
| 09:30 | 59 | 71 | 50 |
| 09:45 | 57 | 70 | 50 |
| 10:00 | 57 | 70 | 49 |
| 10:15 | 57 | 69 | 49 |
| 10:30 | 57 | 67 | 48 |
| 10:45 | 56 | 68 | 48 |
| 11:00 | 58 | 79 | 49 |
| 11:15 | 58 | 70 | 50 |
| 11:30 | 58 | 74 | 49 |
| 11:45 | 58 | 70 | 50 |
| 12:00 | 57 | 69 | 49 |
| 12:15 | 56 | 68 | 49 |
| 12:30 | 57 | 71 | 49 |

quietly moving forward

Waitrose Ltd

Tabulated Noise data

Sheet 1 of 3

| Time | L _{Aeq} | L _{AMax} | L _{A90} |
|-------|------------------|-------------------|------------------|
| 19:30 | 55 | 74 | 49 |
| 19:45 | 52 | 60 | 50 |
| 20:00 | 52 | 64 | 49 |
| 20:15 | 54 | 71 | 49 |
| 20:30 | 53 | 73 | 49 |
| 20:45 | 55 | 71 | 49 |
| 21:00 | 54 | 72 | 49 |
| 21:15 | 55 | 78 | 48 |
| 21:30 | 51 | 59 | 48 |
| 21:45 | 51 | 63 | 47 |
| 22:00 | 53 | 77 | 47 |
| 22:15 | 50 | 60 | 46 |
| 22:30 | 53 | 80 | 46 |
| 22:45 | 57 | 78 | 47 |
| 23:00 | 50 | 64 | 46 |
| 23:15 | 54 | 66 | 45 |
| 23:30 | 49 | 66 | 44 |
| 23:45 | 48 | 59 | 44 |
| 00:00 | 48 | 58 | 44 |
| 00:15 | 48 | 62 | 44 |
| 00:30 | 47 | 61 | 44 |
| 00:45 | 47 | 60 | 43 |
| 01:00 | 48 | 61 | 44 |
| 01:15 | 48 | 71 | 44 |
| 01:30 | 46 | 62 | 44 |
| 01:45 | 46 | 61 | 44 |
| 02:00 | 46 | 59 | 44 |
| 02:15 | 47 | 63 | 44 |
| 02:30 | 46 | 64 | 44 |
| 02:45 | 46 | 61 | 44 |
| 03:00 | 46 | 56 | 44 |
| 03:15 | 50 | 68 | 44 |
| 03:30 | 46 | 56 | 45 |
| 03:45 | 46 | 58 | 44 |
| 04:00 | 45 | 57 | 43 |
| 04:15 | 46 | 64 | 43 |
| 04:30 | 49 | 70 | 44 |
| 04:45 | 50 | 68 | 45 |
| 05:00 | 50 | 67 | 45 |
| 05:15 | 50 | 66 | 47 |
| 05:30 | 49 | 61 | 45 |
| 05:45 | 57 | 74 | 53 |
| 06:00 | 54 | 64 | 49 |
| 06:15 | 52 | 69 | 48 |
| 06:30 | 53 | 69 | 49 |
| 06:45 | 54 | 77 | 49 |
| 07:00 | 52 | 66 | 48 |
| 07:15 | 53 | 62 | 50 |

| Time | L _{Aeq} | L _{AMax} | L _{A90} |
|-------|------------------|-------------------|------------------|
| 07:30 | 53 | 65 | 51 |
| 07:45 | 54 | 66 | 49 |
| 08:00 | 55 | 71 | 49 |
| 08:15 | 53 | 68 | 48 |
| 08:30 | 56 | 82 | 48 |
| 08:45 | 54 | 77 | 48 |
| 09:00 | 52 | 72 | 48 |
| 09:15 | 51 | 62 | 48 |
| 09:30 | 52 | 63 | 49 |
| 09:45 | 52 | 65 | 48 |
| 10:00 | 52 | 61 | 49 |
| 10:15 | 54 | 75 | 49 |
| 10:30 | 53 | 69 | 49 |
| 10:45 | 52 | 65 | 49 |
| 11:00 | 52 | 60 | 49 |
| 11:15 | 52 | 64 | 49 |
| 11:30 | 52 | 66 | 50 |
| 11:45 | 55 | 74 | 50 |
| 12:00 | 53 | 64 | 50 |
| 12:15 | 56 | 68 | 52 |
| 12:30 | 53 | 65 | 50 |
| 12:45 | 53 | 68 | 50 |
| 13:00 | 54 | 74 | 49 |
| 13:15 | 53 | 70 | 50 |
| 13:30 | 54 | 68 | 51 |
| 13:45 | 54 | 67 | 51 |
| 14:00 | 53 | 62 | 51 |
| 14:15 | 53 | 62 | 50 |
| 14:30 | 56 | 78 | 51 |
| 14:45 | 53 | 64 | 50 |
| 15:00 | 56 | 70 | 51 |
| 15:15 | 54 | 67 | 50 |
| 15:30 | 54 | 66 | 50 |
| 15:45 | 56 | 71 | 50 |
| 16:00 | 54 | 66 | 50 |
| 16:15 | 53 | 67 | 50 |
| 16:30 | 54 | 74 | 50 |
| 16:45 | 53 | 63 | 50 |
| 17:00 | 54 | 71 | 50 |
| 17:15 | 52 | 65 | 50 |
| 17:30 | 52 | 64 | 49 |
| 17:45 | 52 | 68 | 49 |
| 18:00 | 52 | 64 | 49 |
| 18:15 | 52 | 67 | 49 |
| 18:30 | 52 | 64 | 49 |
| 18:45 | 52 | 69 | 49 |
| 19:00 | 52 | 61 | 48 |
| 19:15 | 51 | 64 | 48 |

quietly moving forward

Waitrose Ltd

Tabulated Noise data

Sheet 2 of 3

| Time | L _{Aeq} | L _{AMax} | L _{A90} |
|-------|------------------|-------------------|------------------|
| 19:30 | 54 | 77 | 48 |
| 19:45 | 51 | 65 | 48 |
| 20:00 | 52 | 66 | 48 |
| 20:15 | 54 | 70 | 48 |
| 20:30 | 52 | 65 | 48 |
| 20:45 | 51 | 65 | 47 |
| 21:00 | 50 | 68 | 47 |
| 21:15 | 52 | 64 | 47 |
| 21:30 | 49 | 57 | 46 |
| 21:45 | 50 | 70 | 46 |
| 22:00 | 50 | 60 | 47 |
| 22:15 | 50 | 59 | 47 |
| 22:30 | 49 | 58 | 47 |
| 22:45 | 50 | 61 | 47 |
| 23:00 | 49 | 59 | 46 |
| 23:15 | 49 | 60 | 46 |
| 23:30 | 50 | 59 | 47 |
| 23:45 | 50 | 65 | 48 |
| 00:00 | 49 | 60 | 47 |
| 00:15 | 50 | 61 | 47 |
| 00:30 | 49 | 62 | 46 |
| 00:45 | 48 | 59 | 46 |
| 01:00 | 47 | 58 | 45 |
| 01:15 | 47 | 59 | 44 |
| 01:30 | 46 | 56 | 44 |
| 01:45 | 46 | 57 | 44 |
| 02:00 | 46 | 60 | 44 |
| 02:15 | 50 | 66 | 44 |
| 02:30 | 47 | 65 | 43 |
| 02:45 | 45 | 60 | 43 |
| 03:00 | 44 | 54 | 43 |
| 03:15 | 45 | 55 | 43 |
| 03:30 | 45 | 55 | 43 |
| 03:45 | 45 | 53 | 43 |
| 04:00 | 45 | 59 | 43 |
| 04:15 | 45 | 58 | 43 |
| 04:30 | 46 | 60 | 43 |
| 04:45 | 46 | 68 | 43 |
| 05:00 | 49 | 68 | 44 |
| 05:15 | 49 | 75 | 44 |
| 05:30 | 52 | 70 | 44 |
| 05:45 | 48 | 63 | 44 |
| 06:00 | 56 | 73 | 45 |
| 06:15 | 51 | 68 | 46 |
| 06:30 | 49 | 61 | 46 |
| 06:45 | 53 | 76 | 46 |
| 07:00 | 50 | 62 | 47 |
| 07:15 | 50 | 65 | 46 |

| Time | L _{Aeq} | L _{AMax} | L _{A90} |
|-------|------------------|-------------------|------------------|
| 07:30 | 50 | 74 | 46 |
| 07:45 | 49 | 60 | 46 |
| 08:00 | 52 | 69 | 46 |
| 08:15 | 50 | 65 | 46 |
| 08:30 | 51 | 66 | 47 |
| 08:45 | 52 | 72 | 46 |
| 09:00 | 49 | 59 | 47 |
| 09:15 | 50 | 64 | 48 |
| 09:30 | 51 | 64 | 48 |
| 09:45 | 54 | 70 | 49 |
| 10:00 | 51 | 65 | 48 |
| 10:15 | 55 | 70 | 49 |
| 10:30 | 52 | 63 | 49 |
| 10:45 | 52 | 66 | 50 |
| 11:00 | 52 | 63 | 50 |
| 11:15 | 54 | 66 | 50 |
| 11:30 | 54 | 73 | 51 |
| 11:45 | 54 | 69 | 50 |
| 12:00 | 56 | 81 | 50 |
| 12:15 | 54 | 69 | 51 |
| 12:30 | 54 | 76 | 51 |
| 12:45 | 53 | 66 | 50 |
| 13:00 | 55 | 68 | 51 |
| 13:15 | 53 | 65 | 50 |
| 13:30 | 53 | 70 | 51 |
| 13:45 | 56 | 72 | 51 |
| 14:00 | 54 | 67 | 51 |
| 14:15 | 53 | 64 | 50 |
| 14:30 | 55 | 72 | 51 |
| 14:45 | 54 | 65 | 51 |
| 15:00 | 54 | 66 | 51 |
| 15:15 | 54 | 76 | 51 |
| 15:30 | 55 | 68 | 51 |
| 15:45 | 53 | 66 | 50 |
| 16:00 | 54 | 75 | 50 |
| 16:15 | 55 | 72 | 50 |
| 16:30 | 53 | 65 | 50 |
| 16:45 | 54 | 65 | 51 |
| 17:00 | 53 | 66 | 49 |
| 17:15 | 54 | 65 | 50 |
| 17:30 | 53 | 68 | 50 |
| 17:45 | 55 | 68 | 50 |
| 18:00 | 52 | 62 | 49 |
| 18:15 | 51 | 60 | 48 |
| 18:30 | 52 | 65 | 49 |
| 18:45 | 52 | 67 | 49 |
| 19:00 | 52 | 65 | 49 |
| 19:15 | 53 | 74 | 49 |

quietly moving forward

Waitrose Ltd

Tabulated Noise data

| Time | L _{Aeq} | L _{AMax} | L _{A90} |
|-------|------------------|-------------------|------------------|
| 19:30 | 52 | 67 | 49 |
| 19:45 | 52 | 72 | 49 |
| 20:00 | 51 | 63 | 48 |
| 20:15 | 50 | 61 | 47 |
| 20:30 | 50 | 63 | 48 |
| 20:45 | 61 | 73 | 53 |
| 21:00 | 51 | 66 | 47 |
| 21:15 | 53 | 67 | 47 |
| 21:30 | 50 | 71 | 47 |
| 21:45 | 50 | 63 | 46 |
| 22:00 | 49 | 64 | 46 |
| 22:15 | 49 | 59 | 45 |
| 22:30 | 48 | 60 | 45 |
| 22:45 | 48 | 61 | 45 |
| 23:00 | 47 | 57 | 44 |
| 23:15 | 47 | 58 | 44 |
| 23:30 | 49 | 72 | 44 |
| 23:45 | 50 | 77 | 43 |
| 00:00 | 47 | 60 | 43 |
| 00:15 | 47 | 67 | 43 |
| 00:30 | 45 | 58 | 43 |
| 00:45 | 45 | 59 | 43 |
| 01:00 | 44 | 57 | 42 |
| 01:15 | 45 | 57 | 42 |
| 01:30 | 50 | 76 | 43 |
| 01:45 | 48 | 68 | 42 |
| 02:00 | 44 | 55 | 42 |
| 02:15 | 44 | 55 | 43 |
| 02:30 | 44 | 55 | 43 |
| 02:45 | 44 | 56 | 42 |
| 03:00 | 44 | 58 | 43 |
| 03:15 | 45 | 59 | 42 |
| 03:30 | 44 | 57 | 42 |
| 03:45 | 44 | 56 | 42 |
| 04:00 | 44 | 55 | 43 |
| 04:15 | 46 | 63 | 43 |
| 04:30 | 48 | 65 | 44 |
| 04:45 | 51 | 79 | 45 |
| 05:00 | 48 | 60 | 45 |
| 05:15 | 51 | 67 | 46 |
| 05:30 | 50 | 66 | 47 |
| 05:45 | 53 | 76 | 48 |
| 06:00 | 55 | 72 | 50 |
| 06:15 | 56 | 78 | 50 |
| 06:30 | 55 | 68 | 51 |
| 06:45 | 54 | 70 | 51 |
| 07:00 | 55 | 72 | 51 |
| 07:15 | 54 | 65 | 51 |

Sheet 3 of 3

| Time | L _{Aeq} | L _{AMax} | L _{A90} |
|-------|------------------|-------------------|------------------|
| 07:30 | 54 | 72 | 51 |
| 07:45 | 54 | 67 | 51 |
| 08:00 | 53 | 74 | 50 |
| 08:15 | 54 | 73 | 50 |
| 08:30 | 54 | 71 | 50 |
| 08:45 | 54 | 78 | 49 |
| 09:00 | 52 | 63 | 49 |
| 09:15 | 54 | 70 | 50 |
| 09:30 | 55 | 71 | 49 |
| 09:45 | 53 | 63 | 50 |
| 10:00 | 52 | 67 | 49 |
| 10:15 | 52 | 70 | 48 |
| 10:30 | 51 | 62 | 48 |
| 10:45 | 52 | 69 | 49 |
| 11:00 | 53 | 69 | 49 |
| 11:15 | 54 | 65 | 50 |
| 11:30 | 54 | 68 | 50 |
| 11:45 | 55 | 80 | 50 |
| 12:00 | 54 | 66 | 50 |
| 12:15 | 53 | 67 | 50 |
| 12:30 | 52 | 74 | 49 |

quietly moving forward


APPENDIX E

**SURVEY RESULTS
(GRAPHICAL)**

Noise Level Time History at Waitrose Ruislip MP2 - North east roof




— LAeq — LAFmax — LAF90



Noise Level Time History at Waitrose Ruislip MP1 Partners Terrace Roof



— LAeq — LAFmax — LAF90



APPENDIX F

PUBLISHED PLANT NOISE DATA

| DRY AIR COOLER (DAC) SELECTION | | | | | | | | |
|--------------------------------|-----------------|---------------------|-----------------|---------------------------|--------------------------------|----------------------------------|--|-------------------------------|
| DAC REFERENCE NUMBER | YEAR OF INSTALL | STATUS Existing New | PLANT SELECTION | | | | | UNIT NOISE RATING DB(A) @ 10M |
| | | | SUPPLIER | DAC MODEL REFERENCE | COASTAL / CORROSIVE ATMOSPHERE | COIL / FIN MATERIAL CONSTRUCTION | APPROXIMATE UNIT WEIGHT INCLUDING FLUID (KG) | |
| DAC1 | 2026 | NEW | CLADE | ASL-ZAP-EC-243-ECMP-448-H | NO | CU/ALMG | 1822 | 35 |
| DAC2 | 2026 | NEW | CLADE | ASL-ZAP-EC-243-ECMP-448-H | NO | CU/ALMG | 1822 | 35 |

| DESIGN CONDITIONS | | | | | | | | |
|--|--|--|--|--|--|--|--|--|
| FLUID = 15% PROPYLENE GLYCOL - FLUID FLOW/RETURN TEMPERATURE = +40° / +46°C (Gen3) | | | | | | | | |

| WATER COOLED COLDROOM CONDENSING UNITS (TABLE A) | | | | | | | | |
|--|-----------------|---|-----------------|-----------------------------|----------|-------------|------------------------------|-------------------------------|
| PLANT REFERENCE NUMBER | YEAR OF INSTALL | STATUS Existing New Refurbished Offsite Ref. | PLANT SELECTION | | | | INSTALLATION | |
| | | | SUPPLIER | PLANT MODEL REFERENCE | SST (°C) | APPLICATION | APPROXIMATE UNIT WEIGHT (KG) | UNIT NOISE RATING DB(A) @ 10M |
| LT1 | 2026 | NEW | SCM FRIGO | CUB02 AQUA UMT WG T067 BTDX | -30 | FREEZER | 176 | 41 |
| LT2 | 2026 | NEW | SCM FRIGO | CUB02 AQUA UMT WG T067 BTDX | -30 | FREEZER | 176 | 41 |
| HT1 | 2026 | NEW | SCM FRIGO | CUB02 AQUA UMT WG T067 MTDX | -8 | CHILLER | 150 | 41 |
| HT2 | 2026 | NEW | SCM FRIGO | CUB02 AQUA UMT WG T067 MTDX | -8 | CHILLER | 150 | 41 |
| HT3 | 2026 | NEW | SCM FRIGO | CUB02 AQUA UMT WG T067 MTDX | -5 | CHILLER | 150 | 41 |
| HT4 | 2026 | NEW | SCM FRIGO | CUB02 AQUA UMT WG T067 MTDX | -5 | CHILLER | 150 | 41 |

IMPORTANT NOTE FOR CLADE HYDRO MINI UNITS ONLY: THE ELECTRICAL CURRENTS STATED ABOVE ARE FOR THE CLADE CONDENSING UNIT ONLY. AS THE UNIT ALSO ACTS AS A DISTRIBUTION BOARD, ALL CABLING MUST TAKE INTO ACCOUNT THE



Sky Air Alpha-

2 Specifications

1 - 1 RZAG-NV1

| Technical Specifications | | | | RZAG71NV1 | RZAG100NV1 | RZAG125NV1 |
|--------------------------|---------------------|-----------|----------|-----------|--------------------------------------|------------|
| Casing | Colour | | Material | | Ivory white | |
| | | | | | Painted galvanized steel plate | |
| Dimensions | Unit | Height | mm | | 870 | |
| | | Width | mm | | 1,100 | |
| | | Depth | mm | | 460 | |
| | Packed unit | Height | mm | | 1,043 | |
| | | Width | mm | | 1,205 | |
| | | Depth | mm | | 509 | |
| Weight | Unit | kg | | 81 | 85 | 94 |
| | Packed unit | kg | | 92 | 95 | 10 |
| Packing | Weight | kg | | | 10 | |
| Heat exchanger | Fin | Type | | | WF fin | |
| | | Treatment | | | Anti-corrosion treatment (PE) | |
| Fan | Type | | | | Propeller | |
| | Discharge direction | | | | Horizontal | |
| | Quantity | | | | 1 | |
| | Air flow rate | Cooling | Nom. | m³/min | 68 | 80 |
| | | Heating | Nom. | m³/min | 75 | 80 |
| | | | Partial | m³/min | - | 45 |
| Fan motor | Quantity | | | | 1 | |
| | Model | | | | Brushless DC motor | |
| | Output | | W | | 234 | |
| | Drive | | | | Direct drive | |
| Compressor | Quantity | | | | 1 | |
| | Type | | | | Hermetically sealed swing compressor | |
| Operation range | Cooling | Ambient | Min. | °CDB | -20 | |
| | | | Max. | °CDB | 52 | |
| | Heating | Ambient | Min. | °CWB | -20 | |
| | | | Max. | °CWB | 18 | |
| Sound power level | Cooling | | dBA | 64 | 66 | 69 |
| | Heating | | dBA | - | - | 68 (1) |
| Sound pressure | Cooling | Nom. | dBA | 46 | 47 | 49 |


quietly moving forward

| Outdoor Units | | | RZAG35B |
|--------------------------|-------------------------------|-------------|-----------------------|
| Dimensions | Height x Width x Depth | mm | 734 x 870 x 373 |
| Weight | | kg | 52 |
| Electrical Details | | | 1ph |
| | Power Supply | | 13.42 |
| | Maximum Input Current (MCA) A | | 16 |
| | Max Fuse Size | A | |
| Interconnection Wiring | Core / Cable Size | | 3+E / 1.5 |
| Piping Connections | Liquid / Gas | inches (mm) | 1/4 (6.4) / 3/8 (9.5) |
| Pipework | Maximum Length | m | 50 |
| | Maximum Vertical Rise | m | 30 |
| | Precharged to | m | 30 |
| | Additional charge | g/m | 20 |
| | Holding charge | kg | 1.55 |
| Sound Pressure (Cooling) | Nominal | dBA | 48 |
| Sound Pressure (Heating) | Nominal | dBA | 48 |
| Sound Power (Cooling) | | dBA | 62 |

 **MUB 025 315EC Multibox**
Performance

Item Number: #235423 Operating Mode: 230V 1~ 50/60Hz - 90° air flow

Performance curve



Hydraulic data

| | |
|--------------------------|---------------|
| Required air flow | 0.36 m³/s |
| Required static pressure | 241 Pa |
| Working air flow | 0.36 m³/s |
| Working static pressure | 241 Pa |
| Air density | 1.204 kg/m³ |
| Power | 168.8 W |
| Fan control - RPM | 1,556 rpm |
| Current | 1.39 A |
| SFP | 0.471 kW/m³/s |
| Control voltage | 10.0 V |
| Supply voltage | 230 V |

| Sound power level | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | Total | |
|--|-------|-----|-----|-----|----|----|----|----|-------|----|
| Inlet | dB(A) | 31 | 53 | 55 | 60 | 64 | 65 | 58 | 48 | 69 |
| Outlet | dB(A) | 33 | 54 | 56 | 61 | 66 | 66 | 59 | 50 | 70 |
| Surrounding | dB(A) | 10 | 33 | 29 | 29 | 34 | 38 | 25 | 12 | 41 |
| Sound pressure level at 3m (20m² Sabine) | dB(A) | - | - | - | - | - | - | - | 34 | |
| Sound pressure level at 3m free field | dB(A) | - | - | - | - | - | - | - | 20 | |

PROJECT PROPOSAL



**TECHNICAL DATA SELECTION
PRELIMINARY**

SW: # DB: #

PROJECT N.: ..
DATE: 31-07-2025
PROJECT NAME:

Output data

Requested model

PLN 154 H_cc heating

Cooling

| | | USR W 24°C 18°C 30% SRC A 35.0°C 40% | USR W 24°C 18°C 30% SRC A 35.0°C 40% | USR W 24°C 18°C 27% SRC A 35.0°C 40% |
|---|-----|--|--|--|
| Data Inputs | | | | |
| Cooling capacity [UNI EN 14511] | kW | 183.0 | 183.0 | 183.0 |
| Water Flow user side | l/h | 26300 | 26300 | 26300 |
| Water Pressure drops user side | kPa | 30 | 30 | 30 |
| Total Power input [UNI EN 14511] | kW | 54.8 | 54.8 | 54.8 |
| Total Absorbed Current | A | 121.8 | 121.8 | 121.8 |
| EER [UNI EN 14511] | W/W | 3.34 | 3.34 | 3.34 |
| LP Pumps (option) User side - Available pressure head | kPa | t.b.d. | t.b.d. | t.b.d. |
| HP Pumps (option) User side - Available pressure head | kPa | t.b.d. | t.b.d. | t.b.d. |

Heating

| | | USR W 65°C 70°C 30% SRC A 0°C 87% | USR W 65°C 70°C 30% SRC A -4°C 87% | USR W 60°C 70°C 27% SRC A -4°C 87% |
|---|-------|---|--|--|
| Data Inputs | | | | |
| Heating capacity [UNI EN 14511] | kW | 125.0 | 115.5 | 115.5 |
| Water Flow user side | l/h | 21900 | 20280 | 10130 |
| Water Pressure drops user side | kPa | 20 | 18 | 5 |
| Total Power input [UNI EN 14511] | kW | 68.4 | 68.1 | 66.5 |
| Total Absorbed Current | A | 138.7 | 138.2 | 135.0 |
| COP [UNI EN 14511] | W/W | 1.83 | 1.70 | 1.73 |
| SCOP | Wh/Wh | 4.00 | 4.00 | 4.00 |
| Eta s (Seasonal Heating Efficiency) | | 157.00 | 157.00 | 157.00 |
| Heating Seasonal Efficiency Class (Range A+++ -> D) | | A+++ | A+++ | A+++ |
| LP Pumps (option) User side - Available pressure head | kPa | t.b.d. | t.b.d. | t.b.d. |
| HP Pumps (option) User side - Available pressure head | kPa | t.b.d. | t.b.d. | t.b.d. |

Common Data

| | | | | |
|--|-------|-----|-----|-----|
| Maximum absorbed current (FLA) [without options] | A | 157 | 157 | 157 |
| Start up current (LRA) [without options] | A | 320 | 320 | 320 |
| Start up current with Soft Starter kit [without options] | A | 261 | 261 | 261 |
| Sound power level Lw (Low Noise) [without options] | dB(A) | 82 | 82 | 82 |
| Sound pressure level Lp (Low Noise) [EN3744] | dB(A) | 53 | 53 | 53 |