



SECTION A-A
(SCALE 1:25)



- 1) ALL DIMENSIONS ARE IN mm'S UNLESS OTHERWISE SHOWN.
- 2) THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT CONTRACT DOCUMENTATION AND SPECIFICATIONS.
- 3) NOM. COVER TO REINFORCEMENT 50mm UNLESS NOTED OTHERWISE.
- 4) ALL REINFORCEMENT TO BE HIGH YIELD GRADE 500N/mm² BARS TO BS 4449.
- 5) ALL REINFORCEMENT TO BE CUT & SHAPED IN ACCORDANCE WITH BS 8666: 2005
- 6) LAP LENGTH TO BARS SHALL BE :
NOMINAL 40xBAR
MINIMUM 38xBAR ϕ
- 7) THE CONTRACTOR SHALL PROVIDE CHAIRS AND SPACERS AT MORE THAN 1m CENTRES AS NECESSARY TO SUPPORT REINFORCEMENT AND MAINTAIN SPECIFIED COVER DURING PLACEMENT OF CONCRETE.
- 8) SHORT BARS TO BE FIXED AT ALTERNATE ENDS TO STAGGER LAP POSITIONS.

80-405824-054 - 11kV FOUNDATION GA
80-405824-056 - 11kV FOUNDATION RC SCHEDULE

REVISION:	AB		AS BUILT
DRAWN:	W.OGUNYINKA	23.03.20	
CHECKED:	A.TEASDALE	23.03.20	
APPROVED:	G.ARMITAGE	23.03.20	

Scale : AS NOTED		Date : 29.08.18
Drawn : A.TEASDALE	Checked : M.LOWE	Approved : G.ARMITAGE
Client Dwg No. :		Rev : AB
FPS Dwg No. :	80-405824-055	