Project Management Initials : Designer : S.G. Checked : K.T. Approved : S.G. ISO_A0 1189mm x 841mm

Last saved by: ZHUBRO2021-08-10 Last Plotted: 2021-08-10
Filename: \\AECOM-EUR.AECOMNET.COM\UKAUC$\PROJECTS\BP\60642181_HILLINGDON\900_CAD_GIS\912_DISCIPLINE_MEP_MOUNT VERNON\EXTERNAL SERVICES\THHR-ACM-MV-ZZ-DR-E-6002.DWG

BASE DRAWINGS

USED IN COMPILATION OF THIS DRAWING :

Author	Drawing No / Rev	Date Received

TN

DB-EX-01-2L2 A1
3 x M/C
CABLE DUCT REQUIRED UNDER HARDSTANDING
DB-EX-01-2L2 A2
DB-EX-01-2L2 A1
EXISTING LIGHTING COLUMN TO BE USED TO MOUNT CCTV SIGNAL TRANSMITTER
CIRCUIT: DB-EX-01-1L2
DB-EX-01-2L2 A1
CABLE DUCT REQUIRED UNDER HARDSTANDING
REMOVE EXISTING LIGHTING COLUMN AND ASSOCIATED CABLING
EXISTING LIGHTING CABLE SUPPLIED FROM CHAPEL TO BE SAFELY ISOLATED AND REMOVED
DB-EX-01-2L2 A1
EXISTING COLUMN TO BE REMOVED AND REPLACED WITH NEW COLUMN WITH A2 COLUMN TOP LUMINAIRE
EXISTING BARRIER BOLLARDS TO BE REMOVED.
DB-EX-01-2L2 A1
DB-EX-01-2L2 A1
A1 DB-EX-01-2L2
CABLE DUCT REQUIRED UNDER HARDSTANDING
DB-EX-01-2L2 A1
DB-EX-01-1L3 A3
180
DB-EX-01-1L3 A2
DB-EX-01-1L3 A2
DB-EX-01-1L3 A2