

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
00_WC/Shower 002		-	112	-	39
00_WC/Shower 003		-	131	-	24
00_WC/Shower 004		-	117	-	37
00_WC/Shower 005		-	119	-	36
00_WC/Shower 006		-	116	-	38
00_Wheelchairs/Trolleys St		64	-	-	105
00_X-Ray 001		-	119	-	588
00_X-Ray 002		-	118	-	615
00_X-Ray 003		-	122	-	625
01_A. Pat Change		-	147	-	26
01_A. WC 001		-	128	-	47
01_A. WC 002		-	134	-	40
01_A. WC 003		-	131	-	46
01_A. WC 004		-	120	-	49
01_A. WC 005		-	134	-	39
01_A. WC 006		-	134	-	37
01_A. WC 007		-	134	-	33
01_A. WC 008		-	134	-	37
01_A. WC 009		-	134	-	36
01_A. WC 010		-	134	-	35
01_A. WC 011		-	103	-	88
01_A. WC 012		-	123	-	45
01_A. WC 013		-	134	-	37
01_A. WC 014		-	134	-	36
01_A. WC 015		-	134	-	39
01_A. WC 016		-	134	-	34
01_A. WC 017		-	112	-	57
01_A. WC 018		-	134	-	37
01_A. WC 019		-	134	-	22
01_A. WC 020		-	134	-	33
01_A. WC 021		-	134	-	34
01_A. WC 022		-	134	-	28
01_A. WC 023		-	134	-	37
01_A. WC 024		-	123	-	45
01_A. WC 025		-	134	-	22
01_A. WC 026		-	133	-	41
01_A. WC 027		-	134	-	32
01_A. WC 028		-	134	-	34
01_A. WC 029		-	134	-	27
01_A. WC 030		-	134	-	39
01_A. WC 031		-	134	-	26
01_A. WC 032		-	134	-	40
01_A. WC 033		-	134	-	39

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
01_A. WC 034		-	134	-	38
01_A. WC/Chg		-	127	-	44
01_A. WC/Nappy change 001		-	134	-	39
01_A. WC/Nappy change 002		-	134	-	33
01_A. WC/Shower 001		-	131	-	21
01_A. WC/Shower 002		-	131	-	20
01_A. WC/Shower 003		-	131	-	26
01_A. WC/Shower 004		-	131	-	28
01_A. WC/Shower 005		-	131	-	23
01_A. WC/Shower 006		-	131	-	24
01_A. WC 035		-	134	-	37
01_A. WC 036		-	133	-	41
01_A. WC 037		-	134	-	30
01_Admin Office		146	-	-	104
01_Admin Space		149	-	-	99
01_Anaesthetic Room		-	194	-	210
01_Audiology Manager		180	-	-	66
01_BED/FM Lift Lobby 001		-	92	-	187
01_BED/FM Lift Lobby 002		-	91	-	190
01_BED/FM Lift Lobby 003		-	92	-	186
01_BED/FM Lift Lobby 004		-	92	-	186
01_Bev Bay 001		-	188	-	7
01_Bev Bay 002		-	133	-	27
01_Breast Treat		-	247	-	61
01_C.U. 001		130	-	-	48
01_C.U. 002		139	-	-	45
01_C.U. 003		135	-	-	49
01_C.U. 004		123	-	-	61
01_C.U. 005		108	-	-	73
01_C.U. 006		103	-	-	75
01_C.U. 007		118	-	-	70
01_C.U. 008		115	-	-	62
01_C.U. 009		134	-	-	46
01_C.U. 010		136	-	-	44
01_C.U. 011		140	-	-	45
01_C.U. 012		112	-	-	68
01_C.U. scope Decont		76	-	-	163
01_C.U./Med Store/Prep		81	-	-	146
01_C/E 001		-	172	-	140
01_C/E 002		-	172	-	119
01_C/E 003		-	176	-	115
01_C/E 004		-	171	-	119
01_C/E 005		-	173	-	118

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
01_C/E 006		-	169	-	123
01_C/E 007		-	173	-	118
01_C/E 008		-	169	-	124
01_C/E 009		-	174	-	117
01_C/E 010		-	171	-	121
01_C/E 011		-	162	-	136
01_C/E 012		-	174	-	117
01_C/E 013		-	170	-	126
01_C/E 014		-	171	-	124
01_C/E 015		-	164	-	135
01_C/E 016		-	173	-	122
01_C/E 017		-	170	-	122
01_C/E 018		-	135	-	240
01_C/E 019		-	178	-	109
01_C/E 020		-	175	-	114
01_C/E 021		-	168	-	126
01_C/E 022		-	173	-	117
01_C/E 023		-	172	-	119
01_C/E 024		-	177	-	127
01_C/E - Optometrist 001		-	182	-	106
01_C/E - Optometrist 002		-	187	-	101
01_C/E Large/MDT 001		-	148	-	199
01_C/E Large/MDT 002		-	148	-	199
01_C/E Large/MDT 003		-	293	-	47
01_Cannualtion room 001		-	233	-	66
01_Cannualtion room 002		-	202	-	86
01_Cannualtion room 003		-	248	-	62
01_Cannualtion room 004		-	240	-	64
01_Cardiac/ECG 001		-	156	-	151
01_Cardiac/ECG 002		-	170	-	120
01_Cardiac/Echo 001		-	170	-	128
01_Cardiac/Echo 002		-	171	-	126
01_Cardiac/Echo 003		-	174	-	122
01_Cardiac/Echo 004		-	170	-	128
01_Charity St		167	-	-	33
01_Chem St.		157	-	-	54
01_Child Wait		-	84	60	111
01_Circulation 001		-	119	-	79
01_Circulation 002		-	82	-	356
01_Circulation 003		-	97	-	254
01_Circulation 004		-	80	-	209
01_Circulation 005		-	91	-	138
01_Circulation 006		-	98	-	274

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
01_Circulation 007		-	107	-	114
01_Circulation 008		-	79	-	526
01_Circulation 009		-	101	-	95
01_Circulation 010		-	76	-	410
01_Circulation 011		-	80	-	291
01_Circulation 012		-	115	-	77
01_Circulation 013		-	126	-	61
01_Circulation 014		-	103	-	139
01_Circulation 015		-	76	-	411
01_Circulation 016		-	120	-	73
01_Circulation 017		-	84	-	307
01_Clean St.		128	-	-	53
01_Cleaners 001		137	-	-	34
01_Cleaners 002		132	-	-	35
01_Cleaners 003		134	-	-	35
01_Cleaners 004		130	-	-	39
01_Cleaners 005		166	-	-	27
01_Clinical Room		-	197	-	98
01_Coffee Shop		-	90	-	160
01_Coffee Shop Seating 001		-	139	-	52
01_Coffee Shop Seating 002		-	143	-	132
01_Colposcopy		-	147	-	311
01_Complementary Therapy/Group Meeting		-	146	-	199
01_Cons. St.		94	-	-	110
01_Consult Booth		-	244	-	64
01_Contrast Prep Room		266	-	-	55
01_Control 001		130	-	-	148
01_Control 002		145	-	-	111
01_Control 003		150	-	-	101
01_Control 004		142	-	-	140
01_Corridor 001		-	81	-	744
01_Corridor 002		-	96	-	198
01_Corridor 003		-	85	-	736
01_Corridor 004		-	98	-	52
01_Corridor 005		-	102	-	165
01_Corridor 006		-	87	-	184
01_Corridor 007		-	91	-	381
01_Corridor 008		-	97	-	274
01_Corridor 009		-	87	-	258
01_Corridor 010		-	121	-	148
01_Corridor 011		-	89	-	701
01_Corridor 012		-	95	-	495
01_Corridor 013		-	126	-	127

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
01_Corridor 014		-	93	-	133
01_Corridor 015		-	91	-	252
01_Corridor 016		-	88	-	383
01_Corridor 017		-	88	-	439
01_Corridor 018		-	95	-	293
01_Corridor 019		-	86	-	151
01_Corridor 020		-	95	-	487
01_Corridor 021		-	82	-	918
01_Corridor 022		-	117	-	75
01_Corridor 023		-	188	-	31
01_Corridor 024		-	82	-	758
01_Corridor 025		-	90	-	903
01_Corridor 026		-	76	-	288
01_Corridor 027		-	83	-	1238
01_Corridor 028		-	86	-	898
01_Corridor 029		-	108	-	74
01_Corridor 030		-	104	-	225
01_Corridor 031		-	92	-	214
01_Corridor 032		-	93	-	389
01_Corridor 033		-	137	-	66
01_Corridor 034		-	95	-	226
01_Corridor 035		-	89	-	288
01_Corridor 036		-	76	-	1026
01_CT Control 001		142	-	-	150
01_CT Control 002		160	-	-	92
01_CT Scanner 001		-	115	-	675
01_CT Scanner 002		-	117	-	640
01_CT Scanner 003		-	112	-	737
01_CT Scanner 004		-	117	-	636
01_Cubicle 001		-	116	-	49
01_Cubicle 002		-	158	-	49
01_Cubicle 003		-	158	-	49
01_Cubicle 004		-	157	-	50
01_Cubicle 005		-	116	-	48
01_Cubicle 006		-	159	-	48
01_D.B. 001		176	-	-	12
01_D.B. 002		176	-	-	16
01_D.B. 003		176	-	-	16
01_D.B. 004		176	-	-	13
01_D.B. 005		176	-	-	19
01_D.B. 006		176	-	-	15
01_D.B. 007		176	-	-	12
01_D.B. 008		176	-	-	15

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
01_D.B. 009		176	-	-	12
01_D.B. 010		176	-	-	15
01_D.B. 011		176	-	-	16
01_D.B. 012		176	-	-	22
01_D.B. 013		176	-	-	14
01_D.B. 014		176	-	-	14
01_D.B. 015		176	-	-	26
01_D.B. 016		176	-	-	14
01_D.B. 017		176	-	-	14
01_D.B. 018		176	-	-	14
01_D.B. 019		176	-	-	17
01_D.B. 020		176	-	-	13
01_D.B. 021		176	-	-	17
01_D.B. 022		176	-	-	14
01_D.B. 023		176	-	-	16
01_D.B. 024		121	-	-	54
01_D.B. 025		164	-	-	38
01_D.B. 026		128	-	-	53
01_D.B. 027		133	-	-	48
01_D.B. 028		131	-	-	48
01_D.B. 029		156	-	-	38
01_D.B. 030		112	-	-	68
01_D.B. 031		126	-	-	60
01_D.B. 032		114	-	-	64
01_D.B. 033		137	-	-	48
01_D.B. 034		132	-	-	47
01_D.B. 035		129	-	-	48
01_D.B. 036		134	-	-	46
01_D.B. 037		127	-	-	64
01_D.B. 038		117	-	-	87
01_D.U. scope Decont		81	-	-	134
01_Day treat (recliner) 001		-	133	-	113
01_Day treat (recliner) 002		-	136	-	106
01_Day treat (recliner) 003		-	104	-	107
01_Day treat (recliner) 004		-	180	-	115
01_Day treat (recliner) 005		-	180	-	115
01_Day treat (recliner) 006		-	107	-	107
01_Day treat (recliner) 007		-	108	-	107
01_Day treat (recliner) 008		-	172	-	125
01_Day treat (recliner) 009		-	171	-	120
01_Day treat (recliner) 010		-	172	-	125
01_Day treat (recliner) 011		-	120	-	124
01_Day treat (recliner) 012		-	121	-	121

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
01_Day treat (recliner) 013		-	102	-	121
01_Day treat (recliner) 014		-	171	-	127
01_Day treat (recliner) 015		-	197	-	90
01_Day treat (recliner) 016		-	169	-	129
01_Day treat (recliner) 017		-	174	-	123
01_Day treat (recliner) 018		-	172	-	118
01_Day treat (recliner) 019		-	172	-	125
01_Day treat (recliner) 020		-	293	-	33
01_Day treat (recliner) 021		-	174	-	123
01_Day treat (recliner) 022		-	172	-	125
01_Day treat (recliner) 023		-	171	-	120
01_Day treat (recliner) 024		-	171	-	120
01_Day treat (recliner) 025		-	170	-	123
01_Dental Surgery 001		-	172	-	284
01_Dental Surgery 002		-	171	-	285
01_Dental Surgery 003		-	172	-	281
01_Disposal 001		126	-	-	51
01_Disposal 002		126	-	-	52
01_Disposal 003		148	-	-	43
01_Disposal 004		133	-	-	49
01_Disposal 005		133	-	-	48
01_DOF Lobby 001		-	188	-	28
01_DOF Lobby 002		-	188	-	26
01_DON Clean 001		-	147	-	21
01_DON Clean 002		-	147	-	30
01_DON Dirty		-	147	-	33
01_DON Lobby 001		-	188	-	26
01_DON Lobby 002		-	188	-	27
01_DON/DOFF area 001		-	138	-	31
01_DON/DOFF area 002		-	124	-	37
01_Donation/Contact Point		126	-	-	167
01_Donations St		156	-	-	37
01_Endoscopy Suites 001		-	134	-	387
01_Endoscopy Suites 002		-	136	-	374
01_Endoscopy Suites 003		-	133	-	395
01_Ensuite 001		-	131	-	17
01_Ensuite 002		-	131	-	17
01_Ensuite 003		-	131	-	17
01_Ensuite 004		-	131	-	17
01_Ensuite 005		-	131	-	17
01_Ensuite 006		-	131	-	17
01_Ensuite 007		-	131	-	17
01_Ensuite 008		-	131	-	18

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
01_Ensuite 009		-	131	-	17
01_Ensuite 010		-	131	-	17
01_Eq. Bay		167	-	-	7
01_Eq. Store 001		117	-	-	60
01_Eq. Store 002		167	-	-	21
01_Eq. Store 003		137	-	-	48
01_Exam room 001		-	193	-	95
01_Exam room 002		-	195	-	93
01_Exam room 003		-	194	-	101
01_Exam room 004		-	189	-	98
01_Exam room 005		-	194	-	101
01_Fitting Room 001		-	176	-	145
01_Fitting Room 002		-	180	-	115
01_Fitting Room 003		-	185	-	135
01_Fitting Room 004		-	180	-	130
01_Foot wash/Shoe storage		101	-	-	59
01_General Office		118	-	-	180
01_Group Room		94	-	-	176
01_Hearing Test Room/Booth		-	164	-	154
01_Hearing Therapist		-	183	-	128
01_Hot Desk		262	-	-	56
01_Hot Desks		226	-	-	69
01_Hot Pack bay		153	-	-	41
01_Hysteroscopy		-	140	-	344
01_ICC (Incident Coordination Centre)		86	-	-	490
01_Ice Pack bay		-	188	-	17
01_Imaging: Fluoro		-	116	-	643
01_Imaging: Gamma		-	116	-	644
01_Imaging: IR		-	117	-	767
01_Imaging: X-Ray inpatient		-	120	-	570
01_Inj Room		-	196	-	100
01_Inpatient hold 001		-	98	60	113
01_Inpatient hold 002		-	84	60	112
01_Inpatient hold 003		-	109	60	100
01_Inpatient hold for 3		-	90	60	192
01_Interview 001		230	-	-	52
01_Interview 002		186	-	-	71
01_Interview 003		230	-	-	52
01_Interview 004		188	-	-	70
01_Interview 005		210	-	-	54
01_Interview 006		203	-	-	61
01_Interview 007		188	-	-	64
01_Interview 008		191	-	-	62

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
01_Interview 009		160	-	-	89
01_Interview 010		196	-	-	59
01_Interview 011		213	-	-	50
01_Interview 012		162	-	-	89
01_Interview & Virtual Cnslt		201	-	-	57
01_IT HUB 001		392	-	-	40
01_IT HUB 002		282	-	-	77
01_IT HUB 003		276	-	-	82
01_IT HUB 004		271	-	-	86
01_IT HUB 005		437	-	-	36
01_IT HUB 006		276	-	-	82
01_IT HUB 007		334	-	-	54
01_Laboratory		179	-	-	114
01_Laser		-	175	-	213
01_Linen 001		167	-	-	20
01_Linen 002		167	-	-	18
01_Linen 003		154	-	-	27
01_Lobby 002		-	151	-	38
01_Lobby 003		-	150	-	61
01_Lobby 005		-	188	-	22
01_Management Office: Fluoro/IT (4)		153	-	-	96
01_Management Office: US (4)		143	-	-	109
01_Measure Bay 001		-	293	-	42
01_Measure Bay 002		-	293	-	43
01_Medical Examiner Office		150	-	-	149
01_Meds Store/Prep		115	-	-	218
01_Meeting Room		114	-	-	162
01_Mohs lab		152	-	-	121
01_MRI 001		-	115	-	677
01_MRI 002		-	114	-	681
01_MRI 003		-	110	-	802
01_MRI Lobby		-	132	-	52
01_Multi Faith Room		85	-	-	596
01_Muslin Prayer Room		109	-	-	184
01_Non-radioactive supplies		154	-	-	37
01_Office 001		166	-	-	83
01_Office 002		177	-	-	114
01_Office 003		183	-	-	98
01_Office 004		170	-	-	84
01_Office 005		165	-	-	108
01_Office 006		151	-	-	122
01_Office 007		164	-	-	78
01_Office 008		167	-	-	78

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
01_Office 009		139	-	-	130
01_Office 010		155	-	-	115
01_Office 011		177	-	-	68
01_Office 012		159	-	-	95
01_Office 013		133	-	-	131
01_Office 014		159	-	-	103
01_Office 015		184	-	-	86
01_Office Managers		183	-	-	64
01_Office Vetting		175	-	-	70
01_Office/Resource Base		140	-	-	121
01_Office: Analysis		153	-	-	172
01_Office: Manager		193	-	-	62
01_Office: Open Plan 001		151	-	-	165
01_Office: Open Plan 002		152	-	-	120
01_Ops Centre 001		307	-	-	27
01_Ops Centre 002		307	-	-	27
01_Ophthalmic 001		-	197	-	98
01_Ophthalmic 002		-	195	-	94
01_Ophthalmic 003		-	140	-	200
01_Ophthalmic 004		-	189	-	99
01_Opthamology: Lanes 001		-	243	-	70
01_Opthamology: Lanes 002		-	243	-	70
01_Oral Surgery		-	170	-	288
01_Outpatient Pharmacy		87	-	-	870
01_Overseas Office		129	-	-	137
01_PAC's Team		193	-	-	58
01_Pass		255	-	-	33
01_Pat Change 001		-	147	-	21
01_Pat Change 002		-	147	-	21
01_Pat Change 003		-	147	-	20
01_Pat Change 004		-	147	-	16
01_Pat Change 005		-	147	-	15
01_Pat Change 006		-	147	-	20
01_Pat Change 007		-	147	-	19
01_Pat Change 008		-	147	-	27
01_Pat Change 009		-	147	-	17
01_Pat Change 010		-	147	-	14
01_Pat Change 011		-	147	-	21
01_Pat Change 012		-	147	-	17
01_Pat Change 013		-	147	-	18
01_Pat Change 014		-	147	-	19
01_Pat Change 015		-	147	-	18
01_Pat Change 016		-	147	-	23

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
01_Pat Change 017		-	147	-	22
01_Pat Change 018		-	147	-	20
01_Pat Change 019		-	147	-	22
01_Pat Change 020		-	147	-	16
01_Pat Change 021		-	147	-	19
01_Pat Change 022		-	147	-	14
01_Pat Change 023		-	147	-	26
01_Pat Change 024		-	147	-	23
01_Pat Change 025		-	147	-	24
01_Pat Change 026		-	147	-	20
01_Pat Change 027		-	147	-	16
01_Pat Change: Assisted 001		-	147	-	26
01_Pat Change: Assisted 002		-	147	-	21
01_PFT Test 001		122	-	-	148
01_PFT Test 002		127	-	-	134
01_Phototherapy 001		-	177	-	136
01_Phototherapy 002		-	165	-	157
01_Plaster		-	118	-	413
01_Plebotomy 001		-	146	-	188
01_Plebotomy 002		-	158	-	55
01_Plebotomy 003		-	111	-	53
01_Plebotomy 004		-	158	-	55
01_Pre-assessment		-	194	-	125
01_Pre-op assessment		-	197	-	96
01_Prep/Recovery Stage 1 001		-	191	-	113
01_Prep/Recovery Stage 1 002		-	191	-	112
01_Prep/Recovery Stage 1 003		-	188	-	115
01_Prep/Recovery Stage 1 004		-	191	-	113
01_Prep/Recovery Stage 1 005		-	191	-	113
01_Prep/Recovery Stage 1 006		-	191	-	113
01_Prep/Recovery Stage 1 007		-	191	-	113
01_Prep/Recovery Stage 1 008		-	191	-	113
01_Prep/Recovery Stage 1 009		-	193	-	111
01_Prep/Recovery Stage 1 010		-	188	-	115
01_Radioactive open/closed sources		199	-	-	59
01_Radiology Office (6 MR/CT)		150	-	-	205
01_Radiology View/Report		221	-	-	48
01_Recap		-	160	-	100
01_Reception		-	179	60	43
01_Reception office		-	203	60	84
01_Reception/Wait 001		-	111	60	229
01_Reception/Wait 002		-	90	60	195
01_Reception/Wait 003		-	83	60	257

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
01_Reception/Wait 004		-	91	60	258
01_Reception/Wait 005		-	101	60	308
01_Reception/Wait 006		-	219	60	18
01_Reception/Wait 007		-	92	60	308
01_Reception/Wait 008		-	130	60	163
01_Reception/Wait 009		-	94	60	377
01_Recovery 001		-	115	-	65
01_Recovery 002		-	140	-	67
01_Recovery 003		-	116	-	66
01_Recovery 004		-	141	-	66
01_Recovery 005		-	116	-	64
01_Recovery 006		-	190	-	96
01_Recovery 007		-	140	-	216
01_Recovery 008		-	115	-	67
01_Recovery Stage 2		-	154	-	155
01_Repair Workshop		155	-	-	182
01_Reporting 001		255	-	-	35
01_Reporting 002		255	-	-	34
01_Reporting room: FLUORO		198	-	-	65
01_Reporting room: Nuclear Medicine		255	-	-	31
01_Reporting room: Recovery		110	-	-	239
01_Reporting Room: Ultrasound		223	-	-	45
01_Reporting Room: X-Ray		255	-	-	32
01_Reporting: Acute Team		142	-	-	118
01_Resus bay		-	280	-	5
01_RNIB		-	197	-	98
01_RO St.		150	-	-	43
01_Seminar		-	141	-	142
01_Seminar/MDT 001		-	138	-	144
01_Seminar/MDT 002		-	139	-	139
01_Shop 001		-	32	60	942
01_Shop 002		-	44	60	701
01_Shower 001		-	131	-	31
01_Shower 002		-	131	-	19
01_Shower 003		-	131	-	19
01_SHW/CH		-	131	-	30
01_Staff Base 001		-	97	-	60
01_Staff Base 002		-	76	-	78
01_Staff Base 003		-	82	-	52
01_Staff Base 004		-	100	-	76
01_Staff Base 005		-	153	-	69
01_Staff Base 006		-	89	-	102
01_Staff Base 007		-	163	-	56

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
01_Staff Base 008		-	82	-	52
01_Staff Base 009		-	76	-	54
01_Staff Base 010		-	68	-	66
01_Staff Change 001		-	87	-	70
01_Staff Change 002		-	86	-	72
01_Staff Change 003		-	120	-	39
01_Staff Change 004		-	72	-	110
01_Staff Change 005		-	74	-	102
01_Staff Change 006		-	73	-	122
01_Staff Rest/Bev 001		123	-	-	133
01_Staff Rest/Bev 002		125	-	-	143
01_Staff Rest/Bev 003		121	-	-	153
01_Staff Rest/Bev 004		123	-	-	146
01_Staff Rest/Bev (Combined)		101	-	-	301
01_Staff WC 001		-	134	-	33
01_Staff WC 002		-	134	-	26
01_Staff WC 003		-	134	-	25
01_Stair A		-	69	-	154
01_Stair C 001		-	72	-	160
01_Stair C 002		-	71	-	162
01_Stair D		-	71	-	147
01_Store 001		144	-	-	42
01_Store 002		107	-	-	75
01_Store 003		161	-	-	35
01_Store 004		167	-	-	15
01_Store 005		167	-	-	38
01_Store 006		167	-	-	15
01_Store 007		153	-	-	37
01_Store 008		167	-	-	13
01_Store 009		167	-	-	19
01_Store 010		167	-	-	24
01_Store 011		167	-	-	32
01_Store 012		154	-	-	37
01_Store 013		167	-	-	21
01_Store 014		137	-	-	47
01_Store 015		167	-	-	13
01_Store 016		167	-	-	27
01_Store 017		167	-	-	27
01_Store: Equipment 001		117	-	-	57
01_Store: Equipment 002		127	-	-	51
01_Store: Equipment 003		118	-	-	57
01_Store: Equipment (Shared)		104	-	-	81
01_Sub-Wait		-	219	60	49

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
01_Supplies St.		167	-	-	47
01_Switchgear		176	-	-	23
01_Therapies: Cardiac		-	117	-	240
01_Therapy Eq. St.		146	-	-	75
01_Therapy Female		-	193	-	95
01_Therapy/Gym		-	106	-	604
01_Therapy/Treat 001		-	191	-	96
01_Therapy/Treat 002		-	196	-	92
01_Therapy/Treat 003		-	193	-	95
01_Therapy/Treat 004		-	188	-	100
01_Therapy/Treat 005		-	199	-	90
01_Therapy/Treat 006		-	195	-	93
01_Treat: Procedures		-	142	-	217
01_Treatment 001		-	170	-	122
01_Treatment 002		-	160	-	146
01_Treatment 003		-	161	-	138
01_Treatment 004		-	165	-	135
01_Treatment 005		-	166	-	134
01_Treatment 006		-	169	-	123
01_Treatment (2-sided) 001		-	163	-	133
01_Treatment (2-sided) 002		-	167	-	126
01_Treatment (2-sided) 003		-	168	-	125
01_Treatment (2-sided) 004		-	166	-	129
01_Ultrasound 001		-	142	-	332
01_Ultrasound 002		-	154	-	281
01_Ultrasound 003		-	155	-	277
01_Ultrasound 004		-	137	-	365
01_Unit Pantry 001		112	-	-	70
01_Unit Pantry 002		150	-	-	38
01_US/Mammography 001		-	149	-	294
01_US/Mammography 002		-	152	-	279
01_Vestry		167	-	-	30
01_Viewing/Teaching area		-	187	-	77
01_Virtual Booth 001		-	293	-	31
01_Virtual Booth 002		-	293	-	34
01_Visitor Lift Lobby 001		-	108	-	137
01_Visitor Lift Lobby 002		-	109	-	132
01_Visitor Lift Lobby 003		-	108	-	136
01_Wait 001		-	94	60	225
01_Wait 002		-	158	60	119
01_Wait 003		-	173	60	33
01_Wait 004		-	132	60	107
01_Wait 005		-	125	60	132

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
01_Wait 006		-	111	60	193
01_Waiting Zone IR: 5 places		-	120	60	80
01_Waiting: 10 places 001		-	91	60	152
01_Waiting: 10 places 002		-	105	60	153
01_Waiting: 10 places 003		-	112	60	162
01_Waiting: 12 places		-	95	60	131
01_Waiting: 15 places		-	92	60	347
01_Waiting: 20 places		-	77	60	236
01_WC 001		-	134	-	20
01_WC 002		-	134	-	24
01_WC 003		-	134	-	35
01_WC 004		-	134	-	29
01_WC 005		-	134	-	30
01_WC 006		-	134	-	25
01_WC 007		-	134	-	30
01_WC 008		-	134	-	28
01_WC 009		-	134	-	27
01_WC 010		-	134	-	26
01_WC 011		-	134	-	32
01_WC 012		-	134	-	20
01_WC 013		-	134	-	27
01_WC 014		-	134	-	22
01_WC 015		-	134	-	26
01_WC: Staff 001		-	134	-	37
01_WC: Staff 002		-	134	-	21
01_X-Ray 001		-	126	-	646
01_X-Ray 002		-	119	-	575
01_X-Ray: Inpatient		-	121	-	603
02_4-Bed Bay 001		-	75	-	481
02_4-Bed Bay 002		-	75	-	479
02_A. WC 001		-	134	-	39
02_A. WC 002		-	134	-	30
02_A. WC 003		-	134	-	34
02_A. WC 004		-	134	-	38
02_A. WC 005		-	134	-	39
02_A. WC 006		-	134	-	35
02_A. WC 007		-	134	-	52
02_A. WC 008		-	134	-	38
02_A. WC 009		-	134	-	37
02_A. WC 010		-	132	-	42
02_A. WC 011		-	132	-	42
02_A. WC 012		-	134	-	38
02_A. WC 013		-	134	-	41

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
02_A. WC 014		-	134	-	38
02_A. WC/Shower 001		-	134	-	38
02_A. WC/Shower 002		-	134	-	39
02_A. WC/Shower 003		-	91	-	86
02_A. WC/Shower 004		-	134	-	39
02_A. WC/Shower 005		-	134	-	34
02_A. WC/Shower 006		-	89	-	88
02_A. WC/Shower 007		-	112	-	63
02_A. WC/Shower 008		-	112	-	62
02_A. WC/Shower 009		-	134	-	36
02_A. WC/Shower 010		-	134	-	30
02_Ambient General Store		95	-	-	124
02_Anaesthetic Room 001		-	159	-	304
02_Anaesthetic Room 002		-	159	-	307
02_Anaesthetic Room 003		-	163	-	287
02_Anaesthetic Room 004		-	158	-	311
02_Anaesthetic Room 005		-	160	-	300
02_Anaesthetic Room 006		-	159	-	303
02_Anaesthetic Room 007		-	159	-	307
02_Bariatric Bedroom		-	145	-	106
02_Bay: Ice Making 001		-	188	-	10
02_Bay: Ice Making 002		-	188	-	9
02_Bay: Wheelchair		-	188	-	8
02_BED/FM Lift Lobby 001		-	92	-	186
02_BED/FM Lift Lobby 002		-	91	-	190
02_BED/FM Lift Lobby 003		-	92	-	186
02_BED/FM Lift Lobby 004		-	92	-	187
02_Blood Issue		170	-	-	87
02_Blood Transfusion		87	-	-	418
02_Breakout Space 001		167	-	-	46
02_Breakout Space 002		164	-	-	47
02_Breakout Space 003		209	-	-	36
02_Breakout Space 004		182	-	-	42
02_C.U. 001		108	-	-	70
02_C.U. 002		85	-	-	73
02_C.U. 003		85	-	-	73
02_C.U. 004		123	-	-	57
02_C.U. 005		128	-	-	51
02_Circulation 001		-	101	-	95
02_Circulation 002		-	91	-	138
02_Circulation 003		-	79	-	540
02_Circulation 004		-	112	-	85
02_Circulation 005		-	138	-	48

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
02_Circulation 006		-	76	-	411
02_Circulation 007		-	114	-	83
02_Circulation 008		-	117	-	75
02_Circulation 009		-	83	-	322
02_Circulation 010		-	83	-	311
02_Circulation 011		-	97	-	383
02_Circulation 012		-	76	-	410
02_Circulation 013		-	79	-	590
02_Circulation 014		-	143	-	45
02_Clean Coats		110	-	-	54
02_Clean/Drug prep 001		129	-	-	162
02_Clean/Drug prep 002		129	-	-	160
02_Cleaners 001		121	-	-	42
02_Cleaners 002		155	-	-	28
02_Cleaners 003		129	-	-	37
02_Cleaners 004		137	-	-	33
02_Cleaners 005		141	-	-	35
02_Cleaners 006		137	-	-	35
02_Clinical Equipment 001		91	-	-	153
02_Clinical Equipment 002		92	-	-	152
02_Clinical Equipment Cleaning		91	-	-	149
02_Clinical/Sterile Supplies 001		85	-	-	192
02_Clinical/Sterile Supplies 002		85	-	-	192
02_Cold room		98	-	-	132
02_Control Point		135	-	-	88
02_Corridor 001		-	89	-	555
02_Corridor 002		-	91	-	156
02_Corridor 003		-	75	-	166
02_Corridor 004		-	82	-	667
02_Corridor 005		-	84	-	791
02_Corridor 006		-	105	-	239
02_Corridor 007		-	74	-	1089
02_Corridor 008		-	75	-	167
02_Corridor 009		-	91	-	271
02_Corridor 010		-	92	-	565
02_Corridor 011		-	82	-	495
02_Corridor 012		-	100	-	164
02_Corridor 013		-	111	-	151
02_Corridor 014		-	89	-	211
02_Corridor 015		-	81	-	496
02_Corridor 016		-	92	-	199
02_Corridor 017		-	90	-	212
02_Corridor 018		-	68	-	287

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
02_Corridor 019		-	99	-	209
02_Corridor 020		-	89	-	638
02_Corridor 021		-	71	-	295
02_Corridor 022		-	73	-	1089
02_Corridor 023		-	82	-	416
02_Corridor 024		-	88	-	643
02_Corridor 025		-	83	-	433
02_Corridor 026		-	105	-	129
02_Corridor 027		-	106	-	126
02_Corridor 028		-	138	-	49
02_D.B. 001		176	-	-	12
02_D.B. 002		176	-	-	13
02_D.B. 003		176	-	-	11
02_D.B. 004		176	-	-	11
02_D.B. 005		176	-	-	14
02_D.B. 006		176	-	-	13
02_D.B. 007		176	-	-	16
02_D.B. 008		176	-	-	16
02_D.B. 009		176	-	-	18
02_D.B. 010		176	-	-	19
02_D.B. 011		176	-	-	13
02_D.B. 012		176	-	-	24
02_D.B. 013		176	-	-	11
02_D.B. 014		176	-	-	22
02_D.B. 015		176	-	-	19
02_D.U. 001		106	-	-	70
02_D.U. 002		106	-	-	70
02_D.U. 003		109	-	-	68
02_D.U. 004		109	-	-	68
02_D.U. 005		119	-	-	56
02_D.U. 006		106	-	-	72
02_D.U. 007		108	-	-	70
02_D.U. 008		107	-	-	72
02_D.U. 009		100	-	-	81
02_D.U. 010		115	-	-	60
02_D.U. 011		111	-	-	68
02_D.U. 012		116	-	-	62
02_D.U. 013		101	-	-	78
02_D.U. 014		112	-	-	68
02_Decont Unit		-	58	-	332
02_Disposal 001		130	-	-	48
02_Disposal 002		108	-	-	87
02_Disposal 003		132	-	-	47

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
02_Disposal 004		152	-	-	38
02_Disposal 005		117	-	-	61
02_Disposal 006		123	-	-	56
02_Disposal 007		108	-	-	87
02_Elec. Cup 001		176	-	-	21
02_Elec. Cup 002		176	-	-	19
02_Elec. Cup 003		176	-	-	23
02_Elec. Cup 004		176	-	-	21
02_Elec. Cup 005		176	-	-	20
02_Elec. Cup 006		176	-	-	22
02_Elec. Cup 007		176	-	-	19
02_En-Suite Bariatric		-	111	-	40
02_Ensuite 001		-	131	-	27
02_Ensuite 002		-	131	-	28
02_Ensuite 003		-	131	-	28
02_Ensuite 004		-	131	-	28
02_Ensuite 005		-	131	-	28
02_Ensuite 006		-	131	-	28
02_Ensuite 007		-	131	-	27
02_Ensuite 008		-	131	-	28
02_Ensuite 009		-	129	-	31
02_Ensuite 010		-	131	-	27
02_Ensuite 011		-	131	-	27
02_Ensuite 012		-	131	-	27
02_Ensuite 013		-	131	-	27
02_Ensuite 014		-	131	-	55
02_Ensuite 015		-	112	-	41
02_Ensuite 016		-	131	-	28
02_Ensuite 017		-	131	-	28
02_Ensuite 018		-	131	-	28
02_Ensuite 019		-	114	-	40
02_Ensuite 020		-	131	-	27
02_Ensuite 021		-	116	-	39
02_Ensuite 022		-	113	-	41
02_Ensuite 023		-	131	-	28
02_Ensuite 024		-	131	-	30
02_Ensuite oncall room		-	73	-	179
02_Eq. Bay 001		167	-	-	8
02_Eq. Bay 002		167	-	-	7
02_Eq. Bay 003		167	-	-	5
02_Eq. Bay 004		167	-	-	5
02_Eq. Bay/Large 001		142	-	-	20
02_Eq. Bay/Large 002		149	-	-	18

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
02_Eq. Bay/Large 003		162	-	-	20
02_Eq. Bay/Large 004		167	-	-	15
02_Eq. Bay/Large 005		167	-	-	12
02_Eq. Bay/Large 006		167	-	-	11
02_Eq. Store		72	-	-	215
02_Exam/Physical Therapy		-	143	-	202
02_Family Room 001		127	-	-	121
02_Family Room 002		125	-	-	124
02_Gallery		-	101	-	107
02_Gas St. 001		167	-	-	28
02_Gas St. 002		167	-	-	28
02_Hot Automated Laboratory		76	-	-	1893
02_Inpatient hold 001		-	165	60	60
02_Inpatient hold 002		-	150	60	51
02_Inpatient hold 003		-	166	60	59
02_Inpatient hold 004		-	115	60	77
02_Inpatient hold 005		-	142	60	49
02_Interview 001		188	-	-	62
02_Interview 002		211	-	-	54
02_Interview 003		178	-	-	68
02_Interview 004		233	-	-	44
02_Iso Lobby 001		-	171	-	34
02_Iso Lobby 002		-	180	-	34
02_Iso Lobby 003		-	169	-	35
02_Iso Lobby 004		-	171	-	37
02_Iso Lobby 005		-	148	-	43
02_Iso Lobby 006		-	172	-	34
02_Iso Lobby 007		-	169	-	35
02_Iso Lobby 008		-	173	-	36
02_Iso Single Bedroom 001		-	151	-	93
02_Iso Single Bedroom 002		-	124	-	160
02_Iso Single Bedroom 003		-	151	-	92
02_Iso Single Bedroom 004		-	151	-	92
02_Iso Single Bedroom 005		-	123	-	163
02_Iso Single Bedroom 006		-	123	-	162
02_Iso Single Bedroom 007		-	124	-	162
02_Isolation Recovery Room (Stage 1) 001		-	171	-	121
02_Isolation Recovery Room (Stage 1) 002		-	148	-	122
02_IT HUB 001		282	-	-	77
02_IT HUB 002		289	-	-	73
02_IT HUB 003		304	-	-	66
02_IT HUB 004		276	-	-	82
02_IT HUB 005		276	-	-	82

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
02_IT HUB 006		295	-	-	69
02_IV Fluid Store		96	-	-	93
02_Linen 001		167	-	-	15
02_Linen 002		150	-	-	32
02_Linen 003		167	-	-	15
02_Lobby		-	150	-	61
02_Lockers		108	-	-	31
02_MDT Room 001		109	-	-	189
02_MDT Room 002		135	-	-	106
02_MDT Room 003		141	-	-	127
02_MDT Room 004		133	-	-	153
02_Med Store/Prep		113	-	-	200
02_Office 001		205	-	-	53
02_Office 002		200	-	-	55
02_Office 003		202	-	-	54
02_Office 004		188	-	-	61
02_Office 005		200	-	-	55
02_Office - 3 person		162	-	-	83
02_Office: 1 person + Microscope 003		182	-	-	95
02_Office Morphology		169	-	-	80
02_Office/Reception		-	197	60	84
02_Office: 1 person + Meeting Space + Microscope		153	-	-	137
02_Office: 1 person + Microscope 001		183	-	-	98
02_Office: 1 person + Microscope 002		183	-	-	98
02_Office: 2 staff		186	-	-	68
02_Office: 3 staff 001		176	-	-	73
02_Office: 3 staff 002		176	-	-	73
02_Office: 4 person		137	-	-	116
02_Office: 6 person		153	-	-	130
02_Office: Clinical Lead		161	-	-	119
02_Office: Manager		162	-	-	82
02_Office: Open Plan (Junior)		142	-	-	162
02_Open Plan Office & Consultants		121	-	-	467
02_Operating Room 001		-	122	-	851
02_Operating Room 002		-	122	-	849
02_Operating Room 003		-	123	-	819
02_Operating Room 004		-	122	-	843
02_Operating Room Large 001		-	118	-	988
02_Operating Room Large 002		-	118	-	955
02_Operating Room Large 003		-	118	-	966
02_Photocopier Room		245	-	-	34
02_PoCT 001		189	-	-	62
02_PoCT 002		181	-	-	69

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
02_PoCT 003		187	-	-	63
02_PoCT 004		182	-	-	68
02_Prep Room 001		-	194	-	100
02_Prep Room 002		-	194	-	97
02_Prep Room 003		-	191	-	102
02_Prep Room 004		-	197	-	96
02_Prep Room 005		-	195	-	96
02_Prep Room 006		-	196	-	98
02_Prep Room 007		-	194	-	100
02_Prep/Recovery (Stage 2) 001		-	192	-	95
02_Prep/Recovery (Stage 2) 002		-	196	-	92
02_Prep/Recovery (Stage 2) 003		-	192	-	99
02_Prep/Recovery (Stage 2) 004		-	192	-	99
02_Prep/Recovery (Stage 2) 005		-	194	-	97
02_Prep/Recovery (Stage 2) 006		-	202	-	87
02_Prep/Recovery (Stage 2) 007		-	192	-	99
02_Prep/Recovery (Stage 2) 008		-	192	-	99
02_Prep/Recovery (Stage 2) 009		-	192	-	99
02_Prep/Recovery (Stage 2) 010		-	194	-	97
02_Prep/Recovery (Stage 2) 011		-	192	-	95
02_Prep/Recovery (Stage 2) 012		-	192	-	99
02_Prep/Recovery (Stage 2) 013		-	194	-	97
02_Prep/Recovery (Stage 2) 014		-	190	-	97
02_Prep/Recovery (Stage 2) 015		-	194	-	94
02_Prep/Recovery (Stage 2) 016		-	192	-	99
02_Prep/Recovery (Stage 2) 017		-	187	-	103
02_Prep/Recovery (Stage 2) 018		-	191	-	100
02_Prep/Recovery (Stage 2) 019		-	163	-	102
02_Prep/Recovery (Stage 2) 020		-	166	-	98
02_Prep/Recovery (Stage 2) 021		-	192	-	95
02_Prep/Recovery (Stage 2) 022		-	192	-	95
02_Prep/Recovery (Stage 2) 023		-	196	-	92
02_Prep/Recovery (Stage 2) 024		-	192	-	95
02_Prep/Recovery (Stage 2) 025		-	189	-	102
02_Prep/Recovery (Stage 2) 026		-	196	-	95
02_Quiet Workspace 001		205	-	-	52
02_Quiet Workspace 002		208	-	-	56
02_Reception 001		-	126	60	90
02_Reception 002		-	123	60	133
02_Recovery (Stage 1) 001		-	148	-	122
02_Recovery (Stage 1) 002		-	148	-	122
02_Recovery (Stage 1) 003		-	148	-	122
02_Recovery (Stage 1) 004		-	148	-	122

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
02_Recovery (Stage 1) 005		-	149	-	120
02_Recovery (Stage 1) 006		-	149	-	120
02_Recovery (Stage 1) 007		-	151	-	124
02_Recovery (Stage 1) 008		-	148	-	122
02_Recovery (Stage 1) 009		-	149	-	120
02_Recovery (Stage 1) 010		-	148	-	121
02_Recovery (Stage 1) 011		-	149	-	119
02_Recovery (Stage 1) 012		-	171	-	121
02_Resus Bay 001		-	293	-	7
02_Resus Bay 002		-	293	-	7
02_Resus Bay 003		-	252	-	11
02_Resus Bay 004		-	244	-	12
02_Resus Bay 005		-	293	-	4
02_Resus Bay 006		-	293	-	4
02_Scrub 001		-	175	-	189
02_Scrub 002		-	213	-	168
02_Scrub 003		-	184	-	170
02_Scrub 004		-	210	-	174
02_Scrub 005		-	185	-	185
02_Scrub 006		-	188	-	170
02_Scrub 007		-	192	-	166
02_Seminar 001		-	140	-	144
02_Seminar 002		-	139	-	141
02_Seminar 003		-	153	-	107
02_Shared Admin (Combined)		96	-	-	547
02_Shower 001		-	131	-	17
02_Shower 002		-	131	-	18
02_Shower 003		-	131	-	18
02_Shower 004		-	131	-	17
02_Single Bedroom 001		-	157	-	100
02_Single Bedroom 002		-	97	-	132
02_Single Bedroom 003		-	155	-	103
02_Single Bedroom 004		-	155	-	103
02_Single Bedroom 005		-	126	-	147
02_Single Bedroom 006		-	153	-	107
02_Single Bedroom 007		-	154	-	104
02_Single Bedroom 008		-	154	-	104
02_Single Bedroom 009		-	110	-	131
02_Single Bedroom 010		-	154	-	104
02_Single Bedroom 011		-	127	-	146
02_Single Bedroom 012		-	127	-	145
02_Single Bedroom 013		-	155	-	103
02_Single Bedroom 014		-	109	-	131

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
02_Single Bedroom 015		-	109	-	132
02_Single Bedroom 016		-	97	-	131
02_Single Bedroom 017		-	126	-	147
02_Single Bedroom 018		-	126	-	148
02_Single Bedroom 019		-	151	-	106
02_Single Bedroom 020		-	126	-	148
02_Single Bedroom 021		-	97	-	132
02_Single Bedroom 022		-	156	-	101
02_Single Bedroom 023		-	155	-	103
02_Single Bedroom 024		-	157	-	100
02_Single Bedroom 025		-	97	-	132
02_Single Bedroom 026		-	156	-	102
02_Single Bedroom 027		-	159	-	100
02_Single Bedroom 028		-	126	-	147
02_Single Bedroom 029		-	111	-	131
02_Single Bedroom 030		-	157	-	100
02_Single Bedroom 031		-	157	-	100
02_Single Bedroom 032		-	126	-	147
02_Sluice		132	-	-	47
02_Staff Base 001		-	114	-	36
02_Staff Base 002		-	107	-	40
02_Staff Base 003		-	110	-	54
02_Staff Base 004		-	102	-	55
02_Staff Base 005		-	94	-	74
02_Staff Base 006		-	67	-	151
02_Staff Base 007		-	107	-	39
02_Staff Base 008		-	67	-	148
02_Staff Base 009		-	108	-	60
02_Staff Base 010		-	111	-	38
02_Staff Base 011		-	90	-	97
02_Staff Base 012		-	83	-	95
02_Staff Base 013		-	94	-	74
02_Staff Change 001		-	77	-	126
02_Staff Change 002		-	60	-	233
02_Staff Change 003		-	68	-	205
02_Staff Change 004		-	77	-	128
02_Staff Rest (Combined)		87	-	-	523
02_Staff Rest Room (Night)		-	135	-	64
02_Staff Rest/Bev 001		119	-	-	155
02_Staff Rest/Bev 002		107	-	-	149
02_Staff Rest/Bev 003		136	-	-	107
02_Staff Rest/Bev 004		118	-	-	158
02_Staff WC		-	134	-	31

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
02_Stage 2 Lounge		155	-	-	100
02_Stair A		-	69	-	154
02_Stair C 001		-	72	-	160
02_Stair C 002		-	71	-	162
02_Stair D		-	71	-	147
02_Sterile St Clean		98	-	-	63
02_Sterile St Dirty		97	-	-	65
02_Sterile St Supplies		69	-	-	181
02_Sterile St.		63	-	-	373
02_Store 001		167	-	-	24
02_Store 002		114	-	-	73
02_Store 003		94	-	-	111
02_Store 004		167	-	-	17
02_Store 005		121	-	-	73
02_Store 006		84	-	-	133
02_Store 007		108	-	-	94
02_Store 008		167	-	-	31
02_Store Change		111	-	-	98
02_Store: Furniture		95	-	-	96
02_Store: scrubs		135	-	-	48
02_Switchgear 001		176	-	-	18
02_Switchgear 002		176	-	-	34
02_Treatment (2-sided)		-	171	-	120
02_Unit Pantry 001		139	-	-	45
02_Unit Pantry 002		115	-	-	61
02_Unit Pantry 003		116	-	-	60
02_Unit Pantry 004		110	-	-	66
02_Unit Pantry 005		107	-	-	69
02_UPS 001		176	-	-	17
02_UPS 002		176	-	-	18
02_UPS 003		176	-	-	15
02_UPS 004		176	-	-	16
02_UPS 005		176	-	-	18
02_UPS 006		176	-	-	17
02_UPS 007		176	-	-	15
02_Visitor Lift Lobby 001		-	108	-	137
02_Visitor Lift Lobby 002		-	109	-	132
02_Visitor Lift Lobby 003		-	108	-	136
02_Wait 001		-	97	60	146
02_Wait 002		-	151	60	75
02_Waiting: 20 Places		-	82	60	320
02_WC 001		-	134	-	19
02_WC 002		-	134	-	31

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
02_WC 003		-	134	-	33
02_WC 004		-	134	-	19
02_WC 005		-	134	-	36
02_WC 006		-	134	-	24
02_WC 007		-	134	-	22
02_WC 008		-	134	-	23
02_WC 009		-	134	-	19
02_WC 010		-	134	-	24
02_WC 011		-	134	-	20
02_WC/Shower 001		-	134	-	29
02_WC/Shower 002		-	125	-	50
02_WC/Shower 003		-	134	-	31
02_WC/Shower 004		-	134	-	30
02_WC/Shower: A. Trolley		-	79	-	102
02_WC: Semi amb 001		-	134	-	21
02_WC: Semi amb 002		-	134	-	20
03_2 Bed Bay 001		-	94	-	269
03_2 Bed Bay 002		-	96	-	259
03_2 Bed Bay 003		-	97	-	253
03_4 Bed Bay 001		-	80	-	475
03_4 Bed Bay 002		-	82	-	477
03_4 Bed Bay 003		-	86	-	441
03_4 Bed Bay 004		-	83	-	474
03_4 Bed Bay 005		-	86	-	443
03_A. WC 001		-	134	-	37
03_A. WC 002		-	134	-	36
03_A. WC 003		-	134	-	34
03_A. WC 004		-	134	-	38
03_A. WC 005		-	134	-	43
03_A. WC 006		-	134	-	36
03_A. WC/Shower 001		-	129	-	64
03_A. WC/Shower 002		-	134	-	63
03_A. WC/Shower 003		-	131	-	63
03_A. WC/Shower 004		-	134	-	67
03_Baby feed/change 001		-	147	-	56
03_Baby feed/change 002		-	147	-	67
03_Bariatric Bedroom 001		-	178	-	103
03_Bariatric Bedroom 002		-	171	-	114
03_BED/FM Lift Lobby 001		-	108	-	186
03_BED/FM Lift Lobby 002		-	107	-	190
03_BED/FM Lift Lobby 003		-	108	-	187
03_BED/FM Lift Lobby 004		-	108	-	186
03_C.U. 001		110	-	-	99

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
03_C.U. 002		167	-	-	45
03_C.U. 003		167	-	-	48
03_C.U. 004		105	-	-	111
03_C.U. 005		167	-	-	50
03_C.U. 006		134	-	-	70
03_C.U./CSSD St.		139	-	-	70
03_C.U./Prep		116	-	-	140
03_Central Consumables St 001		125	-	-	80
03_Central Consumables St 002		108	-	-	103
03_Child Play 001		-	219	60	69
03_Child Play 002		-	219	60	123
03_Child Play 003		-	106	60	271
03_Circulation 001		-	121	-	95
03_Circulation 002		-	84	-	410
03_Circulation 003		-	94	-	297
03_Circulation 004		-	84	-	411
03_Circulation 005		-	90	-	546
03_Cleaners 001		167	-	-	28
03_Cleaners 002		167	-	-	33
03_Clinical Psychology Office		196	-	-	126
03_Consult/Exam 001		-	204	-	129
03_Consult/Exam 002		-	200	-	133
03_Consult/Exam 003		-	202	-	131
03_Consult/Exam 004		-	197	-	139
03_Consult/Exam 005		-	202	-	131
03_Consult/Exam 006		-	204	-	129
03_Consult/Exam (Larger)		-	177	-	168
03_Corridor 001		-	115	-	223
03_Corridor 002		-	104	-	633
03_Corridor 003		-	108	-	795
03_Corridor 004		-	103	-	637
03_Corridor 005		-	106	-	353
03_Corridor 006		-	123	-	197
03_Corridor 007		-	106	-	569
03_Corridor 008		-	131	-	118
03_Corridor 009		-	104	-	623
03_Corridor 010		-	98	-	374
03_Corridor 011		-	111	-	379
03_Corridor 012		-	125	-	193
03_Corridor 013		-	122	-	251
03_Corridor 014		-	123	-	261
03_Corridor 015		-	87	-	716
03_Corridor 016		-	109	-	132

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
03_Corridor 017		-	118	-	174
03_Corridor 018		-	107	-	427
03_Corridor 019		-	106	-	307
03_Corridor 020		-	129	-	110
03_Corridor 021		-	177	-	49
03_Corridor 022		-	96	-	732
03_Corridor 023		-	117	-	236
03_D.U. 001		130	-	-	72
03_D.U. 002		117	-	-	94
03_D.U. 003		147	-	-	61
03_D.U. 004		161	-	-	51
03_D.U. 005		167	-	-	46
03_D.U. 006		131	-	-	71
03_D.U. 007		143	-	-	63
03_D.U. 008		167	-	-	49
03_Disposal 001		167	-	-	48
03_Disposal 002		115	-	-	92
03_Disposal 003		167	-	-	48
03_Disposal 004		167	-	-	46
03_Educational Area 001		-	220	-	80
03_Educational Area 002		-	215	-	75
03_Elec. Cup. 001		176	-	-	18
03_Elec. Cup. 002		176	-	-	22
03_Elec. Cup. 003		176	-	-	12
03_Elec. Cup. 004		176	-	-	12
03_Elec. Cup. 005		176	-	-	12
03_Elec. Cup. 006		176	-	-	18
03_En-Suite Bariatric 001		-	131	-	43
03_En-Suite Bariatric 002		-	131	-	38
03_Ensuite 001		-	131	-	27
03_Ensuite 002		-	131	-	28
03_Ensuite 003		-	131	-	29
03_Ensuite 004		-	131	-	28
03_Ensuite 005		-	131	-	27
03_Ensuite 006		-	131	-	28
03_Ensuite 007		-	131	-	27
03_Ensuite 008		-	131	-	28
03_Ensuite 009		-	131	-	27
03_Ensuite 010		-	131	-	27
03_Ensuite 011		-	131	-	28
03_Ensuite 012		-	131	-	28
03_Ensuite 013		-	131	-	27
03_Ensuite 014		-	131	-	28

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
03_Ensuite 015		-	131	-	28
03_Ensuite 016		-	131	-	28
03_Ensuite 017		-	131	-	28
03_Ensuite 018		-	131	-	28
03_Ensuite 019		-	131	-	28
03_Ensuite 020		-	131	-	27
03_Ensuite 021		-	131	-	32
03_Ensuite 022		-	131	-	28
03_Ensuite 023		-	131	-	28
03_Ensuite 024		-	131	-	28
03_Ensuite 025		-	131	-	28
03_Ensuite 026		-	131	-	28
03_Ensuite 027		-	131	-	27
03_Ensuite 028		-	131	-	28
03_Ensuite 029		-	131	-	28
03_Ensuite 030		-	131	-	28
03_Ensuite 031		-	131	-	28
03_Ensuite 032		-	131	-	27
03_Ensuite 033		-	131	-	28
03_Ensuite 034		-	131	-	28
03_Ensuite 035		-	131	-	29
03_Ensuite 036		-	131	-	27
03_Ensuite 037		-	131	-	27
03_Ensuite 038		-	131	-	28
03_Ensuite 039		-	131	-	27
03_Ensuite 040		-	131	-	29
03_Ensuite 041		-	131	-	27
03_Ensuite 042		-	131	-	27
03_Ensuite 043		-	131	-	28
03_Ensuite 044		-	131	-	30
03_Ensuite 045		-	131	-	26
03_Ensuite 046		-	131	-	28
03_Ensuite 047		-	131	-	29
03_Ensuite 048		-	131	-	28
03_Ensuite 049		-	131	-	27
03_Ensuite 050		-	131	-	28
03_Ensuite 051		-	131	-	27
03_Ensuite 052		-	131	-	28
03_Ensuite 053		-	131	-	28
03_Ensuite 054		-	131	-	26
03_Ensuite 055		-	131	-	28
03_Ensuite 056		-	131	-	28
03_Ensuite 057		-	131	-	28

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
03_Ensuite 058		-	131	-	31
03_Ensuite 059		-	131	-	27
03_Ensuite 060		-	131	-	27
03_Ensuite 061		-	131	-	26
03_Ensuite 062		-	131	-	28
03_Ensuite 063		-	131	-	28
03_Ensuite 064		-	131	-	28
03_Ensuite 065		-	131	-	28
03_Ensuite 066		-	131	-	28
03_Ensuite 067		-	111	-	66
03_Ensuite 068		-	131	-	28
03_Ensuite 069		-	131	-	32
03_Ensuite 070		-	131	-	27
03_Ensuite 071		-	131	-	28
03_Ensuite 072		-	131	-	28
03_Ensuite 073		-	131	-	32
03_Eq. Bay 001		167	-	-	11
03_Eq. Bay 002		167	-	-	5
03_Eq. Bay 003		167	-	-	6
03_Eq. Bay 004		167	-	-	11
03_Eq. Store 001		145	-	-	67
03_Eq. Store 002		167	-	-	33
03_Eq. Store 003		126	-	-	103
03_Eq. Store 004		158	-	-	59
03_Eq. Store 005		167	-	-	40
03_Eq. Store 006		126	-	-	76
03_Eq. Store 007		148	-	-	69
03_Eq. Store 008		167	-	-	34
03_Eq. Store 009		167	-	-	33
03_HDU Lobby 001		-	188	-	46
03_HDU Lobby 002		-	188	-	44
03_HDU Lobby 003		-	188	-	45
03_HDU Lobby 004		-	188	-	46
03_Housekeeping 001		167	-	-	25
03_Housekeeping 002		167	-	-	19
03_Housekeeping 003		167	-	-	23
03_Interview 001		261	-	-	54
03_Interview 002		261	-	-	51
03_Interview 003		203	-	-	84
03_Interview 004		261	-	-	60
03_Interview 005		174	-	-	108
03_Iso Lobby 001		-	168	-	52
03_Iso Lobby 002		-	184	-	45

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
03_IT HUB 001		507	-	-	21
03_IT HUB 002		333	-	-	82
03_IT HUB 003		331	-	-	83
03_IT HUB 004		333	-	-	82
03_Larger Therapy Store		116	-	-	157
03_Linen 001		167	-	-	14
03_Linen 002		167	-	-	19
03_Linen 003		167	-	-	18
03_Linen 004		167	-	-	10
03_Lobby 001		-	149	-	77
03_Lobby 002		-	188	-	61
03_Lockers 001		167	-	-	33
03_Lockers 002		167	-	-	47
03_MDT Room 001		149	-	-	143
03_MDT Room 002		172	-	-	178
03_MDT Room 003		164	-	-	152
03_MDT Room 004		150	-	-	141
03_Meds Store/Prep 001		144	-	-	200
03_Meds Store/Prep 002		134	-	-	171
03_MEP PLANT		58	-	-	8643
03_Milk Kitchen		-	207	-	73
03_NPT Lab		223	-	-	89
03_Office 001		210	-	-	80
03_Office 002		252	-	-	57
03_Office 003		248	-	-	67
03_Office 004		255	-	-	39
03_Office: Open Plan 001		222	-	-	82
03_Office: Open Plan 002		237	-	-	84
03_On-Call+Ensuite 001		-	89	-	177
03_On-Call+Ensuite 002		-	94	-	181
03_On-Call+Ensuite 003		-	93	-	168
03_Oncology Waiting		-	185	60	130
03_Pantry/Kitchen 001		-	205	-	107
03_Pantry/Kitchen 002		-	155	-	174
03_Pantry/Kitchen 003		-	171	-	148
03_Patient Pods 001		-	202	-	159
03_Patient Pods 002		-	202	-	159
03_Patient Pods 003		-	201	-	161
03_Patient Pods 004		-	202	-	159
03_Patient Pods 005		-	199	-	165
03_Patient Pods 006		-	204	-	158
03_Patient Weigh/Assessment		-	293	-	55
03_Phebotomy Chair		-	151	-	175

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
03_Play		-	137	60	240
03_Quiet room		239	-	-	64
03_Quiet room/int		255	-	-	55
03_Reception		-	270	60	64
03_Resus Bay 001		-	293	-	6
03_Resus Bay 002		-	293	-	6
03_Resus Bay 003		-	293	-	3
03_Resus Bay 004		-	293	-	5
03_Seminar		-	169	-	134
03_SERVER ROOM		229	-	-	266
03_Shared Admin		142	-	-	200
03_Shared Day Space		146	-	-	138
03_Single Bedroom 001		-	190	-	102
03_Single Bedroom 002		-	198	-	96
03_Single Bedroom 003		-	189	-	103
03_Single Bedroom 004		-	191	-	101
03_Single Bedroom 005		-	192	-	100
03_Single Bedroom 006		-	189	-	103
03_Single Bedroom 007		-	191	-	101
03_Single Bedroom 008		-	188	-	103
03_Single Bedroom 009		-	192	-	101
03_Single Bedroom 010		-	191	-	103
03_Single Bedroom 011		-	192	-	102
03_Single Bedroom 012		-	189	-	103
03_Single Bedroom 013		-	189	-	103
03_Single Bedroom 014		-	190	-	103
03_Single Bedroom 015		-	195	-	98
03_Single Bedroom 016		-	189	-	103
03_Single Bedroom 017		-	195	-	98
03_Single Bedroom 018		-	188	-	104
03_Single Bedroom 019		-	169	-	114
03_Single Bedroom 020		-	189	-	103
03_Single Bedroom 021		-	189	-	103
03_Single Bedroom 022		-	190	-	102
03_Single Bedroom 023		-	191	-	101
03_Single Bedroom 024		-	188	-	104
03_Single Bedroom 025		-	275	-	13
03_Single Bedroom 026		-	190	-	102
03_Single Bedroom 027		-	275	-	13
03_Single Bedroom 028		-	190	-	102
03_Single Bedroom 029		-	188	-	103
03_Single Bedroom 030		-	192	-	101
03_Single Bedroom 031		-	191	-	101

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
03_Single Bedroom 032		-	193	-	100
03_Single Bedroom 033		-	190	-	102
03_Single Bedroom 034		-	191	-	101
03_Single Bedroom 035		-	189	-	103
03_Single Bedroom 036		-	185	-	106
03_Single Bedroom 037		-	190	-	102
03_Single Bedroom 038		-	187	-	105
03_Single Bedroom 039		-	189	-	103
03_Single Bedroom 040		-	191	-	101
03_Single Bedroom 041		-	191	-	101
03_Single Bedroom 042		-	196	-	97
03_Single Bedroom 043		-	190	-	102
03_Single Bedroom 044		-	196	-	97
03_Single Bedroom 045		-	190	-	102
03_Single Bedroom 046		-	189	-	103
03_Single Bedroom 047		-	189	-	102
03_Single Bedroom 048		-	190	-	102
03_Single Bedroom 049		-	189	-	103
03_Single Bedroom 050		-	191	-	101
03_Single Bedroom 051		-	190	-	102
03_Single Bedroom 052		-	190	-	102
03_Single Bedroom 053		-	194	-	98
03_Single Bedroom 054		-	191	-	102
03_Single Bedroom 055		-	189	-	103
03_Single Bedroom 056		-	190	-	102
03_Single Bedroom 057		-	185	-	106
03_Single Room 001		-	191	-	102
03_Single Room 002		-	188	-	103
03_Single Room 003		-	191	-	101
03_Single Room 004		-	182	-	107
03_Single Room 005		-	183	-	108
03_Single Room 006		-	189	-	104
03_Single room (HDU) 001		-	169	-	114
03_Single room (HDU) 002		-	169	-	114
03_Single room (HDU) 003		-	169	-	114
03_Social Space/Dining 001		-	324	-	35
03_Social Space/Dining 002		-	299	-	40
03_Staff Base 001		-	101	-	75
03_Staff Base 002		-	157	-	53
03_Staff Base 003		-	203	-	49
03_Staff Base 004		-	110	-	78
03_Staff Base 005		-	127	-	72
03_Staff Base 006		-	110	-	75

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
03_Staff Base with Pneumt Tube 001		-	124	-	74
03_Staff Base with Pneumt Tube 002		-	141	-	87
03_Staff Base with Pneumt Tube 003		-	130	-	72
03_Staff Base with Pneumt Tube 004		-	116	-	85
03_Staff Change (Female)		-	110	-	70
03_Staff Change (Male)		-	147	-	37
03_Staff Communal Changing Room 001		-	77	-	147
03_Staff Communal Changing Room 002		-	79	-	136
03_Staff Rest/Base		-	124	-	96
03_Staff Rest/Bev 001		140	-	-	150
03_Staff Rest/Bev 002		136	-	-	178
03_Stair A		-	80	-	154
03_Stair C 001		-	84	-	160
03_Stair C 002		-	83	-	162
03_Stair D		-	76	-	171
03_Store 001		167	-	-	27
03_Store 002		167	-	-	26
03_Store 003		141	-	-	69
03_Store 004		126	-	-	103
03_Therapy Store		167	-	-	49
03_Therapy Workbase		293	-	-	44
03_Treatment 001		-	195	-	139
03_Treatment 002		-	202	-	131
03_Treatment (2-sided) 001		-	209	-	122
03_Treatment (2-sided) 002		-	209	-	120
03_Treatment Chemo		-	201	-	133
03_Unit Pantry 001		133	-	-	70
03_Unit Pantry 002		124	-	-	78
03_Visitor Lift Lobby 001		-	134	-	132
03_Visitor Lift Lobby 002		-	132	-	136
03_Visitor Lift Lobby 003		-	133	-	137
03_Wait 001		-	219	60	65
03_Wait 002		-	94	60	189
03_Wait 003		-	219	60	77
03_Ward Managers Office 001		255	-	-	56
03_Ward Managers Office 002		255	-	-	56
03_WC 001		-	134	-	31
03_WC 002		-	134	-	29
03_WC 003		-	134	-	18
03_WC 004		-	134	-	23
03_WC 005		-	134	-	20
03_WC 006		-	134	-	21
03_WC 007		-	134	-	18

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
03_WC 008		-	134	-	14
03_WC 009		-	134	-	14
03_WC 010		-	134	-	19
03_WC 011		-	134	-	19
03_WC 012		-	134	-	21
03_WC 013		-	134	-	20
03_WC/Shower: A. Trolley 001		-	99	-	98
03_WC/Shower: A. Trolley 002		-	98	-	101
03_WC: Semi amb 001		-	134	-	21
03_WC: Semi amb 002		-	134	-	26
03_WC: Semi amb 003		-	134	-	21
03_WC: Semi amb 004		-	134	-	27
04_2-Bed Bay w cot 001		-	86	-	242
04_2-Bed Bay w cot 002		-	87	-	240
04_4-cot bay 001		-	73	-	560
04_4-cot bay 002		-	73	-	541
04_A. WC 001		-	125	-	45
04_A. WC 002		-	134	-	36
04_A. WC 003		-	134	-	30
04_A. WC 004		-	133	-	41
04_A. WC 005		-	130	-	43
04_A. WC 006		-	134	-	30
04_A. WC 007		-	134	-	37
04_A. WC 008		-	112	-	53
04_A. WC 009		-	134	-	39
04_A. WC 010		-	134	-	40
04_A. WC 011		-	126	-	45
04_A. WC 012		-	121	-	52
04_A. WC 013		-	134	-	34
04_A. WC 014		-	134	-	36
04_A. WC 015		-	134	-	37
04_A. WC/Shower		-	134	-	37
04_Admin/Staff Base		-	93	-	200
04_Anaesthetic Room 001		-	166	-	276
04_Anaesthetic Room 002		-	166	-	276
04_BED/FM Lift Lobby 001		-	91	-	190
04_BED/FM Lift Lobby 002		-	92	-	187
04_BED/FM Lift Lobby 003		-	92	-	186
04_BED/FM Lift Lobby 004		-	92	-	186
04_Bereavement: Labour 001		-	112	-	142
04_Bereavement: Labour 002		-	112	-	142
04_Bereavement: Neonates		-	123	-	144
04_Breast Feed		-	95	-	116

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_Breast Feed/Pump room		-	114	-	86
04_Buggy Park 001		167	-	-	8
04_Buggy Park 002		167	-	-	7
04_C.U. 001		91	-	-	104
04_C.U. 002		103	-	-	80
04_C.U. 003		92	-	-	98
04_C.U. 004		85	-	-	125
04_C.U. 005		93	-	-	94
04_C.U. 006		99	-	-	86
04_C.U. 007		98	-	-	85
04_C.U. 008		101	-	-	82
04_C/E 001		-	169	-	125
04_C/E 002		-	179	-	109
04_C/E 003		-	174	-	144
04_C/E 004		-	169	-	125
04_C/E 005		-	170	-	124
04_C/E 006		-	171	-	122
04_C/E 007		-	169	-	124
04_C/E 008		-	165	-	134
04_C/E 009		-	169	-	123
04_C/E 010		-	169	-	124
04_Circulation 001		-	84	-	326
04_Circulation 002		-	76	-	411
04_Circulation 003		-	101	-	95
04_Circulation 004		-	79	-	590
04_Circulation 005		-	90	-	144
04_Circulation 006		-	79	-	538
04_Circulation 007		-	76	-	410
04_Cleaners 001		138	-	-	32
04_Cleaners 002		135	-	-	35
04_Cleaners 003		128	-	-	38
04_Cleaners 004		134	-	-	35
04_Cleaners 005		126	-	-	41
04_Cold St.		164	-	-	43
04_Corridor 001		-	141	-	47
04_Corridor 002		-	89	-	207
04_Corridor 003		-	89	-	749
04_Corridor 004		-	85	-	714
04_Corridor 005		-	95	-	363
04_Corridor 006		-	99	-	226
04_Corridor 007		-	114	-	80
04_Corridor 008		-	101	-	108
04_Corridor 009		-	86	-	689

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_Corridor 010		-	100	-	195
04_Corridor 011		-	95	-	133
04_Corridor 012		-	91	-	431
04_Corridor 013		-	104	-	144
04_Corridor 014		-	84	-	1793
04_Corridor 015		-	105	-	178
04_Corridor 016		-	93	-	511
04_Corridor 017		-	115	-	81
04_Corridor 018		-	97	-	292
04_Corridor 019		-	99	-	215
04_Corridor 020		-	109	-	110
04_Corridor 021		-	103	-	147
04_Corridor 022		-	118	-	79
04_Corridor 023		-	109	-	119
04_Corridor 024		-	140	-	61
04_Corridor 025		-	88	-	1016
04_Corridor 026		-	112	-	114
04_Corridor 027		-	121	-	72
04_Corridor 028		-	80	-	478
04_Corridor 029		-	87	-	719
04_Cot Clean & Store		98	-	-	130
04_Cots: Single room 001		-	140	-	137
04_Cots: Single room 002		-	147	-	122
04_Cots: Single room 003		-	148	-	117
04_Cots: Single room 004		-	145	-	104
04_Cots: Single room 005		-	140	-	135
04_Cots: Single room 006		-	154	-	111
04_Cots: Single room 007		-	157	-	87
04_Cots: Single room 008		-	141	-	135
04_Cots: Single room 009		-	140	-	135
04_Cots: Single room 010		-	147	-	120
04_D.U. 001		110	-	-	65
04_D.U. 002		109	-	-	72
04_D.U. 003		109	-	-	72
04_D.U. 004		99	-	-	94
04_D.U. 005		109	-	-	68
04_D.U. 006		112	-	-	63
04_D.U. 007		116	-	-	68
04_D.U. 008		143	-	-	42
04_D.U. 009		93	-	-	100
04_Delivery Room 001		-	142	-	214
04_Delivery Room 002		-	139	-	228
04_Delivery Room 003		-	142	-	216

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_Delivery Room 004		-	139	-	230
04_Delivery Room 005		-	142	-	216
04_Delivery Room 006		-	142	-	216
04_Delivery: Large 001		-	142	-	230
04_Delivery: Large 002		-	138	-	237
04_Delivery: Large 003		-	138	-	237
04_Delivery: Large 004		-	136	-	247
04_Delivery: Large 005		-	136	-	247
04_Delivery: Large 006		-	142	-	228
04_Delivery: Large 007		-	137	-	239
04_Delivery: Large 008		-	138	-	233
04_Delivery: Large 009		-	138	-	237
04_Delivery: Large 010		-	138	-	233
04_Disposal 001		140	-	-	44
04_Disposal 002		134	-	-	49
04_Disposal 003		139	-	-	43
04_Disposal 004		146	-	-	40
04_Elec. Cup. 001		176	-	-	12
04_Elec. Cup. 002		176	-	-	21
04_Elec. Cup. 003		176	-	-	15
04_Elec. Cup. 004		176	-	-	12
04_Elec. Cup. 005		176	-	-	13
04_Elec. Cup. 006		176	-	-	13
04_Elec. Cup. 007		176	-	-	12
04_Elec. Cup. 008		176	-	-	16
04_Elec. Cup. 009		176	-	-	12
04_Elec. Cup. 010		176	-	-	12
04_Elec. Cup. 011		176	-	-	13
04_Elec. Cup. 012		176	-	-	13
04_Elec. Cup. 013		176	-	-	12
04_Elec. Cup. 014		176	-	-	13
04_Elec. Cup. 015		176	-	-	13
04_Elec. Cup. 016		176	-	-	13
04_Elec. Cup. 017		176	-	-	13
04_Ensuite 001		-	131	-	29
04_Ensuite 002		-	131	-	28
04_Ensuite 003		-	131	-	27
04_Ensuite 004		-	118	-	38
04_Ensuite 005		-	131	-	27
04_Ensuite 006		-	131	-	28
04_Ensuite 007		-	131	-	28
04_Ensuite 008		-	131	-	24
04_Ensuite 009		-	131	-	27

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_Ensuite 010		-	131	-	27
04_Ensuite 011		-	131	-	27
04_Ensuite 012		-	131	-	28
04_Ensuite 013		-	131	-	28
04_Ensuite 014		-	131	-	28
04_Ensuite 015		-	117	-	39
04_Ensuite 016		-	131	-	30
04_Ensuite 017		-	131	-	29
04_Ensuite 018		-	127	-	33
04_Ensuite 019		-	129	-	32
04_Ensuite 020		-	131	-	29
04_Ensuite 021		-	131	-	27
04_Ensuite 022		-	131	-	27
04_Ensuite 023		-	131	-	28
04_Ensuite 024		-	131	-	27
04_Ensuite 025		-	131	-	28
04_Ensuite 026		-	131	-	27
04_Ensuite 027		-	131	-	29
04_Ensuite 028		-	131	-	27
04_Ensuite 029		-	131	-	28
04_Ensuite 030		-	131	-	29
04_Ensuite 031		-	131	-	28
04_Ensuite 032		-	131	-	28
04_Ensuite 033		-	131	-	27
04_Ensuite 034		-	131	-	27
04_Ensuite 035		-	121	-	36
04_Ensuite 036		-	131	-	28
04_Ensuite 037		-	131	-	28
04_Ensuite 038		-	131	-	29
04_Ensuite 039		-	131	-	27
04_Ensuite 040		-	131	-	28
04_Ensuite 041		-	131	-	28
04_Ensuite 042		-	120	-	37
04_Ensuite 043		-	131	-	28
04_Ensuite 044		-	131	-	27
04_Ensuite 045		-	131	-	28
04_Ensuite 046		-	131	-	28
04_Ensuite 047		-	131	-	28
04_Ensuite 048		-	120	-	37
04_Ensuite 049		-	131	-	28
04_Ensuite 050		-	131	-	27
04_Ensuite 051		-	118	-	36
04_Ensuite 052		-	118	-	36

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_Ensuite 053		-	131	-	27
04_Ensuite 054		-	128	-	33
04_Ensuite 055		-	127	-	33
04_Ensuite 056		-	122	-	36
04_Ensuite 057		-	131	-	28
04_Ensuite 058		-	131	-	28
04_Ensuite 059		-	118	-	38
04_Ensuite 060		-	131	-	29
04_Ensuite 061		-	127	-	33
04_Ensuite 062		-	118	-	38
04_Ensuite 063		-	119	-	37
04_Ensuite 064		-	131	-	28
04_Ensuite 065		-	131	-	28
04_Ensuite 066		-	131	-	29
04_Ensuite 067		-	131	-	24
04_Ensuite 068		-	117	-	37
04_Ensuite 069		-	126	-	33
04_Ensuite 070		-	127	-	32
04_Ensuite 071		-	131	-	29
04_Ensuite 072		-	131	-	29
04_Ensuite 073		-	119	-	37
04_Ensuite 074		-	117	-	39
04_Ensuite 075		-	125	-	33
04_Ensuite 076		-	131	-	27
04_Eq. St/Consm		123	-	-	57
04_Eq. Store 001		167	-	-	25
04_Eq. Store 002		165	-	-	43
04_Eq. Store 003		167	-	-	25
04_Eq. Store 004		135	-	-	46
04_Eq. Store 005		107	-	-	69
04_Eq. Store 006		76	-	-	75
04_Eq. Store 007		152	-	-	46
04_Group Room		136	-	-	129
04_HDU Room		-	128	-	232
04_Hearing test room 001		-	162	-	138
04_Hearing test room 002		-	163	-	136
04_Interview/Quiet Room		173	-	-	72
04_Iso Lobby 001		-	152	-	40
04_Iso Lobby 002		-	154	-	39
04_Iso Lobby 003		-	174	-	25
04_Iso Lobby 004		-	180	-	31
04_IT HUB 001		276	-	-	82
04_IT HUB 002		276	-	-	82

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_IT HUB 003		274	-	-	83
04_Junior Doctor Office		171	-	-	115
04_Linen 001		167	-	-	23
04_Linen 002		167	-	-	18
04_Linen 003		167	-	-	23
04_Linen 004		167	-	-	21
04_Linen 005		136	-	-	33
04_Linen 006		155	-	-	27
04_Lobby		-	150	-	61
04_Milk Kitchen 001		-	145	-	74
04_Milk Kitchen 002		-	144	-	75
04_Office 001		171	-	-	82
04_Office 002		177	-	-	68
04_Office 003		179	-	-	77
04_Office 004		167	-	-	85
04_Office 005		183	-	-	70
04_Office 006		151	-	-	95
04_Office 007		191	-	-	64
04_Office 008		163	-	-	85
04_Office 009		180	-	-	71
04_Office 010		171	-	-	81
04_Office 011		163	-	-	79
04_Office 012		185	-	-	67
04_Office 013		150	-	-	100
04_Office 014		160	-	-	82
04_Office 015		167	-	-	76
04_Office 016		180	-	-	71
04_Office 017		165	-	-	87
04_Office - Manager		194	-	-	59
04_Office - reporting (4)		194	-	-	60
04_Office/Teams 001		118	-	-	204
04_Office/Teams 002		116	-	-	217
04_On-Call Room 001		-	171	-	52
04_On-Call Room 002		-	171	-	52
04_Parent's Kitchen/Dining Room		-	107	-	321
04_Parent's Lounge		107	-	-	189
04_Parents: ONS		122	-	-	168
04_Partners Change 001		-	147	-	26
04_Partners Change 002		-	147	-	27
04_PoCT 001		127	-	-	147
04_PoCT 002		182	-	-	68
04_PoCT 003		186	-	-	70
04_PoCT 004		223	-	-	44

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_Prep Room		-	188	-	104
04_Reception		-	134	60	179
04_Reception/Wait 001		-	127	60	227
04_Reception/Wait 002		-	270	60	48
04_Reception/Wait 003		-	136	60	201
04_Reception/Wait 004		-	115	60	239
04_Recovery (Stage 1) 001		-	99	-	118
04_Recovery (Stage 1) 002		-	118	-	122
04_Recovery (Stage 1) 003		-	118	-	122
04_Recovery (Stage 1) 004		-	99	-	118
04_Rooming-In		-	153	-	111
04_Seminar 001		-	140	-	140
04_Seminar 002		-	141	-	132
04_Seminar 003		-	141	-	133
04_Single bedroom AN 001		-	155	-	103
04_Single bedroom AN 002		-	156	-	102
04_Single bedroom AN 003		-	154	-	103
04_Single bedroom AN 004		-	157	-	101
04_Single bedroom AN 005		-	155	-	103
04_Single bedroom AN 006		-	156	-	101
04_Single bedroom AN 007		-	154	-	104
04_Single bedroom AN 008		-	155	-	103
04_Single bedroom AN 009		-	157	-	101
04_Single bedroom w cot 001		-	155	-	103
04_Single bedroom w cot 002		-	155	-	103
04_Single bedroom w cot 003		-	156	-	101
04_Single bedroom w cot 004		-	155	-	103
04_Single bedroom w cot 005		-	152	-	105
04_Single bedroom w cot 006		-	154	-	103
04_Single bedroom w cot 007		-	155	-	102
04_Single bedroom w cot 008		-	156	-	102
04_Single bedroom w cot 009		-	155	-	103
04_Single bedroom w cot 010		-	152	-	105
04_Single bedroom w cot 011		-	156	-	102
04_Single bedroom w cot 012		-	154	-	103
04_Single bedroom w cot 013		-	155	-	103
04_Single bedroom w cot 014		-	156	-	101
04_Single bedroom w cot 015		-	154	-	104
04_Single bedroom w cot 016		-	157	-	101
04_Single bedroom w cot 017		-	154	-	103
04_Single bedroom w cot 018		-	155	-	103
04_Single day space AN 001		-	150	-	92
04_Single day space AN 002		-	150	-	92

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_Single day space AN 003		-	149	-	93
04_Single day space AN 004		-	149	-	93
04_Single day space AN 005		-	150	-	92
04_Single day space AN 006		-	150	-	92
04_Skills Lab		-	132	-	287
04_Staff Base 001		-	84	-	93
04_Staff Base 002		-	83	-	90
04_Staff Base 003		-	87	-	76
04_Staff Base 004		-	103	-	45
04_Staff Base 005		-	203	-	21
04_Staff Base 006		-	126	-	37
04_Staff Base 007		-	82	-	102
04_Staff Base 008		-	203	-	36
04_Staff Base 009		-	70	-	105
04_Staff Base 010		-	70	-	104
04_Staff Change 001		-	65	-	156
04_Staff Change 002		-	75	-	121
04_Staff Change 003		-	95	-	63
04_Staff Change 004		-	69	-	129
04_Staff Change 005		-	67	-	142
04_Staff Change (Female)		-	68	-	146
04_Staff Change (Male)		-	97	-	56
04_Staff Office		175	-	-	70
04_Staff Rest/Bev 001		104	-	-	214
04_Staff Rest/Bev 002		120	-	-	141
04_Staff Rest/Bev 003		123	-	-	133
04_Staff Rest/Bev 004		118	-	-	227
04_Staff Rest/Bev 005		140	-	-	97
04_Staff Rest/Bev 006		124	-	-	149
04_Staff WC 001		-	134	-	21
04_Staff WC 002		-	134	-	39
04_Staff WC 003		-	134	-	20
04_Staff WC 004		-	134	-	21
04_Stair A		-	69	-	154
04_Stair C 001		-	71	-	162
04_Stair C 002		-	72	-	160
04_Stair D		-	68	-	159
04_Store 001		159	-	-	35
04_Store 002		156	-	-	46
04_Store 003		167	-	-	18
04_Store 004		167	-	-	16
04_Store 005		125	-	-	57
04_Store 006		98	-	-	63

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_Store 007		106	-	-	70
04_Store 008		98	-	-	84
04_Store 009		143	-	-	42
04_Store 010		144	-	-	42
04_Store 011		141	-	-	51
04_Store 012		94	-	-	67
04_Store 013		153	-	-	40
04_Store 014		167	-	-	27
04_Store 015		104	-	-	73
04_Store 016		142	-	-	42
04_Store 017		167	-	-	13
04_TCU Office		220	-	-	47
04_TCU/single room w cot 001		-	155	-	103
04_TCU/single room w cot 002		-	156	-	102
04_TCU/single room w cot 003		-	156	-	102
04_TCU/single room w cot 004		-	156	-	102
04_TCU/single room w cot 005		-	155	-	103
04_TCU/single room w cot 006		-	155	-	103
04_Theatre: C-section 001		-	121	-	826
04_Theatre: C-section 002		-	121	-	832
04_Treat: Procedures		-	194	-	92
04_Treatment (2-sided)		-	166	-	133
04_Treatment: Phleb/Vacc 001		-	293	-	47
04_Treatment: Phleb/Vacc 002		-	293	-	45
04_Treatment: Phleb/Vacc 003		-	271	-	61
04_Treatment: Phleb/Vacc 004		-	264	-	63
04_Triage 001		-	164	-	134
04_Triage 002		-	165	-	132
04_Triage 003		-	164	-	133
04_Triage 004		-	165	-	131
04_Triage 005		-	179	-	122
04_Ultrasound 001		-	154	-	281
04_Ultrasound 002		-	154	-	284
04_Ultrasound 003		-	154	-	284
04_Ultrasound 004		-	154	-	281
04_Ultrasound 005		-	154	-	284
04_Ultrasound 006		-	154	-	281
04_Unit Pantry 004		107	-	-	73
04_Unit Pantry 001		99	-	-	81
04_Unit Pantry 002		131	-	-	48
04_Unit Pantry 003		130	-	-	52
04_Visitor Lift Lobby 001		-	108	-	137
04_Visitor Lift Lobby 002		-	108	-	136

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_Visitor Lift Lobby 003		-	109	-	132
04_Waiting: 10 places 001		-	122	60	177
04_Waiting: 10 places 002		-	138	60	140
04_WC 001		-	134	-	20
04_WC 002		-	134	-	29
04_WC 003		-	134	-	28
04_WC 004		-	134	-	26
04_WC 005		-	134	-	20
04_WC 006		-	134	-	21
04_WC 007		-	134	-	26
04_WC 008		-	134	-	26
04_WC 009		-	134	-	28
04_WC 010		-	134	-	21
04_WC- nappy change		-	134	-	38
05_4-Bed Bay 001		-	78	-	443
05_4-Bed Bay 002		-	78	-	443
05_4-Bed Bay 003		-	76	-	476
05_4-Bed Bay 004		-	78	-	442
05_4-Bed Bay 005		-	78	-	443
05_4-Bed Bay 006		-	76	-	475
05_A. WC 001		-	130	-	42
05_A. WC 002		-	134	-	38
05_A. WC/Shower 001		-	101	-	63
05_A. WC/Shower 002		-	86	-	94
05_A. WC/Shower 003		-	101	-	63
05_A. WC/Shower 004		-	110	-	65
05_A. WC/Shower 005		-	110	-	65
05_A. WC/Shower 006		-	101	-	63
05_ARU Gym		-	118	-	238
05_Bariatric Bedroom 001		-	143	-	114
05_Bariatric Bedroom 002		-	143	-	114
05_Bariatric Bedroom 003		-	147	-	103
05_Bay: Wheelchair		-	188	-	9
05_BED/FM Lift Lobby 001		-	92	-	186
05_BED/FM Lift Lobby 002		-	92	-	186
05_BED/FM Lift Lobby 003		-	92	-	187
05_BED/FM Lift Lobby 004		-	91	-	190
05_C.U. 001		134	-	-	46
05_C.U. 002		133	-	-	48
05_C.U. 003		141	-	-	45
05_C.U. 004		134	-	-	46
05_C.U. 005		141	-	-	45
05_C.U. 006		129	-	-	50

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
05_Circulation 001		-	76	-	411
05_Circulation 002		-	84	-	320
05_Circulation 003		-	90	-	144
05_Circulation 004		-	80	-	597
05_Circulation 005		-	101	-	95
05_Circulation 006		-	76	-	410
05_Circulation 007		-	80	-	547
05_Cleaners 001		155	-	-	28
05_Cleaners 002		127	-	-	37
05_Cleaners 003		142	-	-	33
05_Corridor 001		-	88	-	353
05_Corridor 002		-	92	-	799
05_Corridor 003		-	98	-	264
05_Corridor 004		-	93	-	793
05_Corridor 005		-	102	-	232
05_Corridor 006		-	88	-	637
05_Corridor 007		-	89	-	349
05_Corridor 008		-	99	-	260
05_Corridor 009		-	89	-	323
05_Corridor 010		-	141	-	47
05_Corridor 011		-	89	-	307
05_Corridor 012		-	89	-	633
05_D.U. 001		106	-	-	71
05_D.U. 002		112	-	-	64
05_D.U. 003		105	-	-	71
05_D.U. 004		105	-	-	71
05_D.U. 005		107	-	-	70
05_D.U. 006		113	-	-	63
05_Disposal 001		132	-	-	47
05_Disposal 002		152	-	-	38
05_Disposal 003		131	-	-	48
05_Elec. Cup. 001		176	-	-	18
05_Elec. Cup. 002		176	-	-	18
05_Elec. Cup. 003		176	-	-	22
05_En-suite Bariatric 001		-	114	-	38
05_En-suite Bariatric 002		-	111	-	40
05_En-suite Bariatric 003		-	107	-	43
05_Ensuite 001		-	131	-	58
05_Ensuite 002		-	131	-	27
05_Ensuite 003		-	131	-	27
05_Ensuite 004		-	131	-	28
05_Ensuite 005		-	131	-	56
05_Ensuite 006		-	131	-	28

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
05_Ensuite 007		-	131	-	28
05_Ensuite 008		-	131	-	28
05_Ensuite 009		-	131	-	28
05_Ensuite 010		-	131	-	28
05_Ensuite 011		-	131	-	28
05_Ensuite 012		-	131	-	26
05_Ensuite 013		-	131	-	28
05_Ensuite 014		-	131	-	27
05_Ensuite 015		-	131	-	28
05_Ensuite 016		-	131	-	28
05_Ensuite 017		-	131	-	28
05_Ensuite 018		-	131	-	27
05_Ensuite 019		-	131	-	29
05_Ensuite 020		-	131	-	28
05_Ensuite 021		-	131	-	28
05_Ensuite 022		-	131	-	28
05_Ensuite 023		-	131	-	27
05_Ensuite 024		-	131	-	28
05_Ensuite 025		-	131	-	28
05_Ensuite 026		-	131	-	28
05_Ensuite 027		-	131	-	27
05_Ensuite 028		-	131	-	28
05_Ensuite 029		-	131	-	27
05_Ensuite 030		-	131	-	27
05_Ensuite 031		-	131	-	28
05_Ensuite 032		-	131	-	28
05_Ensuite 033		-	131	-	27
05_Ensuite 034		-	131	-	28
05_Ensuite 035		-	131	-	28
05_Ensuite 036		-	131	-	28
05_Ensuite 037		-	131	-	27
05_Ensuite 038		-	131	-	27
05_Ensuite 039		-	131	-	27
05_Ensuite 040		-	131	-	28
05_Ensuite 041		-	131	-	28
05_Ensuite 042		-	131	-	27
05_Ensuite 043		-	131	-	28
05_Ensuite 044		-	131	-	27
05_Ensuite 045		-	131	-	27
05_Ensuite 046		-	131	-	29
05_Ensuite 047		-	131	-	28
05_Ensuite 048		-	131	-	27
05_Ensuite 049		-	131	-	27

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
05_Ensuite 050		-	131	-	28
05_Ensuite 051		-	131	-	27
05_Ensuite 052		-	131	-	28
05_Ensuite 053		-	131	-	28
05_Ensuite 054		-	131	-	27
05_Ensuite 055		-	131	-	28
05_Ensuite 056		-	131	-	28
05_Ensuite 057		-	131	-	28
05_Eq. Bay 001		167	-	-	6
05_Eq. Bay 002		167	-	-	6
05_Eq. Bay 003		163	-	-	6
05_Eq. Bay 004		167	-	-	6
05_Eq. Bay 005		167	-	-	11
05_Eq. Store 001		114	-	-	66
05_Eq. Store 002		167	-	-	26
05_Eq. Store 003		102	-	-	101
05_Interview 001		210	-	-	51
05_Interview 002		190	-	-	73
05_Interview 003		206	-	-	60
05_Interview 004		210	-	-	51
05_Interview 005		211	-	-	54
05_Interview 006		177	-	-	69
05_Iso Lobby 001		-	132	-	52
05_Iso Lobby 002		-	142	-	45
05_Iso Lobby 003		-	128	-	55
05_IT HUB 001		285	-	-	76
05_IT HUB 002		285	-	-	75
05_IT HUB 003		285	-	-	75
05_IT HUB 004		276	-	-	82
05_IT HUB 005		282	-	-	77
05_Linen 001		167	-	-	8
05_Linen 002		167	-	-	18
05_Linen 003		167	-	-	19
05_Linen 004		156	-	-	31
05_Linen 005		167	-	-	19
05_Lobby 001		-	128	-	120
05_Lobby 002		-	137	-	76
05_Lobby 003		-	132	-	106
05_Lobby 004		-	150	-	61
05_Lobby 005		-	127	-	79
05_Lockers 001		110	-	-	46
05_Lockers 002		109	-	-	47
05_Lockers 003		100	-	-	33

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
05_MDT Room 001		111	-	-	188
05_MDT Room 002		131	-	-	132
05_MDT Room 003		123	-	-	143
05_MDT Room 004		129	-	-	203
05_MDT Room 005		133	-	-	152
05_MDT Room 006		139	-	-	178
05_Meds Store/Prep 001		107	-	-	171
05_Meds Store/Prep 002		106	-	-	173
05_Meds Store/Prep 003		113	-	-	200
05_Meeting Room		106	-	-	238
05_MEP PLANT		58	-	-	14364
05_Office 001		195	-	-	57
05_Office 002		162	-	-	83
05_Office 003		255	-	-	28
05_OT Office: 6 Workstations		140	-	-	159
05_Physio office: 6 workstations		168	-	-	93
05_Resus Bay 001		-	293	-	4
05_Resus Bay 002		-	293	-	4
05_Resus Bay 003		-	293	-	4
05_Resus Bay 004		-	293	-	4
05_Resus Bay 005		-	293	-	6
05_Shared Admin 001		117	-	-	195
05_Shared Admin 002		122	-	-	253
05_Shared Day Space		129	-	-	124
05_Single Bedroom 001		-	154	-	104
05_Single Bedroom 002		-	155	-	103
05_Single Bedroom 003		-	155	-	103
05_Single Bedroom 004		-	154	-	103
05_Single Bedroom 005		-	151	-	107
05_Single Bedroom 006		-	151	-	108
05_Single Bedroom 007		-	155	-	103
05_Single Bedroom 008		-	156	-	102
05_Single Bedroom 009		-	157	-	101
05_Single Bedroom 010		-	156	-	102
05_Single Bedroom 011		-	154	-	103
05_Single Bedroom 012		-	155	-	103
05_Single Bedroom 013		-	157	-	101
05_Single Bedroom 014		-	156	-	101
05_Single Bedroom 015		-	155	-	103
05_Single Bedroom 016		-	156	-	101
05_Single Bedroom 017		-	156	-	102
05_Single Bedroom 018		-	156	-	102
05_Single Bedroom 019		-	155	-	103

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
05_Single Bedroom 020		-	155	-	102
05_Single Bedroom 021		-	154	-	104
05_Single Bedroom 022		-	156	-	102
05_Single Bedroom 023		-	156	-	101
05_Single Bedroom 024		-	155	-	103
05_Single Bedroom 025		-	157	-	100
05_Single Bedroom 026		-	155	-	103
05_Single Bedroom 027		-	156	-	102
05_Single Bedroom 028		-	155	-	104
05_Single Bedroom 029		-	154	-	103
05_Single Bedroom 030		-	156	-	102
05_Single Bedroom 031		-	154	-	104
05_Single Bedroom 032		-	157	-	101
05_Single Bedroom 033		-	156	-	102
05_Single Bedroom 034		-	155	-	104
05_Single Bedroom 035		-	155	-	103
05_Single Bedroom 036		-	156	-	102
05_Single Bedroom 037		-	157	-	101
05_Single Bedroom 038		-	156	-	102
05_Single Bedroom 039		-	155	-	102
05_Single Bedroom 040		-	156	-	103
05_Single Bedroom 041		-	155	-	103
05_Single Bedroom 042		-	155	-	103
05_Single Bedroom 043		-	157	-	100
05_Single Bedroom 044		-	155	-	103
05_Single Bedroom 045		-	156	-	102
05_Single Bedroom 046		-	157	-	102
05_Single Bedroom 047		-	156	-	101
05_Single Bedroom 048		-	156	-	103
05_Single Bedroom 049		-	156	-	101
05_Single Bedroom 050		-	154	-	103
05_Single Bedroom 051		-	156	-	102
05_Single Bedroom 052		-	156	-	102
05_Single Bedroom 053		-	156	-	101
05_Single Bedroom 054		-	155	-	103
05_Single Bedroom 055		-	156	-	102
05_Single Bedroom 056		-	156	-	102
05_Single Bedroom 057		-	155	-	103
05_Staff Base 001		-	71	-	77
05_Staff Base 002		-	86	-	79
05_Staff Base 003		-	203	-	6
05_Staff Base 004		-	71	-	76
05_Staff Base 005		-	88	-	72