

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
02_PoCT 003		187	-	-	63
02_PoCT 004		182	-	-	68
02_Prep Room 001		-	194	-	100
02_Prep Room 002		-	194	-	97
02_Prep Room 003		-	191	-	102
02_Prep Room 004		-	197	-	96
02_Prep Room 005		-	195	-	96
02_Prep Room 006		-	196	-	98
02_Prep Room 007		-	194	-	100
02_Prep/Recovery (Stage 2) 001		-	192	-	95
02_Prep/Recovery (Stage 2) 002		-	196	-	92
02_Prep/Recovery (Stage 2) 003		-	192	-	99
02_Prep/Recovery (Stage 2) 004		-	192	-	99
02_Prep/Recovery (Stage 2) 005		-	194	-	97
02_Prep/Recovery (Stage 2) 006		-	202	-	87
02_Prep/Recovery (Stage 2) 007		-	192	-	99
02_Prep/Recovery (Stage 2) 008		-	192	-	99
02_Prep/Recovery (Stage 2) 009		-	192	-	99
02_Prep/Recovery (Stage 2) 010		-	194	-	97
02_Prep/Recovery (Stage 2) 011		-	192	-	95
02_Prep/Recovery (Stage 2) 012		-	192	-	99
02_Prep/Recovery (Stage 2) 013		-	194	-	97
02_Prep/Recovery (Stage 2) 014		-	190	-	97
02_Prep/Recovery (Stage 2) 015		-	194	-	94
02_Prep/Recovery (Stage 2) 016		-	192	-	99
02_Prep/Recovery (Stage 2) 017		-	187	-	103
02_Prep/Recovery (Stage 2) 018		-	191	-	100
02_Prep/Recovery (Stage 2) 019		-	163	-	102
02_Prep/Recovery (Stage 2) 020		-	166	-	98
02_Prep/Recovery (Stage 2) 021		-	192	-	95
02_Prep/Recovery (Stage 2) 022		-	192	-	95
02_Prep/Recovery (Stage 2) 023		-	196	-	92
02_Prep/Recovery (Stage 2) 024		-	192	-	95
02_Prep/Recovery (Stage 2) 025		-	189	-	102
02_Prep/Recovery (Stage 2) 026		-	196	-	95
02_Quiet Workspace 001		205	-	-	52
02_Quiet Workspace 002		208	-	-	56
02_Reception 001		-	126	60	90
02_Reception 002		-	123	60	133
02_Recovery (Stage 1) 001		-	148	-	122
02_Recovery (Stage 1) 002		-	148	-	122
02_Recovery (Stage 1) 003		-	148	-	122
02_Recovery (Stage 1) 004		-	148	-	122

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
02_Recovery (Stage 1) 005		-	149	-	120
02_Recovery (Stage 1) 006		-	149	-	120
02_Recovery (Stage 1) 007		-	151	-	124
02_Recovery (Stage 1) 008		-	148	-	122
02_Recovery (Stage 1) 009		-	149	-	120
02_Recovery (Stage 1) 010		-	148	-	121
02_Recovery (Stage 1) 011		-	149	-	119
02_Recovery (Stage 1) 012		-	171	-	121
02_Resus Bay 001		-	293	-	7
02_Resus Bay 002		-	293	-	7
02_Resus Bay 003		-	252	-	11
02_Resus Bay 004		-	244	-	12
02_Resus Bay 005		-	293	-	4
02_Resus Bay 006		-	293	-	4
02_Scrub 001		-	175	-	189
02_Scrub 002		-	213	-	168
02_Scrub 003		-	184	-	170
02_Scrub 004		-	210	-	174
02_Scrub 005		-	185	-	185
02_Scrub 006		-	188	-	170
02_Scrub 007		-	192	-	166
02_Seminar 001		-	140	-	144
02_Seminar 002		-	139	-	141
02_Seminar 003		-	153	-	107
02_Shared Admin (Combined)		96	-	-	547
02_Shower 001		-	131	-	17
02_Shower 002		-	131	-	18
02_Shower 003		-	131	-	18
02_Shower 004		-	131	-	17
02_Single Bedroom 001		-	157	-	100
02_Single Bedroom 002		-	97	-	132
02_Single Bedroom 003		-	155	-	103
02_Single Bedroom 004		-	155	-	103
02_Single Bedroom 005		-	126	-	147
02_Single Bedroom 006		-	153	-	107
02_Single Bedroom 007		-	154	-	104
02_Single Bedroom 008		-	154	-	104
02_Single Bedroom 009		-	110	-	131
02_Single Bedroom 010		-	154	-	104
02_Single Bedroom 011		-	127	-	146
02_Single Bedroom 012		-	127	-	145
02_Single Bedroom 013		-	155	-	103
02_Single Bedroom 014		-	109	-	131

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
02_Single Bedroom 015		-	109	-	132
02_Single Bedroom 016		-	97	-	131
02_Single Bedroom 017		-	126	-	147
02_Single Bedroom 018		-	126	-	148
02_Single Bedroom 019		-	151	-	106
02_Single Bedroom 020		-	126	-	148
02_Single Bedroom 021		-	97	-	132
02_Single Bedroom 022		-	156	-	101
02_Single Bedroom 023		-	155	-	103
02_Single Bedroom 024		-	157	-	100
02_Single Bedroom 025		-	97	-	132
02_Single Bedroom 026		-	156	-	102
02_Single Bedroom 027		-	159	-	100
02_Single Bedroom 028		-	126	-	147
02_Single Bedroom 029		-	111	-	131
02_Single Bedroom 030		-	157	-	100
02_Single Bedroom 031		-	157	-	100
02_Single Bedroom 032		-	126	-	147
02_Sluice		132	-	-	47
02_Staff Base 001		-	114	-	36
02_Staff Base 002		-	107	-	40
02_Staff Base 003		-	110	-	54
02_Staff Base 004		-	102	-	55
02_Staff Base 005		-	94	-	74
02_Staff Base 006		-	67	-	151
02_Staff Base 007		-	107	-	39
02_Staff Base 008		-	67	-	148
02_Staff Base 009		-	108	-	60
02_Staff Base 010		-	111	-	38
02_Staff Base 011		-	90	-	97
02_Staff Base 012		-	83	-	95
02_Staff Base 013		-	94	-	74
02_Staff Change 001		-	77	-	126
02_Staff Change 002		-	60	-	233
02_Staff Change 003		-	68	-	205
02_Staff Change 004		-	77	-	128
02_Staff Rest (Combined)		87	-	-	523
02_Staff Rest Room (Night)		-	135	-	64
02_Staff Rest/Bev 001		119	-	-	155
02_Staff Rest/Bev 002		107	-	-	149
02_Staff Rest/Bev 003		136	-	-	107
02_Staff Rest/Bev 004		118	-	-	158
02_Staff WC		-	134	-	31

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
02_Stage 2 Lounge		155	-	-	100
02_Stair A		-	69	-	154
02_Stair C 001		-	72	-	160
02_Stair C 002		-	71	-	162
02_Stair D		-	71	-	147
02_Sterile St Clean		98	-	-	63
02_Sterile St Dirty		97	-	-	65
02_Sterile St Supplies		69	-	-	181
02_Sterile St.		63	-	-	373
02_Store 001		167	-	-	24
02_Store 002		114	-	-	73
02_Store 003		94	-	-	111
02_Store 004		167	-	-	17
02_Store 005		121	-	-	73
02_Store 006		84	-	-	133
02_Store 007		108	-	-	94
02_Store 008		167	-	-	31
02_Store Change		111	-	-	98
02_Store: Furniture		95	-	-	96
02_Store: scrubs		135	-	-	48
02_Switchgear 001		176	-	-	18
02_Switchgear 002		176	-	-	34
02_Treatment (2-sided)		-	171	-	120
02_Unit Pantry 001		139	-	-	45
02_Unit Pantry 002		115	-	-	61
02_Unit Pantry 003		116	-	-	60
02_Unit Pantry 004		110	-	-	66
02_Unit Pantry 005		107	-	-	69
02_UPS 001		176	-	-	17
02_UPS 002		176	-	-	18
02_UPS 003		176	-	-	15
02_UPS 004		176	-	-	16
02_UPS 005		176	-	-	18
02_UPS 006		176	-	-	17
02_UPS 007		176	-	-	15
02_Visitor Lift Lobby 001		-	108	-	137
02_Visitor Lift Lobby 002		-	109	-	132
02_Visitor Lift Lobby 003		-	108	-	136
02_Wait 001		-	97	60	146
02_Wait 002		-	151	60	75
02_Waiting: 20 Places		-	82	60	320
02_WC 001		-	134	-	19
02_WC 002		-	134	-	31

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
02_WC 003		-	134	-	33
02_WC 004		-	134	-	19
02_WC 005		-	134	-	36
02_WC 006		-	134	-	24
02_WC 007		-	134	-	22
02_WC 008		-	134	-	23
02_WC 009		-	134	-	19
02_WC 010		-	134	-	24
02_WC 011		-	134	-	20
02_WC/Shower 001		-	134	-	29
02_WC/Shower 002		-	125	-	50
02_WC/Shower 003		-	134	-	31
02_WC/Shower 004		-	134	-	30
02_WC/Shower: A. Trolley		-	79	-	102
02_WC: Semi amb 001		-	134	-	21
02_WC: Semi amb 002		-	134	-	20
03_2 Bed Bay 001		-	94	-	269
03_2 Bed Bay 002		-	96	-	259
03_2 Bed Bay 003		-	97	-	253
03_4 Bed Bay 001		-	80	-	475
03_4 Bed Bay 002		-	82	-	477
03_4 Bed Bay 003		-	86	-	441
03_4 Bed Bay 004		-	83	-	474
03_4 Bed Bay 005		-	86	-	443
03_A. WC 001		-	134	-	37
03_A. WC 002		-	134	-	36
03_A. WC 003		-	134	-	34
03_A. WC 004		-	134	-	38
03_A. WC 005		-	134	-	43
03_A. WC 006		-	134	-	36
03_A. WC/Shower 001		-	129	-	64
03_A. WC/Shower 002		-	134	-	63
03_A. WC/Shower 003		-	131	-	63
03_A. WC/Shower 004		-	134	-	67
03_Baby feed/change 001		-	147	-	56
03_Baby feed/change 002		-	147	-	67
03_Bariatric Bedroom 001		-	178	-	103
03_Bariatric Bedroom 002		-	171	-	114
03_BED/FM Lift Lobby 001		-	108	-	186
03_BED/FM Lift Lobby 002		-	107	-	190
03_BED/FM Lift Lobby 003		-	108	-	187
03_BED/FM Lift Lobby 004		-	108	-	186
03_C.U. 001		110	-	-	99

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
03_C.U. 002		167	-	-	45
03_C.U. 003		167	-	-	48
03_C.U. 004		105	-	-	111
03_C.U. 005		167	-	-	50
03_C.U. 006		134	-	-	70
03_C.U./CSSD St.		139	-	-	70
03_C.U./Prep		116	-	-	140
03_Central Consumables St 001		125	-	-	80
03_Central Consumables St 002		108	-	-	103
03_Child Play 001		-	219	60	69
03_Child Play 002		-	219	60	123
03_Child Play 003		-	106	60	271
03_Circulation 001		-	121	-	95
03_Circulation 002		-	84	-	410
03_Circulation 003		-	94	-	297
03_Circulation 004		-	84	-	411
03_Circulation 005		-	90	-	546
03_Cleaners 001		167	-	-	28
03_Cleaners 002		167	-	-	33
03_Clinical Psychology Office		196	-	-	126
03_Consult/Exam 001		-	204	-	129
03_Consult/Exam 002		-	200	-	133
03_Consult/Exam 003		-	202	-	131
03_Consult/Exam 004		-	197	-	139
03_Consult/Exam 005		-	202	-	131
03_Consult/Exam 006		-	204	-	129
03_Consult/Exam (Larger)		-	177	-	168
03_Corridor 001		-	115	-	223
03_Corridor 002		-	104	-	633
03_Corridor 003		-	108	-	795
03_Corridor 004		-	103	-	637
03_Corridor 005		-	106	-	353
03_Corridor 006		-	123	-	197
03_Corridor 007		-	106	-	569
03_Corridor 008		-	131	-	118
03_Corridor 009		-	104	-	623
03_Corridor 010		-	98	-	374
03_Corridor 011		-	111	-	379
03_Corridor 012		-	125	-	193
03_Corridor 013		-	122	-	251
03_Corridor 014		-	123	-	261
03_Corridor 015		-	87	-	716
03_Corridor 016		-	109	-	132

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
03_Corridor 017		-	118	-	174
03_Corridor 018		-	107	-	427
03_Corridor 019		-	106	-	307
03_Corridor 020		-	129	-	110
03_Corridor 021		-	177	-	49
03_Corridor 022		-	96	-	732
03_Corridor 023		-	117	-	236
03_D.U. 001		130	-	-	72
03_D.U. 002		117	-	-	94
03_D.U. 003		147	-	-	61
03_D.U. 004		161	-	-	51
03_D.U. 005		167	-	-	46
03_D.U. 006		131	-	-	71
03_D.U. 007		143	-	-	63
03_D.U. 008		167	-	-	49
03_Disposal 001		167	-	-	48
03_Disposal 002		115	-	-	92
03_Disposal 003		167	-	-	48
03_Disposal 004		167	-	-	46
03_Educational Area 001		-	220	-	80
03_Educational Area 002		-	215	-	75
03_Elec. Cup. 001		176	-	-	18
03_Elec. Cup. 002		176	-	-	22
03_Elec. Cup. 003		176	-	-	12
03_Elec. Cup. 004		176	-	-	12
03_Elec. Cup. 005		176	-	-	12
03_Elec. Cup. 006		176	-	-	18
03_En-Suite Bariatric 001		-	131	-	43
03_En-Suite Bariatric 002		-	131	-	38
03_Ensuite 001		-	131	-	27
03_Ensuite 002		-	131	-	28
03_Ensuite 003		-	131	-	29
03_Ensuite 004		-	131	-	28
03_Ensuite 005		-	131	-	27
03_Ensuite 006		-	131	-	28
03_Ensuite 007		-	131	-	27
03_Ensuite 008		-	131	-	28
03_Ensuite 009		-	131	-	27
03_Ensuite 010		-	131	-	27
03_Ensuite 011		-	131	-	28
03_Ensuite 012		-	131	-	28
03_Ensuite 013		-	131	-	27
03_Ensuite 014		-	131	-	28

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
03_Ensuite 015		-	131	-	28
03_Ensuite 016		-	131	-	28
03_Ensuite 017		-	131	-	28
03_Ensuite 018		-	131	-	28
03_Ensuite 019		-	131	-	28
03_Ensuite 020		-	131	-	27
03_Ensuite 021		-	131	-	32
03_Ensuite 022		-	131	-	28
03_Ensuite 023		-	131	-	28
03_Ensuite 024		-	131	-	28
03_Ensuite 025		-	131	-	28
03_Ensuite 026		-	131	-	28
03_Ensuite 027		-	131	-	27
03_Ensuite 028		-	131	-	28
03_Ensuite 029		-	131	-	28
03_Ensuite 030		-	131	-	28
03_Ensuite 031		-	131	-	28
03_Ensuite 032		-	131	-	27
03_Ensuite 033		-	131	-	28
03_Ensuite 034		-	131	-	28
03_Ensuite 035		-	131	-	29
03_Ensuite 036		-	131	-	27
03_Ensuite 037		-	131	-	27
03_Ensuite 038		-	131	-	28
03_Ensuite 039		-	131	-	27
03_Ensuite 040		-	131	-	29
03_Ensuite 041		-	131	-	27
03_Ensuite 042		-	131	-	27
03_Ensuite 043		-	131	-	28
03_Ensuite 044		-	131	-	30
03_Ensuite 045		-	131	-	26
03_Ensuite 046		-	131	-	28
03_Ensuite 047		-	131	-	29
03_Ensuite 048		-	131	-	28
03_Ensuite 049		-	131	-	27
03_Ensuite 050		-	131	-	28
03_Ensuite 051		-	131	-	27
03_Ensuite 052		-	131	-	28
03_Ensuite 053		-	131	-	28
03_Ensuite 054		-	131	-	26
03_Ensuite 055		-	131	-	28
03_Ensuite 056		-	131	-	28
03_Ensuite 057		-	131	-	28

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
03_Ensuite 058		-	131	-	31
03_Ensuite 059		-	131	-	27
03_Ensuite 060		-	131	-	27
03_Ensuite 061		-	131	-	26
03_Ensuite 062		-	131	-	28
03_Ensuite 063		-	131	-	28
03_Ensuite 064		-	131	-	28
03_Ensuite 065		-	131	-	28
03_Ensuite 066		-	131	-	28
03_Ensuite 067		-	111	-	66
03_Ensuite 068		-	131	-	28
03_Ensuite 069		-	131	-	32
03_Ensuite 070		-	131	-	27
03_Ensuite 071		-	131	-	28
03_Ensuite 072		-	131	-	28
03_Ensuite 073		-	131	-	32
03_Eq. Bay 001		167	-	-	11
03_Eq. Bay 002		167	-	-	5
03_Eq. Bay 003		167	-	-	6
03_Eq. Bay 004		167	-	-	11
03_Eq. Store 001		145	-	-	67
03_Eq. Store 002		167	-	-	33
03_Eq. Store 003		126	-	-	103
03_Eq. Store 004		158	-	-	59
03_Eq. Store 005		167	-	-	40
03_Eq. Store 006		126	-	-	76
03_Eq. Store 007		148	-	-	69
03_Eq. Store 008		167	-	-	34
03_Eq. Store 009		167	-	-	33
03_HDU Lobby 001		-	188	-	46
03_HDU Lobby 002		-	188	-	44
03_HDU Lobby 003		-	188	-	45
03_HDU Lobby 004		-	188	-	46
03_Housekeeping 001		167	-	-	25
03_Housekeeping 002		167	-	-	19
03_Housekeeping 003		167	-	-	23
03_Interview 001		261	-	-	54
03_Interview 002		261	-	-	51
03_Interview 003		203	-	-	84
03_Interview 004		261	-	-	60
03_Interview 005		174	-	-	108
03_Iso Lobby 001		-	168	-	52
03_Iso Lobby 002		-	184	-	45

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
03_IT HUB 001		507	-	-	21
03_IT HUB 002		333	-	-	82
03_IT HUB 003		331	-	-	83
03_IT HUB 004		333	-	-	82
03_Larger Therapy Store		116	-	-	157
03_Linen 001		167	-	-	14
03_Linen 002		167	-	-	19
03_Linen 003		167	-	-	18
03_Linen 004		167	-	-	10
03_Lobby 001		-	149	-	77
03_Lobby 002		-	188	-	61
03_Lockers 001		167	-	-	33
03_Lockers 002		167	-	-	47
03_MDT Room 001		149	-	-	143
03_MDT Room 002		172	-	-	178
03_MDT Room 003		164	-	-	152
03_MDT Room 004		150	-	-	141
03_Meds Store/Prep 001		144	-	-	200
03_Meds Store/Prep 002		134	-	-	171
03_MEP PLANT		58	-	-	8643
03_Milk Kitchen		-	207	-	73
03_NPT Lab		223	-	-	89
03_Office 001		210	-	-	80
03_Office 002		252	-	-	57
03_Office 003		248	-	-	67
03_Office 004		255	-	-	39
03_Office: Open Plan 001		222	-	-	82
03_Office: Open Plan 002		237	-	-	84
03_On-Call+Ensuite 001		-	89	-	177
03_On-Call+Ensuite 002		-	94	-	181
03_On-Call+Ensuite 003		-	93	-	168
03_Oncology Waiting		-	185	60	130
03_Pantry/Kitchen 001		-	205	-	107
03_Pantry/Kitchen 002		-	155	-	174
03_Pantry/Kitchen 003		-	171	-	148
03_Patient Pods 001		-	202	-	159
03_Patient Pods 002		-	202	-	159
03_Patient Pods 003		-	201	-	161
03_Patient Pods 004		-	202	-	159
03_Patient Pods 005		-	199	-	165
03_Patient Pods 006		-	204	-	158
03_Patient Weigh/Assessment		-	293	-	55
03_Phebotomy Chair		-	151	-	175

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
03_Play		-	137	60	240
03_ Quiet room		239	-	-	64
03_ Quiet room/int		255	-	-	55
03_Reception		-	270	60	64
03_Resus Bay 001		-	293	-	6
03_Resus Bay 002		-	293	-	6
03_Resus Bay 003		-	293	-	3
03_Resus Bay 004		-	293	-	5
03_Seminar		-	169	-	134
03_SERVER ROOM		229	-	-	266
03_Shared Admin		142	-	-	200
03_Shared Day Space		146	-	-	138
03_Single Bedroom 001		-	190	-	102
03_Single Bedroom 002		-	198	-	96
03_Single Bedroom 003		-	189	-	103
03_Single Bedroom 004		-	191	-	101
03_Single Bedroom 005		-	192	-	100
03_Single Bedroom 006		-	189	-	103
03_Single Bedroom 007		-	191	-	101
03_Single Bedroom 008		-	188	-	103
03_Single Bedroom 009		-	192	-	101
03_Single Bedroom 010		-	191	-	103
03_Single Bedroom 011		-	192	-	102
03_Single Bedroom 012		-	189	-	103
03_Single Bedroom 013		-	189	-	103
03_Single Bedroom 014		-	190	-	103
03_Single Bedroom 015		-	195	-	98
03_Single Bedroom 016		-	189	-	103
03_Single Bedroom 017		-	195	-	98
03_Single Bedroom 018		-	188	-	104
03_Single Bedroom 019		-	169	-	114
03_Single Bedroom 020		-	189	-	103
03_Single Bedroom 021		-	189	-	103
03_Single Bedroom 022		-	190	-	102
03_Single Bedroom 023		-	191	-	101
03_Single Bedroom 024		-	188	-	104
03_Single Bedroom 025		-	275	-	13
03_Single Bedroom 026		-	190	-	102
03_Single Bedroom 027		-	275	-	13
03_Single Bedroom 028		-	190	-	102
03_Single Bedroom 029		-	188	-	103
03_Single Bedroom 030		-	192	-	101
03_Single Bedroom 031		-	191	-	101

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
03_Single Bedroom 032		-	193	-	100
03_Single Bedroom 033		-	190	-	102
03_Single Bedroom 034		-	191	-	101
03_Single Bedroom 035		-	189	-	103
03_Single Bedroom 036		-	185	-	106
03_Single Bedroom 037		-	190	-	102
03_Single Bedroom 038		-	187	-	105
03_Single Bedroom 039		-	189	-	103
03_Single Bedroom 040		-	191	-	101
03_Single Bedroom 041		-	191	-	101
03_Single Bedroom 042		-	196	-	97
03_Single Bedroom 043		-	190	-	102
03_Single Bedroom 044		-	196	-	97
03_Single Bedroom 045		-	190	-	102
03_Single Bedroom 046		-	189	-	103
03_Single Bedroom 047		-	189	-	102
03_Single Bedroom 048		-	190	-	102
03_Single Bedroom 049		-	189	-	103
03_Single Bedroom 050		-	191	-	101
03_Single Bedroom 051		-	190	-	102
03_Single Bedroom 052		-	190	-	102
03_Single Bedroom 053		-	194	-	98
03_Single Bedroom 054		-	191	-	102
03_Single Bedroom 055		-	189	-	103
03_Single Bedroom 056		-	190	-	102
03_Single Bedroom 057		-	185	-	106
03_Single Room 001		-	191	-	102
03_Single Room 002		-	188	-	103
03_Single Room 003		-	191	-	101
03_Single Room 004		-	182	-	107
03_Single Room 005		-	183	-	108
03_Single Room 006		-	189	-	104
03_Single room (HDU) 001		-	169	-	114
03_Single room (HDU) 002		-	169	-	114
03_Single room (HDU) 003		-	169	-	114
03_Social Space/Dining 001		-	324	-	35
03_Social Space/Dining 002		-	299	-	40
03_Staff Base 001		-	101	-	75
03_Staff Base 002		-	157	-	53
03_Staff Base 003		-	203	-	49
03_Staff Base 004		-	110	-	78
03_Staff Base 005		-	127	-	72
03_Staff Base 006		-	110	-	75

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
03_Staff Base with Pneumt Tube 001		-	124	-	74
03_Staff Base with Pneumt Tube 002		-	141	-	87
03_Staff Base with Pneumt Tube 003		-	130	-	72
03_Staff Base with Pneumt Tube 004		-	116	-	85
03_Staff Change (Female)		-	110	-	70
03_Staff Change (Male)		-	147	-	37
03_Staff Communal Changing Room 001		-	77	-	147
03_Staff Communal Changing Room 002		-	79	-	136
03_Staff Rest/Base		-	124	-	96
03_Staff Rest/Bev 001		140	-	-	150
03_Staff Rest/Bev 002		136	-	-	178
03_Stair A		-	80	-	154
03_Stair C 001		-	84	-	160
03_Stair C 002		-	83	-	162
03_Stair D		-	76	-	171
03_Store 001		167	-	-	27
03_Store 002		167	-	-	26
03_Store 003		141	-	-	69
03_Store 004		126	-	-	103
03_Therapy Store		167	-	-	49
03_Therapy Workbase		293	-	-	44
03_Treatment 001		-	195	-	139
03_Treatment 002		-	202	-	131
03_Treatment (2-sided) 001		-	209	-	122
03_Treatment (2-sided) 002		-	209	-	120
03_Treatment Chemo		-	201	-	133
03_Unit Pantry 001		133	-	-	70
03_Unit Pantry 002		124	-	-	78
03_Visitor Lift Lobby 001		-	134	-	132
03_Visitor Lift Lobby 002		-	132	-	136
03_Visitor Lift Lobby 003		-	133	-	137
03_Wait 001		-	219	60	65
03_Wait 002		-	94	60	189
03_Wait 003		-	219	60	77
03_Ward Managers Office 001		255	-	-	56
03_Ward Managers Office 002		255	-	-	56
03_WC 001		-	134	-	31
03_WC 002		-	134	-	29
03_WC 003		-	134	-	18
03_WC 004		-	134	-	23
03_WC 005		-	134	-	20
03_WC 006		-	134	-	21
03_WC 007		-	134	-	18

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
03_WC 008		-	134	-	14
03_WC 009		-	134	-	14
03_WC 010		-	134	-	19
03_WC 011		-	134	-	19
03_WC 012		-	134	-	21
03_WC 013		-	134	-	20
03_WC/Shower: A. Trolley 001		-	99	-	98
03_WC/Shower: A. Trolley 002		-	98	-	101
03_WC: Semi amb 001		-	134	-	21
03_WC: Semi amb 002		-	134	-	26
03_WC: Semi amb 003		-	134	-	21
03_WC: Semi amb 004		-	134	-	27
04_2-Bed Bay w cot 001		-	86	-	242
04_2-Bed Bay w cot 002		-	87	-	240
04_4-cot bay 001		-	73	-	560
04_4-cot bay 002		-	73	-	541
04_A. WC 001		-	125	-	45
04_A. WC 002		-	134	-	36
04_A. WC 003		-	134	-	30
04_A. WC 004		-	133	-	41
04_A. WC 005		-	130	-	43
04_A. WC 006		-	134	-	30
04_A. WC 007		-	134	-	37
04_A. WC 008		-	112	-	53
04_A. WC 009		-	134	-	39
04_A. WC 010		-	134	-	40
04_A. WC 011		-	126	-	45
04_A. WC 012		-	121	-	52
04_A. WC 013		-	134	-	34
04_A. WC 014		-	134	-	36
04_A. WC 015		-	134	-	37
04_A. WC/Shower		-	134	-	37
04_Admin/Staff Base		-	93	-	200
04_Anaesthetic Room 001		-	166	-	276
04_Anaesthetic Room 002		-	166	-	276
04_BED/FM Lift Lobby 001		-	91	-	190
04_BED/FM Lift Lobby 002		-	92	-	187
04_BED/FM Lift Lobby 003		-	92	-	186
04_BED/FM Lift Lobby 004		-	92	-	186
04_Bereavement: Labour 001		-	112	-	142
04_Bereavement: Labour 002		-	112	-	142
04_Bereavement: Neonates		-	123	-	144
04_Breast Feed		-	95	-	116

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_Breast Feed/Pump room		-	114	-	86
04_Buggy Park 001		167	-	-	8
04_Buggy Park 002		167	-	-	7
04_C.U. 001		91	-	-	104
04_C.U. 002		103	-	-	80
04_C.U. 003		92	-	-	98
04_C.U. 004		85	-	-	125
04_C.U. 005		93	-	-	94
04_C.U. 006		99	-	-	86
04_C.U. 007		98	-	-	85
04_C.U. 008		101	-	-	82
04_C/E 001		-	169	-	125
04_C/E 002		-	179	-	109
04_C/E 003		-	174	-	144
04_C/E 004		-	169	-	125
04_C/E 005		-	170	-	124
04_C/E 006		-	171	-	122
04_C/E 007		-	169	-	124
04_C/E 008		-	165	-	134
04_C/E 009		-	169	-	123
04_C/E 010		-	169	-	124
04_Circulation 001		-	84	-	326
04_Circulation 002		-	76	-	411
04_Circulation 003		-	101	-	95
04_Circulation 004		-	79	-	590
04_Circulation 005		-	90	-	144
04_Circulation 006		-	79	-	538
04_Circulation 007		-	76	-	410
04_Cleaners 001		138	-	-	32
04_Cleaners 002		135	-	-	35
04_Cleaners 003		128	-	-	38
04_Cleaners 004		134	-	-	35
04_Cleaners 005		126	-	-	41
04_Cold St.		164	-	-	43
04_Corridor 001		-	141	-	47
04_Corridor 002		-	89	-	207
04_Corridor 003		-	89	-	749
04_Corridor 004		-	85	-	714
04_Corridor 005		-	95	-	363
04_Corridor 006		-	99	-	226
04_Corridor 007		-	114	-	80
04_Corridor 008		-	101	-	108
04_Corridor 009		-	86	-	689

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_Corridor 010		-	100	-	195
04_Corridor 011		-	95	-	133
04_Corridor 012		-	91	-	431
04_Corridor 013		-	104	-	144
04_Corridor 014		-	84	-	1793
04_Corridor 015		-	105	-	178
04_Corridor 016		-	93	-	511
04_Corridor 017		-	115	-	81
04_Corridor 018		-	97	-	292
04_Corridor 019		-	99	-	215
04_Corridor 020		-	109	-	110
04_Corridor 021		-	103	-	147
04_Corridor 022		-	118	-	79
04_Corridor 023		-	109	-	119
04_Corridor 024		-	140	-	61
04_Corridor 025		-	88	-	1016
04_Corridor 026		-	112	-	114
04_Corridor 027		-	121	-	72
04_Corridor 028		-	80	-	478
04_Corridor 029		-	87	-	719
04_Cot Clean & Store		98	-	-	130
04_Cots: Single room 001		-	140	-	137
04_Cots: Single room 002		-	147	-	122
04_Cots: Single room 003		-	148	-	117
04_Cots: Single room 004		-	145	-	104
04_Cots: Single room 005		-	140	-	135
04_Cots: Single room 006		-	154	-	111
04_Cots: Single room 007		-	157	-	87
04_Cots: Single room 008		-	141	-	135
04_Cots: Single room 009		-	140	-	135
04_Cots: Single room 010		-	147	-	120
04_D.U. 001		110	-	-	65
04_D.U. 002		109	-	-	72
04_D.U. 003		109	-	-	72
04_D.U. 004		99	-	-	94
04_D.U. 005		109	-	-	68
04_D.U. 006		112	-	-	63
04_D.U. 007		116	-	-	68
04_D.U. 008		143	-	-	42
04_D.U. 009		93	-	-	100
04_Delivery Room 001		-	142	-	214
04_Delivery Room 002		-	139	-	228
04_Delivery Room 003		-	142	-	216

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_Delivery Room 004		-	139	-	230
04_Delivery Room 005		-	142	-	216
04_Delivery Room 006		-	142	-	216
04_Delivery: Large 001		-	142	-	230
04_Delivery: Large 002		-	138	-	237
04_Delivery: Large 003		-	138	-	237
04_Delivery: Large 004		-	136	-	247
04_Delivery: Large 005		-	136	-	247
04_Delivery: Large 006		-	142	-	228
04_Delivery: Large 007		-	137	-	239
04_Delivery: Large 008		-	138	-	233
04_Delivery: Large 009		-	138	-	237
04_Delivery: Large 010		-	138	-	233
04_Disposal 001		140	-	-	44
04_Disposal 002		134	-	-	49
04_Disposal 003		139	-	-	43
04_Disposal 004		146	-	-	40
04_Elec. Cup. 001		176	-	-	12
04_Elec. Cup. 002		176	-	-	21
04_Elec. Cup. 003		176	-	-	15
04_Elec. Cup. 004		176	-	-	12
04_Elec. Cup. 005		176	-	-	13
04_Elec. Cup. 006		176	-	-	13
04_Elec. Cup. 007		176	-	-	12
04_Elec. Cup. 008		176	-	-	16
04_Elec. Cup. 009		176	-	-	12
04_Elec. Cup. 010		176	-	-	12
04_Elec. Cup. 011		176	-	-	13
04_Elec. Cup. 012		176	-	-	13
04_Elec. Cup. 013		176	-	-	12
04_Elec. Cup. 014		176	-	-	13
04_Elec. Cup. 015		176	-	-	13
04_Elec. Cup. 016		176	-	-	13
04_Elec. Cup. 017		176	-	-	13
04_Ensuite 001		-	131	-	29
04_Ensuite 002		-	131	-	28
04_Ensuite 003		-	131	-	27
04_Ensuite 004		-	118	-	38
04_Ensuite 005		-	131	-	27
04_Ensuite 006		-	131	-	28
04_Ensuite 007		-	131	-	28
04_Ensuite 008		-	131	-	24
04_Ensuite 009		-	131	-	27

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_Ensuite 010		-	131	-	27
04_Ensuite 011		-	131	-	27
04_Ensuite 012		-	131	-	28
04_Ensuite 013		-	131	-	28
04_Ensuite 014		-	131	-	28
04_Ensuite 015		-	117	-	39
04_Ensuite 016		-	131	-	30
04_Ensuite 017		-	131	-	29
04_Ensuite 018		-	127	-	33
04_Ensuite 019		-	129	-	32
04_Ensuite 020		-	131	-	29
04_Ensuite 021		-	131	-	27
04_Ensuite 022		-	131	-	27
04_Ensuite 023		-	131	-	28
04_Ensuite 024		-	131	-	27
04_Ensuite 025		-	131	-	28
04_Ensuite 026		-	131	-	27
04_Ensuite 027		-	131	-	29
04_Ensuite 028		-	131	-	27
04_Ensuite 029		-	131	-	28
04_Ensuite 030		-	131	-	29
04_Ensuite 031		-	131	-	28
04_Ensuite 032		-	131	-	28
04_Ensuite 033		-	131	-	27
04_Ensuite 034		-	131	-	27
04_Ensuite 035		-	121	-	36
04_Ensuite 036		-	131	-	28
04_Ensuite 037		-	131	-	28
04_Ensuite 038		-	131	-	29
04_Ensuite 039		-	131	-	27
04_Ensuite 040		-	131	-	28
04_Ensuite 041		-	131	-	28
04_Ensuite 042		-	120	-	37
04_Ensuite 043		-	131	-	28
04_Ensuite 044		-	131	-	27
04_Ensuite 045		-	131	-	28
04_Ensuite 046		-	131	-	28
04_Ensuite 047		-	131	-	28
04_Ensuite 048		-	120	-	37
04_Ensuite 049		-	131	-	28
04_Ensuite 050		-	131	-	27
04_Ensuite 051		-	118	-	36
04_Ensuite 052		-	118	-	36

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_Ensuite 053		-	131	-	27
04_Ensuite 054		-	128	-	33
04_Ensuite 055		-	127	-	33
04_Ensuite 056		-	122	-	36
04_Ensuite 057		-	131	-	28
04_Ensuite 058		-	131	-	28
04_Ensuite 059		-	118	-	38
04_Ensuite 060		-	131	-	29
04_Ensuite 061		-	127	-	33
04_Ensuite 062		-	118	-	38
04_Ensuite 063		-	119	-	37
04_Ensuite 064		-	131	-	28
04_Ensuite 065		-	131	-	28
04_Ensuite 066		-	131	-	29
04_Ensuite 067		-	131	-	24
04_Ensuite 068		-	117	-	37
04_Ensuite 069		-	126	-	33
04_Ensuite 070		-	127	-	32
04_Ensuite 071		-	131	-	29
04_Ensuite 072		-	131	-	29
04_Ensuite 073		-	119	-	37
04_Ensuite 074		-	117	-	39
04_Ensuite 075		-	125	-	33
04_Ensuite 076		-	131	-	27
04_Eq. St/Consm		123	-	-	57
04_Eq. Store 001		167	-	-	25
04_Eq. Store 002		165	-	-	43
04_Eq. Store 003		167	-	-	25
04_Eq. Store 004		135	-	-	46
04_Eq. Store 005		107	-	-	69
04_Eq. Store 006		76	-	-	75
04_Eq. Store 007		152	-	-	46
04_Group Room		136	-	-	129
04_HDU Room		-	128	-	232
04_Hearing test room 001		-	162	-	138
04_Hearing test room 002		-	163	-	136
04_Interview/Quiet Room		173	-	-	72
04_Iso Lobby 001		-	152	-	40
04_Iso Lobby 002		-	154	-	39
04_Iso Lobby 003		-	174	-	25
04_Iso Lobby 004		-	180	-	31
04_IT HUB 001		276	-	-	82
04_IT HUB 002		276	-	-	82

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_IT HUB 003		274	-	-	83
04_Junior Doctor Office		171	-	-	115
04_Linen 001		167	-	-	23
04_Linen 002		167	-	-	18
04_Linen 003		167	-	-	23
04_Linen 004		167	-	-	21
04_Linen 005		136	-	-	33
04_Linen 006		155	-	-	27
04_Lobby		-	150	-	61
04_Milk Kitchen 001		-	145	-	74
04_Milk Kitchen 002		-	144	-	75
04_Office 001		171	-	-	82
04_Office 002		177	-	-	68
04_Office 003		179	-	-	77
04_Office 004		167	-	-	85
04_Office 005		183	-	-	70
04_Office 006		151	-	-	95
04_Office 007		191	-	-	64
04_Office 008		163	-	-	85
04_Office 009		180	-	-	71
04_Office 010		171	-	-	81
04_Office 011		163	-	-	79
04_Office 012		185	-	-	67
04_Office 013		150	-	-	100
04_Office 014		160	-	-	82
04_Office 015		167	-	-	76
04_Office 016		180	-	-	71
04_Office 017		165	-	-	87
04_Office - Manager		194	-	-	59
04_Office - reporting (4)		194	-	-	60
04_Office/Teams 001		118	-	-	204
04_Office/Teams 002		116	-	-	217
04_On-Call Room 001		-	171	-	52
04_On-Call Room 002		-	171	-	52
04_Parent's Kitchen/Dining Room		-	107	-	321
04_Parent's Lounge		107	-	-	189
04_Parents: ONS		122	-	-	168
04_Partners Change 001		-	147	-	26
04_Partners Change 002		-	147	-	27
04_PoCT 001		127	-	-	147
04_PoCT 002		182	-	-	68
04_PoCT 003		186	-	-	70
04_PoCT 004		223	-	-	44

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_Prep Room		-	188	-	104
04_Reception		-	134	60	179
04_Reception/Wait 001		-	127	60	227
04_Reception/Wait 002		-	270	60	48
04_Reception/Wait 003		-	136	60	201
04_Reception/Wait 004		-	115	60	239
04_Recovery (Stage 1) 001		-	99	-	118
04_Recovery (Stage 1) 002		-	118	-	122
04_Recovery (Stage 1) 003		-	118	-	122
04_Recovery (Stage 1) 004		-	99	-	118
04_Rooming-In		-	153	-	111
04_Seminar 001		-	140	-	140
04_Seminar 002		-	141	-	132
04_Seminar 003		-	141	-	133
04_Single bedroom AN 001		-	155	-	103
04_Single bedroom AN 002		-	156	-	102
04_Single bedroom AN 003		-	154	-	103
04_Single bedroom AN 004		-	157	-	101
04_Single bedroom AN 005		-	155	-	103
04_Single bedroom AN 006		-	156	-	101
04_Single bedroom AN 007		-	154	-	104
04_Single bedroom AN 008		-	155	-	103
04_Single bedroom AN 009		-	157	-	101
04_Single bedroom w cot 001		-	155	-	103
04_Single bedroom w cot 002		-	155	-	103
04_Single bedroom w cot 003		-	156	-	101
04_Single bedroom w cot 004		-	155	-	103
04_Single bedroom w cot 005		-	152	-	105
04_Single bedroom w cot 006		-	154	-	103
04_Single bedroom w cot 007		-	155	-	102
04_Single bedroom w cot 008		-	156	-	102
04_Single bedroom w cot 009		-	155	-	103
04_Single bedroom w cot 010		-	152	-	105
04_Single bedroom w cot 011		-	156	-	102
04_Single bedroom w cot 012		-	154	-	103
04_Single bedroom w cot 013		-	155	-	103
04_Single bedroom w cot 014		-	156	-	101
04_Single bedroom w cot 015		-	154	-	104
04_Single bedroom w cot 016		-	157	-	101
04_Single bedroom w cot 017		-	154	-	103
04_Single bedroom w cot 018		-	155	-	103
04_Single day space AN 001		-	150	-	92
04_Single day space AN 002		-	150	-	92

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_Single day space AN 003		-	149	-	93
04_Single day space AN 004		-	149	-	93
04_Single day space AN 005		-	150	-	92
04_Single day space AN 006		-	150	-	92
04_Skills Lab		-	132	-	287
04_Staff Base 001		-	84	-	93
04_Staff Base 002		-	83	-	90
04_Staff Base 003		-	87	-	76
04_Staff Base 004		-	103	-	45
04_Staff Base 005		-	203	-	21
04_Staff Base 006		-	126	-	37
04_Staff Base 007		-	82	-	102
04_Staff Base 008		-	203	-	36
04_Staff Base 009		-	70	-	105
04_Staff Base 010		-	70	-	104
04_Staff Change 001		-	65	-	156
04_Staff Change 002		-	75	-	121
04_Staff Change 003		-	95	-	63
04_Staff Change 004		-	69	-	129
04_Staff Change 005		-	67	-	142
04_Staff Change (Female)		-	68	-	146
04_Staff Change (Male)		-	97	-	56
04_Staff Office		175	-	-	70
04_Staff Rest/Bev 001		104	-	-	214
04_Staff Rest/Bev 002		120	-	-	141
04_Staff Rest/Bev 003		123	-	-	133
04_Staff Rest/Bev 004		118	-	-	227
04_Staff Rest/Bev 005		140	-	-	97
04_Staff Rest/Bev 006		124	-	-	149
04_Staff WC 001		-	134	-	21
04_Staff WC 002		-	134	-	39
04_Staff WC 003		-	134	-	20
04_Staff WC 004		-	134	-	21
04_Stair A		-	69	-	154
04_Stair C 001		-	71	-	162
04_Stair C 002		-	72	-	160
04_Stair D		-	68	-	159
04_Store 001		159	-	-	35
04_Store 002		156	-	-	46
04_Store 003		167	-	-	18
04_Store 004		167	-	-	16
04_Store 005		125	-	-	57
04_Store 006		98	-	-	63

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_Store 007		106	-	-	70
04_Store 008		98	-	-	84
04_Store 009		143	-	-	42
04_Store 010		144	-	-	42
04_Store 011		141	-	-	51
04_Store 012		94	-	-	67
04_Store 013		153	-	-	40
04_Store 014		167	-	-	27
04_Store 015		104	-	-	73
04_Store 016		142	-	-	42
04_Store 017		167	-	-	13
04_TCU Office		220	-	-	47
04_TCU/single room w cot 001		-	155	-	103
04_TCU/single room w cot 002		-	156	-	102
04_TCU/single room w cot 003		-	156	-	102
04_TCU/single room w cot 004		-	156	-	102
04_TCU/single room w cot 005		-	155	-	103
04_TCU/single room w cot 006		-	155	-	103
04_Theatre: C-section 001		-	121	-	826
04_Theatre: C-section 002		-	121	-	832
04_Treat: Procedures		-	194	-	92
04_Treatment (2-sided)		-	166	-	133
04_Treatment: Phleb/Vacc 001		-	293	-	47
04_Treatment: Phleb/Vacc 002		-	293	-	45
04_Treatment: Phleb/Vacc 003		-	271	-	61
04_Treatment: Phleb/Vacc 004		-	264	-	63
04_Triage 001		-	164	-	134
04_Triage 002		-	165	-	132
04_Triage 003		-	164	-	133
04_Triage 004		-	165	-	131
04_Triage 005		-	179	-	122
04_Ultrasound 001		-	154	-	281
04_Ultrasound 002		-	154	-	284
04_Ultrasound 003		-	154	-	284
04_Ultrasound 004		-	154	-	281
04_Ultrasound 005		-	154	-	284
04_Ultrasound 006		-	154	-	281
04_Unit Pantry 004		107	-	-	73
04_Unit Pantry 001		99	-	-	81
04_Unit Pantry 002		131	-	-	48
04_Unit Pantry 003		130	-	-	52
04_Visitor Lift Lobby 001		-	108	-	137
04_Visitor Lift Lobby 002		-	108	-	136

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
04_Visitor Lift Lobby 003		-	109	-	132
04_Waiting: 10 places 001		-	122	60	177
04_Waiting: 10 places 002		-	138	60	140
04_WC 001		-	134	-	20
04_WC 002		-	134	-	29
04_WC 003		-	134	-	28
04_WC 004		-	134	-	26
04_WC 005		-	134	-	20
04_WC 006		-	134	-	21
04_WC 007		-	134	-	26
04_WC 008		-	134	-	26
04_WC 009		-	134	-	28
04_WC 010		-	134	-	21
04_WC- nappy change		-	134	-	38
05_4-Bed Bay 001		-	78	-	443
05_4-Bed Bay 002		-	78	-	443
05_4-Bed Bay 003		-	76	-	476
05_4-Bed Bay 004		-	78	-	442
05_4-Bed Bay 005		-	78	-	443
05_4-Bed Bay 006		-	76	-	475
05_A. WC 001		-	130	-	42
05_A. WC 002		-	134	-	38
05_A. WC/Shower 001		-	101	-	63
05_A. WC/Shower 002		-	86	-	94
05_A. WC/Shower 003		-	101	-	63
05_A. WC/Shower 004		-	110	-	65
05_A. WC/Shower 005		-	110	-	65
05_A. WC/Shower 006		-	101	-	63
05_ARU Gym		-	118	-	238
05_Bariatric Bedroom 001		-	143	-	114
05_Bariatric Bedroom 002		-	143	-	114
05_Bariatric Bedroom 003		-	147	-	103
05_Bay: Wheelchair		-	188	-	9
05_BED/FM Lift Lobby 001		-	92	-	186
05_BED/FM Lift Lobby 002		-	92	-	186
05_BED/FM Lift Lobby 003		-	92	-	187
05_BED/FM Lift Lobby 004		-	91	-	190
05_C.U. 001		134	-	-	46
05_C.U. 002		133	-	-	48
05_C.U. 003		141	-	-	45
05_C.U. 004		134	-	-	46
05_C.U. 005		141	-	-	45
05_C.U. 006		129	-	-	50

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
05_Circulation 001		-	76	-	411
05_Circulation 002		-	84	-	320
05_Circulation 003		-	90	-	144
05_Circulation 004		-	80	-	597
05_Circulation 005		-	101	-	95
05_Circulation 006		-	76	-	410
05_Circulation 007		-	80	-	547
05_Cleaners 001		155	-	-	28
05_Cleaners 002		127	-	-	37
05_Cleaners 003		142	-	-	33
05_Corridor 001		-	88	-	353
05_Corridor 002		-	92	-	799
05_Corridor 003		-	98	-	264
05_Corridor 004		-	93	-	793
05_Corridor 005		-	102	-	232
05_Corridor 006		-	88	-	637
05_Corridor 007		-	89	-	349
05_Corridor 008		-	99	-	260
05_Corridor 009		-	89	-	323
05_Corridor 010		-	141	-	47
05_Corridor 011		-	89	-	307
05_Corridor 012		-	89	-	633
05_D.U. 001		106	-	-	71
05_D.U. 002		112	-	-	64
05_D.U. 003		105	-	-	71
05_D.U. 004		105	-	-	71
05_D.U. 005		107	-	-	70
05_D.U. 006		113	-	-	63
05_Disposal 001		132	-	-	47
05_Disposal 002		152	-	-	38
05_Disposal 003		131	-	-	48
05_Elec. Cup. 001		176	-	-	18
05_Elec. Cup. 002		176	-	-	18
05_Elec. Cup. 003		176	-	-	22
05_En-suite Bariatric 001		-	114	-	38
05_En-suite Bariatric 002		-	111	-	40
05_En-suite Bariatric 003		-	107	-	43
05_Ensuite 001		-	131	-	58
05_Ensuite 002		-	131	-	27
05_Ensuite 003		-	131	-	27
05_Ensuite 004		-	131	-	28
05_Ensuite 005		-	131	-	56
05_Ensuite 006		-	131	-	28

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
05_Ensuite 007		-	131	-	28
05_Ensuite 008		-	131	-	28
05_Ensuite 009		-	131	-	28
05_Ensuite 010		-	131	-	28
05_Ensuite 011		-	131	-	28
05_Ensuite 012		-	131	-	26
05_Ensuite 013		-	131	-	28
05_Ensuite 014		-	131	-	27
05_Ensuite 015		-	131	-	28
05_Ensuite 016		-	131	-	28
05_Ensuite 017		-	131	-	28
05_Ensuite 018		-	131	-	27
05_Ensuite 019		-	131	-	29
05_Ensuite 020		-	131	-	28
05_Ensuite 021		-	131	-	28
05_Ensuite 022		-	131	-	28
05_Ensuite 023		-	131	-	27
05_Ensuite 024		-	131	-	28
05_Ensuite 025		-	131	-	28
05_Ensuite 026		-	131	-	28
05_Ensuite 027		-	131	-	27
05_Ensuite 028		-	131	-	28
05_Ensuite 029		-	131	-	27
05_Ensuite 030		-	131	-	27
05_Ensuite 031		-	131	-	28
05_Ensuite 032		-	131	-	28
05_Ensuite 033		-	131	-	27
05_Ensuite 034		-	131	-	28
05_Ensuite 035		-	131	-	28
05_Ensuite 036		-	131	-	28
05_Ensuite 037		-	131	-	27
05_Ensuite 038		-	131	-	27
05_Ensuite 039		-	131	-	27
05_Ensuite 040		-	131	-	28
05_Ensuite 041		-	131	-	28
05_Ensuite 042		-	131	-	27
05_Ensuite 043		-	131	-	28
05_Ensuite 044		-	131	-	27
05_Ensuite 045		-	131	-	27
05_Ensuite 046		-	131	-	29
05_Ensuite 047		-	131	-	28
05_Ensuite 048		-	131	-	27
05_Ensuite 049		-	131	-	27

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
05_Ensuite 050		-	131	-	28
05_Ensuite 051		-	131	-	27
05_Ensuite 052		-	131	-	28
05_Ensuite 053		-	131	-	28
05_Ensuite 054		-	131	-	27
05_Ensuite 055		-	131	-	28
05_Ensuite 056		-	131	-	28
05_Ensuite 057		-	131	-	28
05_Eq. Bay 001		167	-	-	6
05_Eq. Bay 002		167	-	-	6
05_Eq. Bay 003		163	-	-	6
05_Eq. Bay 004		167	-	-	6
05_Eq. Bay 005		167	-	-	11
05_Eq. Store 001		114	-	-	66
05_Eq. Store 002		167	-	-	26
05_Eq. Store 003		102	-	-	101
05_Interview 001		210	-	-	51
05_Interview 002		190	-	-	73
05_Interview 003		206	-	-	60
05_Interview 004		210	-	-	51
05_Interview 005		211	-	-	54
05_Interview 006		177	-	-	69
05_Iso Lobby 001		-	132	-	52
05_Iso Lobby 002		-	142	-	45
05_Iso Lobby 003		-	128	-	55
05_IT HUB 001		285	-	-	76
05_IT HUB 002		285	-	-	75
05_IT HUB 003		285	-	-	75
05_IT HUB 004		276	-	-	82
05_IT HUB 005		282	-	-	77
05_Linen 001		167	-	-	8
05_Linen 002		167	-	-	18
05_Linen 003		167	-	-	19
05_Linen 004		156	-	-	31
05_Linen 005		167	-	-	19
05_Lobby 001		-	128	-	120
05_Lobby 002		-	137	-	76
05_Lobby 003		-	132	-	106
05_Lobby 004		-	150	-	61
05_Lobby 005		-	127	-	79
05_Lockers 001		110	-	-	46
05_Lockers 002		109	-	-	47
05_Lockers 003		100	-	-	33

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
05_MDT Room 001		111	-	-	188
05_MDT Room 002		131	-	-	132
05_MDT Room 003		123	-	-	143
05_MDT Room 004		129	-	-	203
05_MDT Room 005		133	-	-	152
05_MDT Room 006		139	-	-	178
05_Meds Store/Prep 001		107	-	-	171
05_Meds Store/Prep 002		106	-	-	173
05_Meds Store/Prep 003		113	-	-	200
05_Meeting Room		106	-	-	238
05_MEP PLANT		58	-	-	14364
05_Office 001		195	-	-	57
05_Office 002		162	-	-	83
05_Office 003		255	-	-	28
05_OT Office: 6 Workstations		140	-	-	159
05_Physio office: 6 workstations		168	-	-	93
05_Resus Bay 001		-	293	-	4
05_Resus Bay 002		-	293	-	4
05_Resus Bay 003		-	293	-	4
05_Resus Bay 004		-	293	-	4
05_Resus Bay 005		-	293	-	6
05_Shared Admin 001		117	-	-	195
05_Shared Admin 002		122	-	-	253
05_Shared Day Space		129	-	-	124
05_Single Bedroom 001		-	154	-	104
05_Single Bedroom 002		-	155	-	103
05_Single Bedroom 003		-	155	-	103
05_Single Bedroom 004		-	154	-	103
05_Single Bedroom 005		-	151	-	107
05_Single Bedroom 006		-	151	-	108
05_Single Bedroom 007		-	155	-	103
05_Single Bedroom 008		-	156	-	102
05_Single Bedroom 009		-	157	-	101
05_Single Bedroom 010		-	156	-	102
05_Single Bedroom 011		-	154	-	103
05_Single Bedroom 012		-	155	-	103
05_Single Bedroom 013		-	157	-	101
05_Single Bedroom 014		-	156	-	101
05_Single Bedroom 015		-	155	-	103
05_Single Bedroom 016		-	156	-	101
05_Single Bedroom 017		-	156	-	102
05_Single Bedroom 018		-	156	-	102
05_Single Bedroom 019		-	155	-	103

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
05_Single Bedroom 020		-	155	-	102
05_Single Bedroom 021		-	154	-	104
05_Single Bedroom 022		-	156	-	102
05_Single Bedroom 023		-	156	-	101
05_Single Bedroom 024		-	155	-	103
05_Single Bedroom 025		-	157	-	100
05_Single Bedroom 026		-	155	-	103
05_Single Bedroom 027		-	156	-	102
05_Single Bedroom 028		-	155	-	104
05_Single Bedroom 029		-	154	-	103
05_Single Bedroom 030		-	156	-	102
05_Single Bedroom 031		-	154	-	104
05_Single Bedroom 032		-	157	-	101
05_Single Bedroom 033		-	156	-	102
05_Single Bedroom 034		-	155	-	104
05_Single Bedroom 035		-	155	-	103
05_Single Bedroom 036		-	156	-	102
05_Single Bedroom 037		-	157	-	101
05_Single Bedroom 038		-	156	-	102
05_Single Bedroom 039		-	155	-	102
05_Single Bedroom 040		-	156	-	103
05_Single Bedroom 041		-	155	-	103
05_Single Bedroom 042		-	155	-	103
05_Single Bedroom 043		-	157	-	100
05_Single Bedroom 044		-	155	-	103
05_Single Bedroom 045		-	156	-	102
05_Single Bedroom 046		-	157	-	102
05_Single Bedroom 047		-	156	-	101
05_Single Bedroom 048		-	156	-	103
05_Single Bedroom 049		-	156	-	101
05_Single Bedroom 050		-	154	-	103
05_Single Bedroom 051		-	156	-	102
05_Single Bedroom 052		-	156	-	102
05_Single Bedroom 053		-	156	-	101
05_Single Bedroom 054		-	155	-	103
05_Single Bedroom 055		-	156	-	102
05_Single Bedroom 056		-	156	-	102
05_Single Bedroom 057		-	155	-	103
05_Staff Base 001		-	71	-	77
05_Staff Base 002		-	86	-	79
05_Staff Base 003		-	203	-	6
05_Staff Base 004		-	71	-	76
05_Staff Base 005		-	88	-	72

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
05_Staff Base 006		-	87	-	75
05_Staff Base 007		-	87	-	78
05_Staff Base 008		-	199	-	5
05_Staff Change 001		-	64	-	208
05_Staff Change 002		-	74	-	153
05_Staff Rest/Bev 001		110	-	-	127
05_Staff Rest/Bev 002		104	-	-	150
05_Staff Rest/Bev 003		104	-	-	150
05_Stair A		-	69	-	154
05_Stair C 001		-	71	-	162
05_Stair C 002		-	72	-	160
05_Stair D		-	68	-	159
05_Store 001		114	-	-	67
05_Store 002		101	-	-	103
05_Store 003		167	-	-	28
05_Store 004		167	-	-	29
05_Store 005		141	-	-	63
05_Treatment (2-sided) 001		-	169	-	123
05_Treatment (2-sided) 002		-	170	-	122
05_Treatment (2-sided) 003		-	169	-	123
05_Unit Pantry 001		100	-	-	79
05_Unit Pantry 002		106	-	-	70
05_Unit Pantry 003		100	-	-	78
05_Visitor Lift Lobby 001		-	108	-	136
05_Visitor Lift Lobby 002		-	109	-	132
05_Visitor Lift Lobby 003		-	108	-	137
05_WC 001		-	134	-	20
05_WC 002		-	134	-	21
05_WC 003		-	134	-	14
05_WC 004		-	134	-	14
05_WC 005		-	134	-	18
05_WC 006		-	134	-	16
05_WC 007		-	134	-	21
05_WC 008		-	134	-	18
05_WC 009		-	134	-	16
05_WC 010		-	134	-	18
05_WC 011		-	134	-	14
05_WC 012		-	134	-	23
05_WC 013		-	134	-	24
05_WC 014		-	134	-	22
05_WC 015		-	134	-	20
05_WC 016		-	134	-	19
05_WC 017		-	134	-	19

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
05_WC 018		-	134	-	24
05_WC 019		-	134	-	15
05_WC/Shower: A. Trolley 001		-	80	-	98
05_WC/Shower: A. Trolley 002		-	79	-	101
05_WC/Shower: A. Trolley 003		-	80	-	100
05_WC: Semi amb 001		-	134	-	26
05_WC: Semi amb 002		-	134	-	26
05_WC: Semi amb 003		-	134	-	21
05_WC: Semi amb 004		-	134	-	27
05_WC: Semi amb 005		-	134	-	21
05_WC: Semi amb 006		-	134	-	26
06_4 Bed bay 001		-	75	-	477
06_4 Bed bay 002		-	78	-	441
06_4 Bed bay 003		-	78	-	442
06_4 Bed bay 004		-	78	-	443
06_4 Bed bay 005		-	78	-	443
06_4 Bed bay 006		-	76	-	476
06_A WC/Shower 001		-	86	-	94
06_A WC/Shower 002		-	111	-	64
06_A WC/Shower 003		-	110	-	65
06_A WC/Shower 004		-	100	-	64
06_A. WC 001		-	116	-	51
06_A. WC 002		-	113	-	53
06_A. WC 003		-	131	-	43
06_A. WC/Shower 001		-	101	-	63
06_A. WC/Shower 002		-	101	-	63
06_Bariatric Bedroom 001		-	143	-	115
06_Bariatric Bedroom 002		-	151	-	95
06_Bariatric Bedroom 003		-	147	-	103
06_BED/FM Lift Lobby 001		-	91	-	190
06_BED/FM Lift Lobby 002		-	92	-	186
06_BED/FM Lift Lobby 003		-	92	-	187
06_BED/FM Lift Lobby 004		-	92	-	186
06_Breast Feed		-	143	-	60
06_C.U. 001		141	-	-	45
06_C.U. 002		134	-	-	46
06_Circulation 001		-	76	-	411
06_Circulation 002		-	79	-	538
06_Circulation 003		-	79	-	567
06_Circulation 004		-	130	-	67
06_Circulation 005		-	84	-	319
06_Circulation 006		-	101	-	95
06_Circulation 007		-	76	-	410

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
06_Circulation 008		-	90	-	144
06_Circulation 009		-	140	-	53
06_Cleaners 001		167	-	-	21
06_Cleaners 002		134	-	-	35
06_Cleaners 003		128	-	-	37
06_Cleaners 004		155	-	-	28
06_Clinical Psychology Office		173	-	-	101
06_Corporate Office 001		239	-	-	42
06_Corporate Office 002		235	-	-	43
06_Corporate Office 003		239	-	-	42
06_Corridor 001		-	104	-	357
06_Corridor 002		-	93	-	88
06_Corridor 003		-	87	-	640
06_Corridor 004		-	104	-	234
06_Corridor 005		-	102	-	241
06_Corridor 006		-	130	-	31
06_Corridor 007		-	188	-	16
06_Corridor 008		-	98	-	626
06_Corridor 009		-	83	-	305
06_Corridor 010		-	141	-	47
06_Corridor 011		-	101	-	257
06_Corridor 012		-	89	-	323
06_Corridor 013		-	121	-	70
06_Corridor 014		-	89	-	304
06_Corridor 015		-	88	-	353
06_Corridor 016		-	91	-	811
06_Corridor 017		-	93	-	794
06_Corridor 018		-	89	-	351
06_Corridor 019		-	88	-	633
06_Corridor 020		-	123	-	165
06_CU 001		129	-	-	50
06_CU 002		134	-	-	46
06_CU 003		140	-	-	46
06_CU 004		133	-	-	48
06_D.U. 001		113	-	-	63
06_D.U. 002		107	-	-	70
06_Disposal 001		152	-	-	38
06_Disposal 002		134	-	-	47
06_Disposal 003		167	-	-	29
06_Disposal 004		131	-	-	48
06_DU 001		106	-	-	69
06_DU 002		112	-	-	64
06_DU 003		108	-	-	69

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
06_DU 004		105	-	-	71
06_Elec Cup 001		176	-	-	18
06_Elec Cup 002		176	-	-	22
06_Elec Cup 003		176	-	-	13
06_Elec Cup 004		176	-	-	13
06_Elec Cup 005		176	-	-	18
06_Ensuite 001		-	131	-	28
06_Ensuite 002		-	131	-	28
06_Ensuite 003		-	131	-	28
06_Ensuite 004		-	131	-	27
06_Ensuite 005		-	131	-	27
06_Ensuite 006		-	131	-	27
06_Ensuite 007		-	131	-	28
06_Ensuite 008		-	131	-	28
06_Ensuite 009		-	131	-	27
06_Ensuite 010		-	131	-	28
06_Ensuite 011		-	131	-	29
06_Ensuite 012		-	131	-	27
06_Ensuite 013		-	131	-	27
06_Ensuite 014		-	131	-	28
06_Ensuite 015		-	131	-	28
06_Ensuite 016		-	131	-	28
06_Ensuite 017		-	131	-	28
06_Ensuite 018		-	131	-	28
06_Ensuite 019		-	131	-	28
06_Ensuite 020		-	131	-	27
06_Ensuite 021		-	131	-	27
06_Ensuite 022		-	131	-	27
06_Ensuite 023		-	131	-	28
06_Ensuite 024		-	131	-	28
06_Ensuite 025		-	131	-	27
06_Ensuite 026		-	131	-	28
06_Ensuite 027		-	131	-	28
06_Ensuite 028		-	131	-	28
06_Ensuite 029		-	131	-	28
06_Ensuite 030		-	131	-	27
06_Ensuite 031		-	131	-	28
06_Ensuite 032		-	131	-	28
06_Ensuite 033		-	131	-	29
06_Ensuite 034		-	131	-	28
06_Ensuite 035		-	131	-	28
06_Ensuite 036		-	131	-	27
06_Ensuite 037		-	131	-	26

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
06_Ensuite 038		-	131	-	27
06_Ensuite 039		-	131	-	28
06_Ensuite 040		-	131	-	27
06_Ensuite 041		-	131	-	27
06_Ensuite 042		-	131	-	26
06_Ensuite 043		-	131	-	27
06_Ensuite 044		-	131	-	27
06_Ensuite 045		-	131	-	28
06_Ensuite 046		-	131	-	28
06_Ensuite 047		-	131	-	27
06_Ensuite 048		-	131	-	28
06_Ensuite 049		-	131	-	28
06_Ensuite 050		-	131	-	28
06_Ensuite 051		-	131	-	27
06_Ensuite 052		-	131	-	27
06_Ensuite 053		-	131	-	28
06_Ensuite 054		-	131	-	28
06_Ensuite 055		-	131	-	28
06_Ensuite 056		-	131	-	27
06_Ensuite 057		-	131	-	28
06_Ensuite Bariatric 001		-	116	-	37
06_Ensuite Bariatric		-	111	-	40
06_Ensuite Bariatric		-	107	-	43
06_Eq Bay 001		167	-	-	6
06_Eq Bay 002		135	-	-	11
06_Eq Bay 003		167	-	-	6
06_Eq Bay 004		167	-	-	6
06_Eq Store 001		113	-	-	68
06_Eq Bay 005		167	-	-	5
06_Eq Bay 006		150	-	-	6
06_Eq Store 002		114	-	-	67
06_Food Court Seating		-	136	-	734
06_Interview 001		211	-	-	54
06_Interview 002		224	-	-	48
06_Interview 003		212	-	-	50
06_Interview 004		195	-	-	57
06_Interview 005		178	-	-	68
06_Interview 006		190	-	-	73
06_Iso Lobby 001		-	145	-	43
06_Iso Lobby 002		-	176	-	36
06_Iso Lobby 003		-	127	-	55
06_Iso Lobby 004		-	173	-	37
06_Iso Lobby 005		-	178	-	33

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
06_Iso Lobby 006		-	180	-	34
06_Iso Single Bedroom 001		-	154	-	88
06_Iso Single Bedroom 002		-	149	-	96
06_Iso Single Bedroom 003		-	149	-	96
06_IT HUB 001		274	-	-	83
06_IT HUB 002		276	-	-	82
06_IT HUB 003		276	-	-	82
06_Kitchens and Servery		-	80	-	2067
06_Linen 001		156	-	-	31
06_Linen 002		167	-	-	8
06_Linen 003		167	-	-	19
06_Linen 004		167	-	-	17
06_Linen 005		167	-	-	14
06_Linen 006		167	-	-	19
06_Linen 007		167	-	-	15
06_Lobby		-	150	-	61
06_Lockers 001		100	-	-	33
06_Lockers 002		109	-	-	47
06_Lockers 003		112	-	-	46
06_MDT Room 001		139	-	-	178
06_MDT Room 002		102	-	-	227
06_MDT Room 003		111	-	-	189
06_MDT Room 004		136	-	-	127
06_MDT Room 005		131	-	-	132
06_MDT Room 006		137	-	-	180
06_MDT Room 007		133	-	-	153
06_MDT Room 008		102	-	-	223
06_Meds Store/Prep 001		106	-	-	173
06_Meds Store/Prep 002		112	-	-	202
06_Meds Store/Prep 003		107	-	-	171
06_Meeting Room 001		107	-	-	238
06_Meeting Room 002		107	-	-	193
06_Meeting Room 003		103	-	-	215
06_Nappy Change		-	131	-	43
06_Office 001		173	-	-	82
06_Office 002		191	-	-	72
06_Office 003		201	-	-	54
06_Office 004		187	-	-	61
06_Office 005		146	-	-	102
06_On-Call Room 001		-	172	-	56
06_On-Call Room 002		-	172	-	56
06_Open Plan for 14 people 001		112	-	-	299
06_Open Plan for 14 people 002		111	-	-	305

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
06_Open Plan for 6 people		137	-	-	170
06_POD		-	293	-	19
06_Resus Bay 001		-	293	-	5
06_Resus Bay 002		-	293	-	3
06_Resus Bay 003		-	293	-	6
06_Resus Bay 004		-	180	-	4
06_Resus Bay 005		-	293	-	5
06_Resus Bay 006		-	293	-	3
06_Shared Admin 001		115	-	-	210
06_Shared Admin 002		117	-	-	236
06_Shared Admin 003		123	-	-	177
06_Shared Admin 004		115	-	-	207
06_Shared Admin 005		119	-	-	191
06_Shared Day Space		120	-	-	193
06_Shower		-	131	-	29
06_Single Bedroom 001		-	155	-	104
06_Single Bedroom 002		-	155	-	103
06_Single Bedroom 003		-	155	-	103
06_Single Bedroom 004		-	156	-	102
06_Single Bedroom 005		-	157	-	100
06_Single Bedroom 006		-	155	-	103
06_Single Bedroom 007		-	154	-	104
06_Single Bedroom 008		-	156	-	101
06_Single Bedroom 009		-	155	-	103
06_Single Bedroom 010		-	154	-	104
06_Single Bedroom 011		-	155	-	102
06_Single Bedroom 012		-	155	-	102
06_Single Bedroom 013		-	155	-	102
06_Single Bedroom 014		-	155	-	103
06_Single Bedroom 015		-	155	-	104
06_Single Bedroom 016		-	156	-	102
06_Single Bedroom 017		-	155	-	102
06_Single Bedroom 018		-	156	-	102
06_Single Bedroom 019		-	155	-	103
06_Single Bedroom 020		-	156	-	102
06_Single Bedroom 021		-	156	-	101
06_Single Bedroom 022		-	156	-	102
06_Single Bedroom 023		-	155	-	103
06_Single Bedroom 024		-	156	-	102
06_Single Bedroom 025		-	156	-	102
06_Single Bedroom 026		-	156	-	102
06_Single Bedroom 027		-	156	-	102
06_Single Bedroom 028		-	157	-	101

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
06_Single Bedroom 029		-	154	-	103
06_Single Bedroom 030		-	155	-	103
06_Single Bedroom 031		-	155	-	103
06_Single Bedroom 032		-	155	-	102
06_Single Bedroom 033		-	154	-	105
06_Single Bedroom 034		-	156	-	101
06_Single Bedroom 035		-	155	-	103
06_Single Bedroom 036		-	157	-	100
06_Single Bedroom 037		-	155	-	103
06_Single Bedroom 038		-	154	-	105
06_Single Bedroom 039		-	154	-	104
06_Single Bedroom 040		-	154	-	104
06_Single Bedroom 041		-	151	-	107
06_Single Bedroom 042		-	157	-	100
06_Single Bedroom 043		-	155	-	103
06_Single Bedroom 044		-	158	-	99
06_Single Bedroom 045		-	155	-	103
06_Single Bedroom 046		-	155	-	103
06_Single Bedroom 047		-	156	-	101
06_Single Bedroom 048		-	155	-	103
06_Single Bedroom 049		-	156	-	102
06_Single Bedroom 050		-	151	-	108
06_Single Bedroom 051		-	156	-	102
06_Single Bedroom 052		-	156	-	102
06_Single Bedroom 053		-	156	-	102
06_Single Bedroom 054		-	157	-	100
06_Staff Base 001		-	78	-	78
06_Staff Base 002		-	71	-	76
06_Staff Base 003		-	76	-	76
06_Staff Base 004		-	77	-	75
06_Staff Base 005		-	87	-	78
06_Staff Base 006		-	71	-	75
06_Staff Breakout		94	-	-	253
06_Staff Change		-	69	-	138
06_Staff Rest (wellbeing)		94	-	-	327
06_Staff Rest/Bev 001		104	-	-	151
06_Staff Rest/Bev 002		104	-	-	150
06_Staff Rest/Bev 003		104	-	-	149
06_Stair		-	64	-	614
06_Stair A		-	69	-	154
06_Stair C 001		-	71	-	162
06_Stair C 002		-	72	-	160
06_Stair D		-	68	-	159

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
06_Store 001		102	-	-	101
06_Store 002		141	-	-	63
06_Store 003		161	-	-	34
06_Store 004		167	-	-	28
06_Store 005		158	-	-	41
06_Store 006		101	-	-	103
06_Therapy Assmnt & Treat 001		-	166	-	135
06_Therapy Assmnt & Treat 002		-	165	-	130
06_Therapy Office: 6 workstations 001		151	-	-	159
06_Therapy Office: 6 workstations 002		142	-	-	176
06_Treatment (2 sided) 001		-	170	-	122
06_Treatment (2 sided) 002		-	169	-	123
06_Treatment (2 sided) 003		-	170	-	122
06_TSU Gym		-	110	-	349
06_Unit Pantry 001		106	-	-	70
06_Unit Pantry 002		100	-	-	79
06_Unit Pantry 003		100	-	-	78
06_Virtual Booth 001		-	293	-	34
06_Virtual Booth 002		-	293	-	34
06_Virtual Booth 003		-	293	-	33
06_Visitor Lift Lobby 001		-	109	-	132
06_Visitor Lift Lobby 002		-	108	-	137
06_Visitor Lift Lobby 003		-	108	-	136
06_WC 001		-	120	-	50
06_WC 002		-	134	-	41
06_WC 003		-	134	-	31
06_WC 004		-	134	-	31
06_WC 005		-	134	-	18
06_WC 006		-	134	-	18
06_WC 007		-	134	-	21
06_WC 008		-	134	-	27
06_WC 009		-	134	-	27
06_WC 010		-	134	-	14
06_WC 011		-	134	-	31
06_WC 012		-	134	-	33
06_WC 013		-	134	-	26
06_WC 014		-	134	-	23
06_WC 015		-	134	-	15
06_WC 016		-	134	-	24
06_WC 017		-	134	-	17
06_WC 018		-	134	-	20
06_WC 019		-	134	-	28
06_WC 020		-	134	-	20

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
06_WC 021		-	134	-	21
06_WC 022		-	134	-	17
06_WC 023		-	134	-	14
06_WC 024		-	134	-	21
06_WC 025		-	134	-	14
06_WC 026		-	134	-	19
06_WC Semi amb 001		-	134	-	21
06_WC Semi amb 002		-	134	-	26
06_WC Semi amb 003		-	134	-	27
06_WC/Shower A Trolley 001		-	79	-	102
06_WC/Shower A Trolley 002		-	79	-	101
06_WC/Shower A Trolley 003		-	80	-	98
06_WC Semi amb 004		-	134	-	21
06_WC Semi amb 005		-	134	-	26
06_WC Semi amb 006		-	134	-	26
06_Zone Hub St.		112	-	-	63
07_Bed/FM Lift Lobby 001		-	88	-	186
07_Bed/FM Lift Lobby 002		-	88	-	186
07_Bed/FM Lift Lobby 003		-	87	-	190
07_Bed/FM Lift Lobby 004		-	87	-	187
07_Circulation 001		-	74	-	410
07_Circulation 002		-	80	-	286
07_Circulation 003		-	95	-	95
07_Circulation 004		-	77	-	442
07_Circulation 005		-	77	-	534
07_Circulation 006		-	74	-	411
07_Corridor		-	127	-	50
07_Decontamination Room: Inc Bed Washer		-	94	-	248
07_IT Hub 001		189	-	-	325
07_IT Hub 002		198	-	-	226
07_IT Store		63	-	-	890
07_Library/Decontamination		138	-	-	76
07_MEP Plant 001		58	-	-	14982
07_MEP Plant 002		60	-	-	4731
07_MEP Plant 003		60	-	-	139
07_MEP Plant 004		102	-	-	71
07_Stair A		-	66	-	156
07_Stair C 001		-	69	-	160
07_Stair C 002		-	68	-	162
07_Store		74	-	-	162
07_Store: Beds		72	-	-	259
B1_A. WC 001		-	127	-	44
B1_A. WC 002		-	132	-	42

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
B1_A. WC 003		-	122	-	47
B1_A. WC 004		-	134	-	39
B1_A. WC 005		-	126	-	45
B1_BED/FM Lift Lobby 001		-	91	-	190
B1_BED/FM Lift Lobby 002		-	92	-	187
B1_BED/FM Lift Lobby 003		-	92	-	186
B1_BED/FM Lift Lobby 004		-	92	-	186
B1_Bev Bay		-	173	-	16
B1_Bulk Fluid Store		70	-	-	222
B1_Central Consumables St		75	-	-	170
B1_Circulation 001		-	76	-	410
B1_Circulation 002		-	90	-	144
B1_Circulation 003		-	80	-	369
B1_Circulation 004		-	101	-	95
B1_Circulation 005		-	83	-	325
B1_Circulation 006		-	88	-	171
B1_Circulation 007		-	77	-	398
B1_Circulation 008		-	81	-	633
B1_Cleaners 001		128	-	-	37
B1_Cleaners 002		134	-	-	38
B1_Cleaners 003		133	-	-	39
B1_Cleaners 004		139	-	-	37
B1_Cleaning Equipment St		72	-	-	203
B1_Clinical Trials St.		112	-	-	65
B1_Cold Room St		65	-	-	449
B1_Cold St.		111	-	-	73
B1_Cons. St.		131	-	-	49
B1_Controlled Drugs		119	-	-	228
B1_Corridor 001		-	90	-	268
B1_Corridor 002		-	98	-	769
B1_Corridor 003		-	101	-	344
B1_Corridor 004		-	106	-	151
B1_Corridor 005		-	119	-	69
B1_Corridor 006		-	178	-	39
B1_Corridor 007		-	146	-	91
B1_Corridor 008		-	137	-	62
B1_Dispensary		77	-	-	3419
B1_Disposal 001		121	-	-	61
B1_Disposal 002		139	-	-	47
B1_Disposal 003		80	-	-	137
B1_Disposal 004		130	-	-	48
B1_Distribution St.		113	-	-	96
B1_Drug Cupboard Secure		114	-	-	61

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
B1_Dry Goods St		70	-	-	230
B1_Entrance Lobby		-	188	-	19
B1_Eq. Store 001		105	-	-	71
B1_Eq. Store 002		123	-	-	60
B1_Freezer St.		88	-	-	112
B1_Fridge Bariatric		105	-	-	78
B1_Goods Inward		83	-	-	142
B1_IT HUB 001		286	-	-	75
B1_IT HUB 002		303	-	-	66
B1_IT HUB 003		321	-	-	58
B1_IT HUB 004		270	-	-	87
B1_IT HUB 005		264	-	-	91
B1_IT HUB 006		264	-	-	91
B1_Linen		106	-	-	146
B1_Linen & Disposables		118	-	-	45
B1_Lobby 001		-	150	-	61
B1_Lobby 002		-	123	-	80
B1_Management		150	-	-	129
B1_MEP PLANT 001		58	-	-	3263
B1_MEP PLANT 002		78	-	-	846
B1_MEP PLANT 003		68	-	-	379
B1_MEP PLANT 004		66	-	-	429
B1_MEP PLANT 005		74	-	-	216
B1_MEP PLANT 006		67	-	-	395
B1_MEP PLANT 007		74	-	-	241
B1_MEP PLANT 008		73	-	-	225
B1_MEP PLANT 009		73	-	-	223
B1_MEP PLANT 010		68	-	-	366
B1_MEP PLANT 011		76	-	-	198
B1_MEP PLANT 012		78	-	-	852
B1_MEP PLANT 013		67	-	-	397
B1_MEP PLANT 014		77	-	-	189
B1_MEP PLANT 015		73	-	-	234
B1_MEP PLANT 016		75	-	-	207
B1_MEP PLANT 017		73	-	-	227
B1_MEP PLANT 018		69	-	-	350
B1_MEP PLANT 019		67	-	-	410
B1_MEP PLANT 020		70	-	-	327
B1_MEP PLANT 021		65	-	-	602
B1_MEP PLANT 022		77	-	-	249
B1_MEP PLANT 023		72	-	-	245
B1_MEP PLANT 024		67	-	-	390
B1_Micro Fibre Laundry		-	49	-	458

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
B1_Office		146	-	-	100
B1_Office (Admin) 001		117	-	-	204
B1_Office (Admin) 002		159	-	-	84
B1_Office (Managnt) 001		185	-	-	80
B1_Office (Managnt) 002		183	-	-	62
B1_Office (Managnt) 003		187	-	-	63
B1_Office (Managnt) 004		166	-	-	82
B1_Office (Managnt) 005		162	-	-	84
B1_Office: Open Plan 001		106	-	-	148
B1_Office: Open Plan 002		135	-	-	106
B1_Office; Medical Examiner		228	-	-	63
B1_Patient Handling/Body Store		-	65	-	2749
B1_Post Room		87	-	-	285
B1_Prep: Diet Bay		-	88	-	686
B1_Preparation Area		-	99	-	372
B1_Regeneration		-	93	-	423
B1_Secure Goods St		124	-	-	59
B1_Secure Lobby		-	124	-	49
B1_Shower: Staff 001		-	131	-	21
B1_Shower: Staff 002		-	131	-	22
B1_St Clean Consm & Chem		106	-	-	81
B1_Staff Change 001		-	71	-	150
B1_Staff Change 002		-	72	-	148
B1_Staff Lobby		-	94	-	119
B1_Staff Rest/Bev 001		128	-	-	152
B1_Staff Rest/Bev 002		125	-	-	151
B1_Staff Rest/Bev 003		148	-	-	141
B1_Stair		-	124	-	61
B1_Stair A		-	69	-	154
B1_Stair C 001		-	73	-	152
B1_Stair C 002		-	73	-	154
B1_Stair D		-	68	-	159
B1_Store		131	-	-	61
B1_Store: In		62	-	-	581
B1_Store: Out/Transit		65	-	-	338
B1_Switchgear 001		176	-	-	22
B1_Switchgear 002		176	-	-	15
B1_Switchgear 003		176	-	-	44
B1_Switchgear 004		176	-	-	31
B1_Viewing Room		-	170	-	31
B1_Visitor Entrance/Wait		-	147	60	144
B1_Visitor Lift Lobby		-	108	-	136
B1_Wash Area		-	90	-	323

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
B1_Washing Room		-	87	-	127
B1_WC 001		-	134	-	28
B1_WC 002		-	134	-	25
B1_WC 003		-	134	-	28
B1_WC 004		-	134	-	35
B1_WC 005		-	134	-	32
B1_WC 006		-	134	-	28
B1_Workspace		111	-	-	265
01_Lobby 001		-	154	-	39
CP_00_Cafe		-	35	-	1181

Criterion 3: The spaces in the building should have appropriate passive control measures to limit solar gains

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
00_4 Bed Bay 001	NO (-86.9%)	NO
00_4 Bed Bay 002	NO (-86.8%)	NO
00_4 Bed Bay 003	NO (-86.8%)	NO
00_4 Bed Bay 004	NO (-86.8%)	NO
00_4 Bed Bay 005	NO (-60.5%)	NO
00_4 Bed Bay 006	NO (-86.8%)	NO
00_4 Bed Bay 007	NO (-73.1%)	NO
00_4 Bed Bay 008	NO (-59.9%)	NO
00_4 Bed Bay 009	NO (-86.8%)	NO
00_Adult Resus 001	NO (-80.9%)	NO
00_Adult Resus 002	N/A	N/A
00_Adult Resus 003	NO (-89.4%)	NO
00_Adult Resus 004	N/A	N/A
00_Adult Resus 005	N/A	N/A
00_Adult Resus 006	NO (-91.6%)	NO
00_Amb. Triage/Transfer 001	N/A	N/A
00_Amb. Triage/Transfer 002	N/A	N/A
00_Amb. Triage/Transfer 003	N/A	N/A
00_Amb. Triage/Transfer 004	N/A	N/A
00_Amb. Triage/Transfer 005	N/A	N/A
00_Amb. Triage/Transfer 006	N/A	N/A
00_Baby Feed	NO (-74.7%)	NO
00_Beds: Single Room 001	NO (-72.5%)	NO
00_Beds: Single Room 002	NO (-63.4%)	NO
00_Beds: Single Room 003	NO (-46.5%)	NO
00_Beds: Single Room 004	NO (-26.7%)	NO
00_Bier View	N/A	N/A
00_Breast Feed	N/A	N/A
00_C.U. 006	NO (-77.5%)	NO
00_C.U. 009	N/A	N/A

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
00_Cafe	NO (-45.5%)	NO
00_Cashier Office	NO (-29%)	NO
00_CE/Treat 001	N/A	N/A
00_CE/Treat 002	N/A	N/A
00_CE/Treat 003	N/A	N/A
00_CE/Treat 004	N/A	N/A
00_Child Wait	NO (-90.5%)	NO
00_Corridor 024	NO (-86.3%)	NO
00_CT Control	NO (-71.9%)	NO
00_CT Scanner	NO (-86.1%)	NO
00_Decon. Lobby	N/A	N/A
00_E-Triage 001	NO (-99.9%)	NO
00_E-Triage 002	NO (-99.9%)	NO
00_E-Triage 003	NO (-99.9%)	NO
00_Ensuite 001	NO (-97%)	NO
00_Ensuite 002	NO (-89.4%)	NO
00_Ensuite 003	NO (-83.3%)	NO
00_Ensuite 004	NO (-56.9%)	NO
00_Ensuite 005	NO (-84.8%)	NO
00_Ensuite 006	NO (-85.4%)	NO
00_Ensuite 007	NO (-88.9%)	NO
00_Ensuite 008	NO (-41.3%)	NO
00_Ensuite 009	NO (-92.5%)	NO
00_Ensuite 010	N/A	N/A
00_Ensuite 011	NO (-47.8%)	NO
00_Ensuite 012	NO (-88.5%)	NO
00_Ensuite 013	NO (-80.9%)	NO
00_Ensuite 014	NO (-96.6%)	NO
00_Ensuite 015	N/A	N/A
00_Ensuite 016	N/A	N/A
00_Ensuite 017	N/A	N/A
00_Ensuite 018	N/A	N/A
00_Ensuite 019	NO (-81.7%)	NO
00_Ensuite 020	N/A	N/A
00_Ensuite 021	NO (-80.7%)	NO
00_Ensuite 022	NO (-100%)	NO
00_Ensuite 023	NO (-57.5%)	NO
00_Ensuite 024	NO (-96.3%)	NO
00_Ensuite 025	NO (-88.5%)	NO
00_Ensuite 026	N/A	N/A
00_Ensuite 027	NO (-33.1%)	NO
00_Ensuite 028	N/A	N/A
00_Ensuite 029	N/A	N/A
00_Ensuite 030	NO (-40.5%)	NO
00_Ensuite 031	N/A	N/A
00_Ensuite 032	NO (-44.4%)	NO
00_Ensuite 033	NO (-63.2%)	NO
00_Ensuite 034	NO (-81.4%)	NO
00_Ensuite 035	NO (-78.7%)	NO

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
00_Ensuite 036	NO (-87%)	NO
00_Ensuite 037	NO (-50.1%)	NO
00_Ensuite 038	NO (-90.2%)	NO
00_Ensuite 039	N/A	N/A
00_Ensuite 040	NO (-74.9%)	NO
00_Ensuite 041	N/A	N/A
00_Ensuite 042	N/A	N/A
00_Ensuite 043	NO (-92.1%)	NO
00_Ensuite 044	N/A	N/A
00_Ensuite 045	NO (-91.9%)	NO
00_Ensuite 046	N/A	N/A
00_Ensuite 047	N/A	N/A
00_Ensuite 048	NO (-41.6%)	NO
00_Ensuite 049	NO (-82.1%)	NO
00_Ensuite 050	NO (-74.1%)	NO
00_Ensuite 051	N/A	N/A
00_Ensuite 052	N/A	N/A
00_Ensuite 053	NO (-59.2%)	NO
00_Entrance Concourse/Waiting 001	NO (-99.9%)	NO
00_Entrance Concourse/Waiting 002	NO (-99.7%)	NO
00_Entrance Concourse/Waiting 003	NO (-99.6%)	NO
00_Entrance Concourse/Waiting 004	NO (-94.1%)	NO
00_Exam (Decontamination)	NO (-72.3%)	NO
00_Exam/Treat 001	N/A	N/A
00_Exam/Treat 002	N/A	N/A
00_Exam/Treat 003	N/A	N/A
00_Exam/Treat 004	N/A	N/A
00_Exam/Treat 005	N/A	N/A
00_Exam/Treat 006	N/A	N/A
00_Exam/Treat 007	N/A	N/A
00_Exam/Treat 008	N/A	N/A
00_Exam/Treat 009	N/A	N/A
00_Exam/Treat 010	N/A	N/A
00_Exam/Treat 011	N/A	N/A
00_Exam/Treat 012	N/A	N/A
00_Exam/Treat 013	N/A	N/A
00_Exam/Treat 014	N/A	N/A
00_Exam/Treat 015	NO (-85.4%)	NO
00_Exam/Treat 016	N/A	N/A
00_Exam/Treat 017	N/A	N/A
00_Exam/Treat 018	N/A	N/A
00_Exam/Treat 019	NO (-71%)	NO
00_Exam/Treat 020	N/A	N/A
00_Exam/Treat 021	N/A	N/A
00_Exam/Treat 022	NO (-89.8%)	NO
00_Exam/Treat 023	N/A	N/A
00_Exam/Treat 024	NO (-94.2%)	NO
00_Exam/Treat 025	N/A	N/A
00_Exam/Treat 026	N/A	N/A

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
00_Exam/Treat 027	N/A	N/A
00_Exam/Treat 028	NO (-89.2%)	NO
00_Exam/Treat 029	N/A	N/A
00_Exam/Treat 030	N/A	N/A
00_Exam/Treat 031	N/A	N/A
00_Exam/Treat 032	N/A	N/A
00_Exam/Treat 033	NO (-82.2%)	NO
00_Exam/Treat 034	NO (-89.4%)	NO
00_Exam/Treat 035	NO (-85%)	NO
00_Exam/Treat 036	NO (-89.1%)	NO
00_Exam/Treat 037	N/A	N/A
00_Exam/Treat 038	N/A	N/A
00_Exam/Treat 039	N/A	N/A
00_Exam/Treat 040	NO (-100%)	NO
00_Exam/Treat 041	N/A	N/A
00_Exam/Treat 042	N/A	N/A
00_Exam/Treat 043	NO (-24.9%)	NO
00_Exam/Treat 044	N/A	N/A
00_Exam/Treat 045	N/A	N/A
00_Exam/Treat 046	N/A	N/A
00_Exam/Treat 047	N/A	N/A
00_Exam/Treat 048	N/A	N/A
00_Exam/Treat 049	N/A	N/A
00_Exam/Treat 050	NO (-82.4%)	NO
00_Exam/Treat 051	N/A	N/A
00_Exam/Treat 052	NO (-58.7%)	NO
00_Exam/Treat: Mental Health 001	N/A	N/A
00_Exam/Treat: Mental Health 002	N/A	N/A
00_Exam/Treat: Spec Diags 001	N/A	N/A
00_Exam/Treat: Spec Diags 002	N/A	N/A
00_Exam/Treat: Spec Diags 003	NO (-90.6%)	NO
00_Exam/Treat: Spec Diags 004	N/A	N/A
00_Exam/Treat: Spec Diags 005	N/A	N/A
00_Exam/Treat: Specialist Diahs - Gynae	NO (-95.5%)	NO
00_Exam/Treat: US 001	N/A	N/A
00_Exam/Treat: US 002	N/A	N/A
00_Floor Coord.n Hub	N/A	N/A
00_HDU/Larger Bed 001	NO (-46.8%)	NO
00_HDU/Larger Bed 002	NO (-67.2%)	NO
00_HUB/Office	N/A	N/A
00_HUB/Reception	N/A	N/A
00_Interview 001	N/A	N/A
00_Interview 002	N/A	N/A
00_Interview 003	N/A	N/A
00_Interview 004	N/A	N/A
00_Interview 005	N/A	N/A
00_Interview 006	N/A	N/A
00_Interview 007	N/A	N/A
00_Interview 008	N/A	N/A

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
00_Interview 009	N/A	N/A
00_Interview 010	N/A	N/A
00_Interview 011	N/A	N/A
00_Interview 012	N/A	N/A
00_Interview 013	N/A	N/A
00_Interview 014	N/A	N/A
00_Interview 015	N/A	N/A
00_Interview 016	N/A	N/A
00_Interview 017	N/A	N/A
00_Interview 018	N/A	N/A
00_Iso Lobby 001	N/A	N/A
00_Iso Lobby 002	N/A	N/A
00_Iso Lobby 002	N/A	N/A
00_Iso Lobby 003	N/A	N/A
00_Iso Lobby 004	N/A	N/A
00_Iso Lobby 005	N/A	N/A
00_Iso Lobby 006	NO (-100%)	NO
00_IT HUB 001	N/A	N/A
00_IT HUB 002	N/A	N/A
00_IT HUB 003	N/A	N/A
00_IT HUB 004	N/A	N/A
00_IT HUB 005	N/A	N/A
00_Kitchen/Bev Bay	N/A	N/A
00_Lounge W Seating/6 001	NO (-86.8%)	NO
00_Lounge W Seating/6 002	NO (-86.8%)	NO
00_Lounge W Seating/6 003	NO (-88.9%)	NO
00_Lounge W Seating/6 004	NO (-89.8%)	NO
00_Lounge W Seating/10	NO (-86.5%)	NO
00_Lounge W Seating/6 005	NO (-95.5%)	NO
00_MDT Room 001	N/A	N/A
00_MDT Room 002	N/A	N/A
00_MDT Room 003	NO (-70.8%)	NO
00_MDT Room 004	N/A	N/A
00_MDT Room 005	N/A	N/A
00_Med. room	N/A	N/A
00_Milk Kitchen	N/A	N/A
00_Office 001	N/A	N/A
00_Office 002	N/A	N/A
00_Office 003	N/A	N/A
00_Office 004	N/A	N/A
00_Office 005	N/A	N/A
00_Office 006	N/A	N/A
00_Office 007	N/A	N/A
00_Office 008	N/A	N/A
00_Office 009	N/A	N/A
00_Office 010	N/A	N/A
00_Office 011	NO (-72.7%)	NO
00_Office 012	N/A	N/A
00_Office 013	N/A	N/A

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
00_Office (Patch Team)	NO (-76.5%)	NO
00_Office - managers	N/A	N/A
00_Office Complaints	NO (-71.5%)	NO
00_Office Pals	NO (-26.6%)	NO
00_Office: Open Plan	NO (-94.6%)	NO
00_PeAD RESUS 001	N/A	N/A
00_PeAD RESUS 002	N/A	N/A
00_Phleb bay	N/A	N/A
00_Photo Pass Room	N/A	N/A
00_Plaster	N/A	N/A
00_Play	NO (-33%)	NO
00_PoCT 001	N/A	N/A
00_PoCT 002	N/A	N/A
00_PoCT 003	N/A	N/A
00_PoCT 004	N/A	N/A
00_PoCT 005	N/A	N/A
00_PoCT 006	N/A	N/A
00_PoCT 007	N/A	N/A
00_PoCT 008	N/A	N/A
00_PoCT 009	N/A	N/A
00_Police/Security Room	N/A	N/A
00_PTS Office	NO (-92.7%)	NO
00_Radiology Report	N/A	N/A
00_Recep/Wait	N/A	N/A
00_Reception 001	NO (-99.7%)	NO
00_Reception 002	N/A	N/A
00_Reception 003	NO (-95.3%)	NO
00_Reception 004	N/A	N/A
00_Reception/Office	N/A	N/A
00_Reception/Wait	NO (-100%)	NO
00_Recliners	NO (-88.8%)	NO
00_Resus Bay 002	N/A	N/A
00_Security Change	N/A	N/A
00_Security Office	NO (-80.3%)	NO
00_Security Room: CCTV	NO (-70.8%)	NO
00_Seminar	NO (-95.6%)	NO
00_Seminar ED Floor	NO (-83.7%)	NO
00_Shared Treat	N/A	N/A
00_Single Bedroom 001	N/A	N/A
00_Single Bedroom 002	NO (-77.6%)	NO
00_Single Bedroom 003	N/A	N/A
00_Single Bedroom 004	N/A	N/A
00_Single Bedroom 005	N/A	N/A
00_Single Bedroom 006	N/A	N/A
00_Single Bedroom 007	NO (-88.2%)	NO
00_Single Bedroom 008	N/A	N/A
00_Single Bedroom 009	NO (-94.7%)	NO
00_Single Bedroom 010	NO (-87.2%)	NO
00_Single Bedroom 011	NO (-87.1%)	NO

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
00_Single Bedroom 012	NO (-32.3%)	NO
00_Single Bedroom 013	NO (-71.9%)	NO
00_Single Bedroom 014	NO (-86.6%)	NO
00_Single Bedroom 015	NO (-38.2%)	NO
00_Single Bedroom 016	NO (-94.1%)	NO
00_Single Bedroom 017	N/A	N/A
00_Single Bedroom 018	NO (-82.4%)	NO
00_Single Bedroom 019	N/A	N/A
00_Single Bedroom 020	NO (-83.3%)	NO
00_Single Bedroom 021	NO (-36.4%)	NO
00_Single Bedroom 022	NO (-73.2%)	NO
00_Single Bedroom 023	NO (-98.6%)	NO
00_Single Bedroom 024	NO (-88%)	NO
00_Single Bedroom 025	N/A	N/A
00_Single Bedroom 026	NO (-87.5%)	NO
00_Single Bedroom 027	NO (-94.1%)	NO
00_Single Bedroom 028	NO (-94.8%)	NO
00_Single Bedroom 029	NO (-81.2%)	NO
00_Single Bedroom 030	NO (-87.5%)	NO
00_Single Bedroom 031	NO (-61.8%)	NO
00_Single Bedroom 032	NO (-91.2%)	NO
00_Single Bedroom 033	NO (-20%)	NO
00_Single Bedroom 034	NO (-87.9%)	NO
00_Single Bedroom 035	NO (-92.6%)	NO
00_Single Bedroom 036	N/A	N/A
00_Single Bedroom 037	NO (-95.9%)	NO
00_Single Bedroom 038	NO (-93.7%)	NO
00_Single Bedroom 039	NO (-61.9%)	NO
00_Single Bedroom 040	N/A	N/A
00_Single Bedroom 041	N/A	N/A
00_Single Bedroom 042	NO (-88.9%)	NO
00_Sister Office	NO (-80.8%)	NO
00_Staff Base 001	N/A	N/A
00_Staff Base 002	N/A	N/A
00_Staff Base 003	NO (-99.8%)	NO
00_Staff Base 004	N/A	N/A
00_Staff Base 005	N/A	N/A
00_Staff Base 006	N/A	N/A
00_Staff Base 007	N/A	N/A
00_Staff Base 008	N/A	N/A
00_Staff Base 009	N/A	N/A
00_Staff Base 010	N/A	N/A
00_Staff Base 011	N/A	N/A
00_Staff Base 012	NO (-99.2%)	NO
00_Staff Base 013	N/A	N/A
00_Staff Base - Gynae	N/A	N/A
00_Staff Base with Pneumt Tube 001	N/A	N/A
00_Staff Base with Pneumt Tube 002	NO (-97.7%)	NO
00_Staff Base with Pneumt Tube 003	NO (-95.6%)	NO

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
00_Staff Rest 001	NO (-95.3%)	NO
00_Staff Rest002	N/A	N/A
00_Staff Rest/Bev 001	NO (-62.8%)	NO
00_Staff Rest/Bev 002	N/A	N/A
00_Streaming 001	N/A	N/A
00_Streaming 002	N/A	N/A
00_Streaming 003	N/A	N/A
00_Streaming 004	NO (-99.9%)	NO
00_Sub-Wait	N/A	N/A
00_Transport Wait (Inc Transport Liason)	NO (-98.1%)	NO
00_Treat/Plaster	N/A	N/A
00_Treat: Procedures 001	N/A	N/A
00_Treat: Procedures 002	N/A	N/A
00_Treatment 001	N/A	N/A
00_Treatment 002	NO (-73.2%)	NO
00_Treatment (2-sided) 001	N/A	N/A
00_Treatment (2-sided) 002	N/A	N/A
00_Treatment: Proc	N/A	N/A
00_Treatment: Procedures - Gynae	NO (-95.6%)	NO
00_Treatment: Specialist Diags 001	N/A	N/A
00_Treatment: Specialist Diags 002	N/A	N/A
00_Triage	N/A	N/A
00_Triage/Streaming 001	N/A	N/A
00_Triage/Streaming 002	N/A	N/A
00_Triage/Streaming 003	N/A	N/A
00_Triage/Streaming 004	N/A	N/A
00_Ultrasound	N/A	N/A
00_Unit Office	N/A	N/A
00_Unit Pantry 001	N/A	N/A
00_Unit Pantry 002	N/A	N/A
00_Unit Pantry 003	N/A	N/A
00_Wait 001	N/A	N/A
00_Wait 002	NO (-96.5%)	NO
00_Wait 003	NO (-86.8%)	NO
00_Wait 004	NO (-91.2%)	NO
00_Wait 005	N/A	N/A
00_Waiting: 15 places 001	NO (-65.6%)	NO
00_Waiting; 15 places002	N/A	N/A
00_Waiting: 4 places	NO (-99.9%)	NO
00_Waiting: 5 places	NO (-99.9%)	NO
00_Waiting: Bed Bay 001	NO (-94%)	NO
00_Waiting: Bed Bay 002	N/A	N/A
00_Waiting: Bed Bay 003	NO (-99.8%)	NO
00_Waiting: Bed Bay 004	NO (-92%)	NO
00_Waiting: Bed Bay 005	NO (-99.7%)	NO
00_Waiting: Bed Bay 006	NO (-92.6%)	NO
00_X-Ray 001	NO (-78.1%)	NO
00_X-Ray 002	N/A	N/A
00_X-Ray 003	N/A	N/A