

**Proposed Installation of
Mechanical Plant**

**234 Bath Road, Heathrow,
London, UB5 3AP.**

Environmental Noise Assessment

Author: Andy Dodd B.Sc. (Hons) MIOA
Senior Consultant

Doc Ref: 104783.ad.Issue1



Proposed Installation of Mechanical Plant

Project Address:	234 Bath Road Heathrow London UB3 5AP
Project Reference:	104783

Issue/Revision Record

Issue:	Date:	Remarks:	Author:
1	14/10/2025	First Issue	Andy Dodd

	Print:	Title:	Date:
Author:	Andy Dodd	Senior Consultant	14/10/2025
Reviewer:	Phil Huffer	Principal Consultant	14/10/2025

1. INTRODUCTION

- 1.1 Acoustics Plus Ltd (APL) is an independent firm of multi-disciplinary acoustic engineers. APL is engaged by both private and public sector clients. APL is a registered member of The Association of Noise Consultants (ANC) and the author is a corporate member of The Institute of Acoustics (IOA).
- 1.2 APL has been instructed by the applicant's planning consultant, Total Planning, to consider and advise upon the noise implications of a proposed installation of mechanical plant.
- 1.3 The building services plant will be located within two dedicated roof top plant areas located on the eastern and western sides of the new hotel extension.
- 1.4 It is understood the Local Planning Authority (LPA) require further information on noise levels from the proposed installation in order to fully assess the noise impact upon the surrounding neighbourhood. This report provides the response to the LPA, on behalf of the Applicant.
- 1.5 This report has been prepared by Acoustics Plus Limited (APL) with all reasonable skill, care, and diligence in accordance with generally accepted acoustic consultancy principles and taking account the services and terms agreed between APL and our client.
- 1.6 Any information provided by third-parties and referred to herein may not have been checked or verified by APL unless expressly stated otherwise. Certain statements made in the report are predictions based on reasonable assumptions and good industry practice.
- 1.7 Such statements involve risk and uncertainty which could cause measured and predicted results to differ materially. APL does therefore not guarantee or warrant any prediction contained in this report.

2. BASELINE SITUATION

- 2.1 The Application Site (the "site") is situated at 234 Bath Road, Heathrow, London, UB3 5AP. The site is a four storey hotel extension. The site and its surroundings are shown in Figures 1 to 8 appended to this report.
- 2.2 It is understood that planning consent has been granted for the proposed development. The scheme comprises the construction of a four-storey hotel extension providing additional guest accommodation, linked to the existing building via a covered bridge structure, together with associated ancillary works. The development will incorporate mechanical plant comprising two air handling units (AHUs) and eight condenser units, to be distributed across two designated rooftop plant zones located on the western and eastern elevations of the proposed building. The site location plan is shown in Diagram 1 below.




Diagram 1

- 2.3 The location of the new hotel extension building is highlighted in green within Diagram 1 above.
- 2.4 The nearest noise sensitive façade with line of sight to the location of the proposed AHU's intake and exhaust grilles will be the rear façade windows of the property located at no.22 Boltons Lane. No.22 Boltons Lane will not have line of sight of the condensers due to the positioning of the condensers within the two roof top light wells.
- 2.5 There are residential dwellings located west of the site but these properties are located at a greater distance, so there will be lower noise impact at these properties.

3. NOISE OUTLINE

- 3.1 In order to produce an environmental noise assessment, consideration must be given to the prevailing background noise in the locality of the installation.
- 3.2 Measurements of background noise were obtained over a 24 hour period at a location deemed representative of background noise levels experienced at the northern boundary of the site. Measurements were obtained at the location seen in Photo 1 below:



Photo 1

- 3.3 The particulars of the measurement exercise are recorded below. The weather conditions were considered appropriate to monitor environmental noise.

Date: 11th & 12th August 2025.
Start Time: 11:29 hrs.
Location: Northern boundary of site (MP1 - see Photo1).

- 3.4 Minimum background and average noise levels are shown in Table 1 below with the full 24 hour time history shown in Diagram 2 (L_{Aeq} and L_{A90}).

Time period	Lowest $L_{A90,15min}$	Average $L_{Aeq,T}$
07:00-23:00hrs	43dB	56dB
23:00-07:00hrs	40dB	52dB

Table 1




Diagram 2

4. DESIGN CRITERIA

4.1 Information regarding the noise levels not to be exceeded by the proposed installation was provided by London Borough of Hillingdon (Planning Permission reference 41331/APP/2016/1035).

Condition 6

"The rating level of the noise emitted from the site shall be at least 5dB below the existing background noise level. The noise levels shall be determined at the boundary of the nearest residential property. The measurements and assessment shall be made in accordance to the latest British Standard 4142, 'Method for rating industrial noise affecting mixed residential and industrial areas.'"

4.2 This assessment shall reference BS4142:2014+A1:2019 'Methods for rating and assessing industrial and commercial sound' to determine the noise impact.

4.3 The procedure contained in BS4142 is to quantify the "specific sound level", which is the measured or predicted level of sound from the source in question over a one hour period for the daytime and a 15 minute period for the night-time. Daytime is defined in the standard as 07:00 to 23:00 hours, and night-time as 23:00 to 07:00 hours.

4.4 The specific sound level is converted to a rating level by adding penalties to account for either tonality or impulsivity. The standard sets out objective methods for determining the presence of tones or impulsive elements, but notes that it is acceptable to subjectively determine these effects.

4.5 The penalty for tonal elements is between 0dB and 6dB, and the standard notes:

"Subjectively, this can be converted to a penalty of 2 dB for a tone which is just perceptible at the noise receptor, 4 dB where it is clearly perceptible, and 6 dB where it is highly perceptible."

4.6 The penalty for impulsive elements is between 0dB and 9dB, and the standard notes:

"Subjectively, this can be converted to a penalty of 3 dB for impulsivity which is just perceptible at the noise receptor, 6 dB where it is clearly perceptible, and 9 dB where it is highly perceptible."

4.7 The background sound level should be established in terms of the LA90 noise index. The standard states that the background sound level should be measured over a period of sufficient length to obtain a representative value. This should not normally be less than 15 minute intervals. The standard states that:

"A representative level ought to account for the range of background sound levels and ought not automatically to be assumed to be either the minimum or modal value."

4.8 The assessment outcome results from a comparison of the rating level with the background sound level. The standard states:

- a) *Typically, the greater this difference, the greater the magnitude of the impact.*
- b) *A difference of around +10 dB or more is likely to be an indication of a significant adverse impact, depending on the context.*
- c) *A difference of around +5 dB is likely to be an indication of an adverse impact, depending on the context.*
- d) *The lower the rating level is relative to the measured background sound level, the less likely it is that the specific sound source will have an adverse impact or a significant adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact, depending on the context.*

"Adverse impacts include, but are not limited to, annoyance and sleep disturbance. Not all adverse impacts will lead to complaints and not every complaint is proof of an adverse impact."

4.9 The standard goes on to note that:

"Where background sound levels and rating levels are low, absolute levels might be as, or more, relevant than the margin by which the rating level exceeds the background. This is especially true at night."

4.10 In addition to the margin by which the Rating Level of the specific sound source exceeds the Background Sound Level, the 2014 edition places emphasis upon an appreciation of the context, as follows:

"An effective assessment cannot be conducted without an understanding of the reason(s) for the assessment and the context in which the sound occurs/will occur. When making assessments and arriving at decisions, therefore, it is essential to place the sound in context."

4.11 The background noise levels were assessed using statistical analysis of the measured data, as directed in BS4142. The histogram for the more noise sensitive night time period can be seen in Diagram 3.




Diagram 3

4.12 The background noise level varied during the measurement period.. Given all plant could operate on demand during the day or night period, it is considered that a background sound level of 43dB LA₉₀ obtained during the more noise sensitive night time period is deemed appropriate for the assessment.

4.13 The plant noise emission criteria that should not be exceeded is therefore as follows and represents 5dBA below the background noise level.

Noise emission limit for mechanical plant

LA_{eq} 38dB

Table 2

4.14 The mechanical plant that is proposed to be installed is detailed below (data sheets provided in Appendix A):

- 2no. ASHP units – Aircraft Air Handling ACAH50 at L_{WA} 49dB
- 8no. condensers – Mitsubishi PURY-M400YNW-A1 at 65dBA @1m (per unit)

4.15 The location of the roof lightwells are highlighted within Diagram 4 below:




Diagram 4

4.16 One AHU unit and 4no. condensers will be located within each of the east and west plant rooms/lightwells. A section and plan drawing of the east plant room lightwell are provided below with the west plant room lightwell mirroring the same layout.




Diagram 5- east plant room/lightwell plan




Diagram 6 – east plant room/lightwell section

5. EQUIPMENT

5.1 All background noise measurements were obtained using the following equipment:

- Rion NA-28 Class 1 Serial No. 00370311
- Rion Calibrator Type NC-74 Class 1 Serial No. 00410215

5.2 The relevant equipment carries full and current traceable calibration. The equipment, where necessary, was calibrated prior to and after the measurements were carried out.

6. CALCULATIONS

6.1 A prediction exercise for the AHU's was undertaken. The calculation exercise utilised information provided by equipment manufacturer – Aircraft Air Handling (copy of the data sheet is provided in Appendix A).

6.2 Throughout the calculation exercise, guidance and formula were extracted from the publication "*Noise Control in Building Services*" (published by SRL).

6.3 The AHU attenuation was calculated by considering the stated sound energy produced by each component of the system. The AHU's will feature attenuation on the exhaust air outlet side of each unit to reduce the in-duct sound power levels. A 600mm long attenuator providing the following octave band performance levels will be required:

AHU exhaust side	Octave Band Centre Frequency (Hz)							
	63	125	250	500	1k	2k	4k	8k
600mm long attenuator	6	8	12	22	28	27	21	14

Table 3

6.4 Noise leaving the AHU's was propagated to the nearest noise sensitive façade using point source propagation.

6.1 Detailed calculations identifying the air intake and exhaust air noise impacts are contained in Appendix B.

6.2 A prediction exercise was also undertaken for the noise output from the condenser units. The calculation exercise utilised information provided by the equipment manufacturer Mitsubishi.

6.3 The total attenuation was calculated by considering distance attenuation from the location of the plant. Noise leaving each unit was propagated over the relevant distance to the nearest noise sensitive façade using point source propagation.

6.4 No correction has been applied to account for any reflecting planes below or adjacent to the proposed condenser units as the plant room light well floor and walls housing the units will be treated with an absorbent material to control reflected sound. The system should provide Class A rated level absorption – suitable material providers can be found at:

- <https://www.cmsdanskin.co.uk/industrial-construction/industrial-acoustic-wall-linings/plant-room-acoustic-wall-lining-panels/>
- <https://www.quietstone.co.uk/product/acoustic-panels/>

6.5 A correction to account for building edge diffraction was assumed. This was extracted from the recently updated (20th March 2025) Microgeneration Certification Scheme MCS020 a) Issue1.0 (For Permitted Development Installations). The standard MCS020a states the following:

A correction shall be made for attenuation due to barriers between the heat pump and an assessment position. The construction of the barrier and the line of sight between the heat pump and assessment position shall both be taken into account to determine the attenuation of the barrier.

The following definitions of a barrier shall be used for the purposes of the assessment

Barrier (Type 1) - a solid brick/masonry wall or a solid fence that is at least 18mm thick. There should be no cracks or gaps in the barrier. The barrier should extend horizontally by 1m or more from either edge of the heat pump.

Barrier (Type 2) – a solid fence that is less than 18mm thick. There should be no cracks or gaps in the barrier. The barrier should extend horizontally by 1m or more from either edge of the heat pump.

No barrier – open fences, fences with gaps and cracks, and vegetation do not count as a barrier. Walls or fences in a poor state of repair (e.g. gaps or pieces missing) do not count as a barrier.

The following definitions of line of sight shall be used for the purposes of the assessment.

- *No view – If a barrier that completely obscures the vision of an assessment position from the top edge of the heat pump.*
- *Partial view – If by moving up to 0.25m in any direction from the top edge of the heat pump the assessment position is visible.*
- *Full view – If the assessment position is visible from the top edge of the heat pump.*

The matrix table below shall be used in conjunction with the above definitions to determine the barrier attenuation.

Barrier Type	Line of Sight		
	No view	Partial View	Full view
Type 1	-10 dB	-5 dB	0 dB
Type 2	-5 dB	-2.5 dB	0 dB
No barrier	0 dB	0 dB	0 dB

Table 4

6.6 A Type 1 barrier will provide suitable screening such that the upper floor windows of the dwelling at 22 Boltons Lane will have no direct line of sight with the condenser units. For the purposes of this report it has been assumed that the additional 10dB attenuation provided by the roof construction (Type 1 barrier) would be of a type in line with this Standard.

6.7 Where relevant, the octave band sound levels of the proposed plant does not indicate any tonal components and as the condenser units are inverter driven there should not be any sharp onset of sound upon startup. All condenser units will be operated on demand basis at any time of the day or night, intermittent noise from their operation may be sufficient enough to attract attention.

6.8 The calculation exercise is shown in Tables 5-8 below.

AHU's noise impact	Octave Band Centre Frequency (Hz)								L_p dBA
	63	125	250	500	1k	2k	4k	8k	
Air inlet intake (east)	11	18	23	21	19	12	9	6	23
Exhaust air outlet (east)	10	18	19	11	8	6	8	12	17
Air inlet intake (west)	4	11	16	15	13	6	3	0	17
Exhaust air outlet (west)	3	12	12	5	2	0	2	6	11

Table 5

Calculation steps – east light well condensers		L_p dBA
1no. Mitsubishi PURY-M400YNW-A1 at 1m		65
4no. Mitsubishi PURY-M400YNW-A1 at 1m		71
Distance attenuation over 77m		-38
Reflecting plane correction		+0
Diffraction (no line of sight / type 1 barrier)		-10
BS4142 feature corrections (intermittency)		+3
Rating noise level at nearest noise sensitive façade		26dBA

Table 6

Calculation steps – west light well condensers		L_p dBA
1no. Mitsubishi PURY-M400YNW-A1 at 1m		65
4no. Mitsubishi PURY-M400YNW-A1 at 1m		71
Distance attenuation over 40m		-32
Reflecting plane correction		+0
Diffraction (no line of sight / type 1 barrier)		-10
BS4142 feature corrections (intermittency)		+3
Rating noise level at nearest noise sensitive façade		32dBA

Table 7

Calculation steps – all plant combined		L_p dBA
AHU air inlet east lightwell (Table 5)		23
AHU exhaust air outlet east lightwell (Table 5)		17
AHU air inlet west lightwell (Table 5)		17
AHU exhaust air outlet west lightwell (Table 5)		11
East lightwell condensers (Table 6)		26
West lightwell condensers (Table 7)		32
Rated noise level of all units at nearest noise sensitive façade		34dBA

Table 8

- 6.9 In order to comply with the requirements of the LPA, any noise from the proposed installation of mechanical plant should not exceed a rated level of 38dBA at 1m from the nearest noise sensitive façade.
- 6.10 The noise impact from the proposed installation meets the rated noise requirements of the LPA.

7. CONCLUSION

- 7.1 The foregoing assessment indicates that the proposed installation will meet the requirements imposed by the LPA. Additional mitigation measures, other than those included in the design will not be required.
- 7.2 If an alternative AHU or condenser unit is installed, the acoustic performance should be checked prior to installation to ensure that the installation will still meet the requirements imposed by the LPA.
- 7.3 It is also recommended that the units are positioned on vibration isolation mounts to minimise structural borne vibration and re-radiated noise into the building.

Figures

234 Bath Road, Heathrow, London, UB3 5AP



Figure 1



Figure 2



Figure 3



Figure 4



Figure 5



Figure 6



Figure 7









Figure 8

Appendix A

Measurement condition
PURY-M350, 400, 450YNW-A1(-BS)

Sound level of PURY-M450YNW-A1(-BS)

Sound level of PURY-M350YNW-A1(-BS)

Sound level of PURY-M400YNW-A1(-BS)


- Depending on the operation conditions, the unit generates noise caused by valve actuation, refrigerant flow, and pressure changes when operating normally. Please consider to avoid location where quietness is required.
- For HBC controller, it is recommended to be installed in places such as ceilings of corridor, rest rooms and plant rooms.

Quotation Reference : 25283-01A
Project Reference : Novotel Heathrow
Unit Reference : AHU 01 & 02
Date : 10 Sep 2025

TECHNICAL SCHEDULE


UNIT CONSTRUCTION											
Panel Thickness		Panel Insulation		Framework							
45 mm		Rockwool 45mm 45kg/m3		Anodised Aluminium Tube							
Panel External Sheet		Panel Internal Sheet		Base Frame							
0.7mm Goosewing Grey Plastisol		0.9mm Galvanised Steel		Anodised Base Frame							
Access Side		Unit Model		Roof Type							
Right		812		Cross Break							
SECTION WEIGHTS AND DIMENSIONS											
Section No.	Length	Width	Height	Weight							
A	800 mm	1200 mm	800 mm	89 kg							
B	1400 mm	1200 mm	1700 mm	274 kg							
C	800 mm	1200 mm	900 mm	109 kg							
D	800 mm	1200 mm	800 mm	79 kg							
E	800 mm	1200 mm	900 mm	119 kg							
OVERALL UNIT DIMENSIONS AND CENTRE OF GRAVITY											
Length	Width	Height Incl. Base	Weight	COG X							
3000 mm	1200 mm	1700 mm	669 kg	1455 mm							
001 INLET SECTION											
Air Flow	Damper		Operations								
1.1 m³/s	None		Motorised by Others								
Air Velocity	Damper Material		Damper depth								
1.43 m/s	Aluminium		0 mm								
Pressure Drop	Damper Type		Dimension								
4 Pa	Opposed		1130 x 750 mm								
002 BAG FILTER											
Type	Class		Withdrawal								
Synthetic Bag	ISO ePM2.5 65% / (F7 EN779)		Side								
Clean Pressure Drop	Mean Pressure Drop		Dirty Pressure Drop								
55 Pa	120 Pa		185 Pa								
Qty/Size1	Qty/Size2		Qty/Size3								
1 x 592 x 592 x 380 mm	1 x 492 x 592 x 380 mm		N/A								
002 ACCESSORIES											
Magnehelic gauge (0-250pa) fitted											
003 PLATE HEAT EXCHANGER											
Model			Qty	Material							
AM AL 08 N 1100 C 1 AE SC DBBD120			1	1 Aluminum (AL)							
WINTER											
Fresh Air				Exhaust Air							
m³/h	kW	Eff.%	Inlet	Outlet	Pa	m³/h	kW	Eff.%	Inlet	Outlet	Pa
			°C	%					°C	%	

3960	25.85	75.00	-5.00	100.0	14.50	24.62	180	3960	25.85	75.00	21.00	50.0	6.13	98.90	187
------	-------	-------	-------	-------	-------	-------	-----	------	-------	-------	-------	------	------	-------	-----

003 DRAIN PAN

Material	Size
Stainless Steel (304)	1100 mm

004 PLENUM FAN

Fan Type	Wheel Type							
Plenum	Backward Curve							
Model	Impeller Diam.							
GR35I-ZID.DG.CR-116893/A01	350 mm							
Quantity		Duty % Per Fan						
1			Single Fan					
Air Flow Volume	Outlet Velocity	Motor Speed						
1.1 m³/s	1.4 m/s		3410 rpm					
Ext Static Pressure	Fan Speed	Power						
350 Pa	2291 rpm		3.30 kW					
Unit Static Pressure	Static Efficiency	FLC						
654 Pa	67.94%		5.40 A					
Fan Total Pressure	VSD	Volts/Ph/Hz						
675 Pa	0-10v		400/3/50					
Drive Type	Abs Power	Poles						
Direct Drive	1.06 kW							
Frequency	63 Hz	125 Hz	250 Hz	500 Hz	1k Hz	2k Hz	4k Hz	8k Hz
Inlet (1)	66	68	71	69	64	61	58	57
Outlet (2)	67	73	76	74	74	71	66	63

(1) SWL INSIDE The Inlet Duct (dB)

(2) SWL INSIDE The Outlet Duct (dB)

004 ACCESSORIES

Inlet guard	
Fan Seal	
Fan Arrow right symbol	

005 OUTLET SECTION


Air Flow	Damper	Operations	Weatherhood
3960 m³/h	None	Motorised by Others	Hole
Air Velocity	Damper Material	Damper Depth	Motor Torque
1.43 m/s	Aluminium	0 mm	3 N/m
Pressure Drop	Damper Type	Damper Dimension	
0 Pa	Opposed	1130 x 750 mm	

006 INLET SECTION

Air Flow	Damper	Operations	Inlet
1.1 m³/s	None	Motorised by Others	Hole
Air Velocity	Damper Material	Damper depth	Motor Torque
1.43 m/s	Aluminium	0 mm	3 N/m
Pressure Drop	Damper Type	Dimension	
0 Pa	Opposed	1130 x 750 mm	

007 BAG FILTER			
Type	Class	Withdrawal	Velocity
Synthetic Bag	ISO ePM10 60% / (M5 EN779)	Side	1.71 m/s
Clean Pressure Drop	Mean Pressure Drop	Dirty Pressure Drop	Qty of Spare Sets of Filter
26 Pa	83 Pa	140 Pa	0
Qty/Size1	Qty/Size2	Qty/Size3	Qty/Size4
1 x 592 x 592 x 380 mm	1 x 492 x 592 x 380 mm	N/A	N/A

007 ACCESSORIES			
Magnehelic gauge (0-250pa) fitted			

008 PLENUM FAN			
Fan Type	Wheel Type		
Plenum	Backward Curve		
Model	Impeller Diam.		
GR35I-ZID.DG.CR-116893/A01	350 mm		
Quantity	Duty % Per Fan		
1	Single Fan		
Air Flow Volume	Outlet Velocity		
1.1 m³/s	1.4 m/s		
Ext Static Pressure	Fan Speed		
350 Pa	2259 rpm		
Unit Static Pressure	Static Efficiency		
624 Pa	67.63%		
Fan Total Pressure	VSD		
644 Pa	0-10v		
Drive Type	Abs Power		
Direct Drive	1.01 kW		
Frequency	63 Hz	125 Hz	250 Hz
Inlet (1)	66	68	70
Outlet (2)	67	73	75
(1) SWL INSIDE The Inlet Duct (dB)		(2) SWL INSIDE The Outlet Duct (dB)	

008 ACCESSORIES			
Inlet guard			
Fan Seal			
Fan Arrow left symbol			

009 OUTLET SECTION			
Air Flow	Damper	Operations	Weatherhood
3960 m³/h	None	Motorised by Others	Weather Louvre
Air Velocity	Damper Material	Damper Depth	Motor Torque
1.43 m/s	Aluminium	0 mm	3 N/m
Pressure Drop	Damper Type	Damper Dimension	
4 Pa	Opposed	1130 x 750 mm	

AHU ACOUSTIC DATA SUPPLY SECTION									
Description	63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz	Overall dB(A)
Outlet Sound Power(dB)	65	69	70	69	71	68	63	60	75
Inlet Sound Power(dB)	62	62	62	57	54	46	43	40	59
Airborne sound power (dB)	49	50	47	45	47	38	30	30	49

AHU ACOUSTIC DATA EXHAUST SECTION									
Description	63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz	Overall dB(A)
Outlet Sound Power(dB)	65	69	69	69	71	67	63	60	74
Inlet Sound Power(dB)	62	62	61	57	54	45	43	40	59
Airborne sound power (dB)	49	50	46	45	47	37	30	30	49

SPECIFIC FAN POWER

Supply Fan		Extract Fan	
Filter Conditions	Clean	Filter Conditions	Clean
Absorbed Power	.96 kW	Absorbed Power	.93 kW
Drive Efficiency	100%	Drive Efficiency	100%
Inverter Efficiency	100%	Inverter Efficiency	100%
Motor Efficiency	100%	Motor Efficiency	100%
Air Volume	1.1 m ³ /s	Air Volume	1.1 m ³ /s
AHU SFP	1.72 w/l/s		

Appendix B

CONTRACT TITLE: 234 Bath Road
SOUND SOURCE: AHU 01 (west plantroom) supply inlet
Make and model Aircraft Air Handling ACAH50

OCTAVE BAND CENTRE FREQUENCY (Hz)													
OVERALL Lw		Lw	63	125	250	500	1k	2k	4k	8k	dBA		
1		Grille area	1.000										
2		Lw entering grille		62	62	62	57	54	46	43	40		
3											59		
4													
5	LENGTH (m)	C or R	x (mm)	x (mm)									
6	3.50	R	400-800	400-800	5.74	4.62	2.31	1.12	1.12	1.12	1.12		
7													
8													
9													
10													
11													
12													
13													
14													
15													
16	BENDS												
17	NUMBER	TYPE	SIZE (mm)										
18	0	90	0600-0700		0.00	0.00	0.00	0.00	0.00	0.00	0.00		
19													
20													
21													
22													
23													
24													
25	BRANCHES												
26	Size of branch 1		100		0	0	0	0	0	0	0		
27	Size of branch 2		0										
28	Size of branch 3		100		0	0	0	0	0	0	0		
29	Size of branch 4		0										
30	DUCT X-SECTIONAL AREAS												
31													
32													
33	OTHER ATTENUATION												
34													
35													
36													
37													
38	END REFLECTION SIZE (m)												
39	0.201 - 0.300			8	3	1	0	0	0	0	0		
40													
41	Lw LEAVING SYSTEM				48	54	59	56	53	45	42		
42	Room Volume (m ³)		10000000		-56	-56	-56	-56	-56	-56	-56		
43	Mid-Frequency RT (s)		0.01		-20	-20	-20	-20	-20	-20	-20		
44	REVERBERANT SPL				-28	-22	-17	-20	-23	-31	-34		
45	Distance to Listener		34		-42	-42	-42	-42	-42	-42	-42		
46	Q=1 in free space		n/a		0	0	0	0	0	0	0		
47	Q=2 flush with surface		0.086 - 0.430		4	5	6	7	8	9	9		
48	Q=4 junction with 2 surfaces		n/a		0	0	0	0	0	0	0		
49	DIRECT SPL				11	18	23	21	19	12	9		
50	RESULTANT TOTAL SPL				11	18	23	21	19	12	9		
51	NR ACHIEVED/REQUIRED		19		63	52	45	39	35	32	30		
52	Additional Attenuation Required				0	0	0	0	0	0	0		

CONTRACT TITLE: 234 Bath Road
SOUND SOURCE: AHU 01 (west plantroom) exhaust outlet
Make and model Aircraft Air Handling ACAH50

OCTAVE BAND CENTRE FREQUENCY (Hz)										
OVERALL Lw		63	125	250	500	1k	2k	4k	8k	dBA
1	Lw	65	69	69	69	71	67	63	60	74
2	Grille area	1.000								
3	Lw entering grille	65	69	69	69	71	67	63	60	74
4										
5	LENGTH (m)	C or R	x (mm)	x (mm)						
6	2.00	R	400-800	400-800	3.28	2.64	1.32	0.64	0.64	0.64
7										
8										
9										
10										
11										
12										
13										
14										
15										
16	BENDS									
17	NUMBER	TYPE	SIZE (mm)							
18	0	90	0600-0700		0.00	0.00	0.00	0.00	0.00	0.00
19										
20										
21										
22										
23										
24										
25	BRANCHES									
26	Size of branch 1	100			0	0	0	0	0	0
27	Size of branch 2	0								
28	Size of branch 3	100			0	0	0	0	0	0
29	Size of branch 4	0								
30	DUCT X-SECTIONAL AREAS									
31										
32										
33	OTHER ATTENUATION									
34	600mm long attenuator			6	8	12	22	28	27	21
35										
36										
37										
38	END REFLECTION SIZE (m)									
39	0.201 - 0.300			8	3	1	0	0	0	0
40										
41	Lw LEAVING SYSTEM				48	55	55	46	42	39
42	Room Volume (m ³)	10000000			-56	-56	-56	-56	-56	-56
43	Mid-Frequency RT (s)	0.01			-20	-20	-20	-20	-20	-20
44	REVERBERANT SPL				-28	-21	-21	-30	-34	-37
45	Distance to Listener	36			-42	-42	-42	-42	-42	-42
46	Q=1 in free space	n/a			0	0	0	0	0	0
47	Q=2 flush with surface	0.086 - 0.430			4	5	6	7	8	9
48	Q=4 junction with 2 surfaces	n/a			0	0	0	0	0	0
49	DIRECT SPL				10	18	19	11	8	6
50	RESULTANT TOTAL SPL				10	18	19	11	8	6
51	NR ACHIEVED/REQUIRED	20			63	52	45	39	35	32
52	Additional Attenuation Required				0	0	0	0	0	0

CONTRACT TITLE: 234 Bath Road
SOUND SOURCE: AHU 02 (east plantroom) supply inlet
Make and model Aircraft Air Handling ACAH50

OCTAVE BAND CENTRE FREQUENCY (Hz)											
OVERALL Lw		Lw	63	125	250	500	1k	2k	4k	8k	dBA
1		Grille area	1.000								
2		Lw entering grille		62	62	62	57	54	46	43	40
3											59
4											
5	LENGTH (m)	C or R	x (mm)	x (mm)							
6	3.50	R	400-800	400-800	5.74	4.62	2.31	1.12	1.12	1.12	1.12
7											
8											
9											
10											
11											
12											
13											
14											
15											
16	BENDS										
17	NUMBER	TYPE	SIZE (mm)								
18	0	90	0600-0700		0.00	0.00	0.00	0.00	0.00	0.00	0.00
19											
20											
21											
22											
23											
24											
25	BRANCHES										
26	Size of branch 1		100		0	0	0	0	0	0	0
27	Size of branch 2		0								
28	Size of branch 3		100		0	0	0	0	0	0	0
29	Size of branch 4		0								
30	DUCT X-SECTIONAL AREAS										
31											
32											
33	OTHER ATTENUATION										
34											
35											
36											
37											
38	END REFLECTION SIZE (m)										
39	0.201 - 0.300			8	3	1	0	0	0	0	0
40											
41	Lw LEAVING SYSTEM			48	54	59	56	53	45	42	39
42	Room Volume (m ³)		1000000		-56	-56	-56	-56	-56	-56	-56
43	Mid-Frequency RT (s)		0.01		-20	-20	-20	-20	-20	-20	-20
44	REVERBERANT SPL			-28	-22	-17	-20	-23	-31	-34	-37
45	Distance to Listener		74		-48	-48	-48	-48	-48	-48	-48
46	Q=1 in free space		n/a		0	0	0	0	0	0	0
47	Q=2 flush with surface		0.086 - 0.430		4	5	6	7	8	9	9
48	Q=4 junction with 2 surfaces		n/a		0	0	0	0	0	0	0
49	DIRECT SPL			4	11	16	15	13	6	3	0
50	RESULTANT TOTAL SPL			4	11	16	15	13	6	3	0
51	NR ACHIEVED/REQUIRED		13		63	52	45	39	35	32	28
52	Additional Attenuation Required			0	0	0	0	0	0	0	0

CONTRACT TITLE: 234 Bath Road
SOUND SOURCE: AHU 02 (east plantroom) exhaust outlet
Make and model Aircraft Air Handling ACAH50

OCTAVE BAND CENTRE FREQUENCY (Hz)										
OVERALL Lw		63	125	250	500	1k	2k	4k	8k	dBA
1	Lw	65	69	69	69	71	67	63	60	74
2	Grille area	1.000								
3	Lw entering grille	65	69	69	69	71	67	63	60	74
4										
5	LENGTH (m)	C or R	x (mm)	x (mm)						
6	2.00	R	400-800	400-800	3.28	2.64	1.32	0.64	0.64	0.64
7										
8										
9										
10										
11										
12										
13										
14										
15										
16	BENDS									
17	NUMBER	TYPE	SIZE (mm)							
18	0	90	0600-0700		0.00	0.00	0.00	0.00	0.00	0.00
19										
20										
21										
22										
23										
24										
25	BRANCHES									
26	Size of branch 1	100			0	0	0	0	0	0
27	Size of branch 2	0								
28	Size of branch 3	100			0	0	0	0	0	0
29	Size of branch 4	0								
30	DUCT X-SECTIONAL AREAS									
31										
32										
33	OTHER ATTENUATION									
34	600mm long attenuator			6	8	12	22	28	27	21
35										
36										
37										
38	END REFLECTION SIZE (m)									
39	0.201 - 0.300			8	3	1	0	0	0	0
40										
41	Lw LEAVING SYSTEM			48	55	55	46	42	39	41
42	Room Volume (m ³)	10000000		-56	-56	-56	-56	-56	-56	-56
43	Mid-Frequency RT (s)	0.01		-20	-20	-20	-20	-20	-20	-20
44	REVERBERANT SPL			-28	-21	-21	-30	-34	-37	-35
45	Distance to Listener	76		-49	-49	-49	-49	-49	-49	-49
46	Q=1 in free space	n/a		0	0	0	0	0	0	0
47	Q=2 flush with surface	0.086 - 0.430		4	5	6	7	8	9	9
48	Q=4 junction with 2 surfaces	n/a		0	0	0	0	0	0	0
49	DIRECT SPL			3	12	12	5	2	0	2
50	RESULTANT TOTAL SPL			3	12	12	5	2	0	2
51	NR ACHIEVED/REQUIRED	13	35	63	52	45	39	35	32	30
52	Additional Attenuation Required			0	0	0	0	0	0	0