


Block Compliance



Block Reference	BC-83	Issued on Date	15/05/2023
Block Name			
Calculation Type	New Build (As Designed)		

Assessor Details	Mr. Dominic Bibby	Assessor ID	U683-0001
Client			

Block Compliance Report - DER

Block Reference: BC-83		Block Name:		
Property-Assessment Reference	Floor area (m ²)	DER (kgCO ₂ /m ²)	TER (kgCO ₂ /m ²)	% DER/TER
BC-83 plot 1 - BC-83 plot 1	125.00	3.75	8.90	57.87 %
BC-83 plot 2 - BC-83 plot 2	125.00	3.48	8.23	57.72 %
BC-83 plot 3 - BC-83 plot 3	76.10	4.80	9.65	50.26 %
BC-83 plot 4 - BC-83 plot 4	60.30	5.15	10.61	51.46 %
BC-83 plot 5 - BC-83 plot 5	58.70	5.33	11.43	53.37 %
Totals:	445.10	22.51	48.82	
Average DER = 4.25 kgCO ₂ /m ²	% DER/TER	PASS		
Average TER = 9.41 kgCO ₂ /m ²	54.79 %			

Block Compliance Report - DFEE

Block Reference: BC-83		Block Name:		
Property-Assessment Reference	Floor area (m ²)	DFEE (kWh/m ² /yr)	TFEE (kWh/m ² /yr)	% DFEE/TFEE
BC-83 plot 1 - BC-83 plot 1	125.00	35.14	37.94	7.38 %
BC-83 plot 2 - BC-83 plot 2	125.00	28.86	34.86	17.20 %
BC-83 plot 3 - BC-83 plot 3	76.10	36.33	42.24	13.99 %
BC-83 plot 4 - BC-83 plot 4	60.30	36.68	41.52	11.66 %
BC-83 plot 5 - BC-83 plot 5	58.70	36.96	44.14	16.28 %
Totals:	445.10	173.98	200.71	
Average DFEE = 34.03 kgCO ₂ /m ²	% DFEE/TFEE	PASS		
Average TFEE = 39.11 kgCO ₂ /m ²	13.00 %			

Block Compliance Report - DPER

Block Reference: BC-83	Block Name:
------------------------	-------------

Block Compliance

Property-Assessment Reference	Floor area (m ²)	DPER (kWh/m ² /yr)	TPER (kWh/m ² /yr)	% DPER/TPER
BC-83 plot 1 - BC-83 plot 1	125.00	39.13	46.47	15.80 %
BC-83 plot 2 - BC-83 plot 2	125.00	36.42	42.88	15.07 %
BC-83 plot 3 - BC-83 plot 3	76.10	50.46	51.69	2.38 %
BC-83 plot 4 - BC-83 plot 4	60.30	54.31	56.67	4.16 %
BC-83 plot 5 - BC-83 plot 5	58.70	56.18	61.08	8.02 %
Totals:	445.10	236.50	258.79	
Average DPER = 44.61 kgCO ₂ /m ²	% DPER/TPER	PASS		
Average TPER = 49.66 kgCO ₂ /m ²	10.17 %			