



DMP File No.  
E:\CAD\DM\DWGS\

NOTES:

1. THIS DRAWING SHOWS AN INDICATIVE FIRE ALARM LAYOUT. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO ENSURE THE FINAL L2 SYSTEM IS FULLY COMPLIANT WITH BS 5839 AND ALL OTHER RELEVANT STANDARDS.
2. VOID PROTECTION AND ASSOCIATED REPEATERS SHALL BE PROVIDED BY THE CONTRACTOR FOR VOIDS GREATER THAN 800mm AND OTHER HIGH RISK AREAS.
3. THE CONTRACTOR IS TO ENSURE ALL GAS SHUT-OFF DEVICES ARE FULLY INTERFACED WITH THE FIRE ALARM SYSTEM.

FIRE ALARM LEGEND

- FAP** FIRE ALARM PANEL
- FAI** FIRE ALARM INTERFACE UNIT
- H** HEAT DETECTOR
- HS** HEAT DETECTOR WITH SOUNDER
- S** SMOKE DETECTOR
- SS** SMOKE DETECTOR WITH SOUNDER
- MCP** MANUAL CALL POINT C/W ALARM COVER
- CIRC** WALL SOUNDER BEACON

P	30.09.22	ISSUED FOR COMMENT
REV	DATE	DESCRIPTION



8 Holgate Court, Western Road,  
Romford, Essex, RM1 3JS

Tel: 01708 729070 [www.davidmiles.co.uk](http://www.davidmiles.co.uk)

project  
BISHOPHALT SCHOOL

title  
BLOCKS A & L - FIRST FLOOR  
PROPOSED FIRE ALARM  
LAYOUT (SHEET 1 of 3)

scale 1:100@A1 date SEPT 2022  
drawn checked rev  
PC JS P

drawing no.  
7722-EFA-

PRELIMINARY

DO NOT SCALE FROM THIS DRAWING  
This drawing is the copyright of David Miles & Partners Ltd.  
& is to be used between themselves and the client.  
Any reproduction without the written permission of David Miles & Partners Ltd is strictly prohibited.