


Note: It is recommended that one vent pipe, 110mm in diameter, is provided per 7,500 square meters of impermeable catchment area on a site.



- NOTES**
- 1) THE DEVELOPER SHOULD TAKE ALL NECESSARY PRECAUTIONS TO AVOID CAUSING ANY DAMAGE TO, OR INTERFERENCE WITH FLOW IN EXISTING SEWERS AND SHALL ENSURE THAT DEBRIS, SILT, MUD ETC. DO NOT ENTER WHERE WORKS ARE TO BE CARRIED OUT ON SEWERS.
 - 2) THE CONTRACTOR MUST CARRY OUT THEIR WORKS IN ACCORDANCE WITH THE CLASSIFICATION AND MANAGEMENT OF CONFINED SPACES PUBLISHED BY WATER UK. THEY MUST ALSO COMPLY WITH ALL OTHER RELEVANT HEALTH AND SAFETY LEGISLATION/ DOCUMENTATION.
 - 3) ALL MATERIALS ARE TO BE STORED IN SUCH A MANNER AS TO PRESERVE THEIR QUALITY AS TO THE STANDARD SPECIFIED IN THE SPECIFICATION.
 - 4) ALL CONCRETE TO BE PRODUCED ON SITE MUST BE MIXED WITH ONLY POTABLE WATER. TO ENSURE THAT IT IS CLEAN FROM DIRT AND AGGREGATES FOR CONCRETES SHALL COMPLY WITH THE RELEVANT PROVISIONS OF BS EN 12620 AND PD 6682-1.
 - 5) SANDS FOR MORTAR AND GROUTS SHALL BE WASHED SAND, COMPLYING WITH BS EN 13139 AND PD 6682-3. ALL OTHER SANDS ARE TO COMPLY WITH BS EN 12620 AND PD 6682-1 OR BS EN 13139 AND PD 6682-3.
 - 6) PULVERISED-FUEL ASH (PFA) FOR USE AS A COMPONENT MATERIAL IN CEMENTITIOUS GROUT OR NON STRUCTURAL CONCRETE SHALL COMPLY VERIFIED CLAY PIPES AND FITTINGS FOR SEWERS SHALL HAVE FLEXIBLE MECHANICAL JOINTS.
 - 7) PIPES FOR FOUL SEWERS AND SURFACE WATER SEWERS SHALL COMPLY WITH THE RELEVANT REQUIREMENTS OF BS EN295 AND BS85 SURFACE WATER PIPES ONLY. PRE-CAST CONCRETE MANHOLE UNITS OF CIRCULAR CROSS SECTION FOR MANHOLES, CHAMBERS AND WET WELLS SHALL COMPLY WITH THE RELEVANT PROVISIONS OF BS EN 1917 AND BS 5911-3.
 - 8) LADDERS FOR MANHOLES IN A VERTICAL PLANE ARE TO BE MILD STEEL AND COMPLY WITH BS4211, CLASS A AND PD 970. GRP LADDERS SHALL BE MANUFACTURED IN ACCORDANCE WITH BS EN 1311 AND FROM GLASS-REINFORCED POLYESTER USING AN APPROPRIATE RESIN FOR THE LADDER LOCATION. UNIDIRECTION REINFORCEMENT SHALL BE PROVIDED IN THE GRP MATRIX TO MAXIMISE STRENGTH.
 - 9) MANHOLE COVERS AND FRAMES SHALL COMPLY WITH THE RELEVANT PROVISIONS OF BS EN 124, BS 7903 AND HIGHWAYS AGENCY GUIDANCE DOCUMENT HA 104/02. THEY SHALL BE OF A NON-ROCKING DESIGN WHICH DO NOT RELY ON THE USE OF CUSHION INSERTS.
 - 10) CLAY BRICKS TO BE USED WITHIN MANHOLES ARE TO BE SOLID, CLASS B ENGINEERING BRICKS COMPLYING TO BS 3921. ALL BRICKS SHALL BE FROST RESISTANT CATEGORY F. STANDARD CONCRETE MIXES SHOULD BE IN ACCORDANCE WITH BS EN 206-1 AND BS 8500 AND SHALL BE USED WITH A 20MM NOMINAL MAXIMUM SIZE OF AGGREGATE AND A SLUMP CLASS OF S2 FOR A TARGET OF 70MM.
 - 11) GEN1 CONCRETE TO BE USED FOR, FILLINGS, BLINDINGS, SOFT SPOTS AND DRAINAGE SLUMPS. GEN3 CONCRETE TO BE USED FOR, ALL OTHER APPLICATIONS. U.N.O. ADMIXTURES (INCLUDING CALCIUM CHLORIDE AND PIGMENTS) SHALL NOT BE USED IN THE PRODUCTION OF CONCRETE.
 - 12) HIGH STRENGTH CONCRETE TOPPING SHALL BE PRODUCED, LAID AND FINISHED IN ACCORDANCE WITH THE RELEVANT PROVISIONS OF BS 8204: PART 2 AND THE FOLLOWING APPROXIMATE MIX PROPORTIONS SHALL BE USED: 1 PART CEMENT, 1 PART NATURAL SAND AND 2 PARTS SINGLE-SIZED COARSE AGGREGATE.
 - 13) ALL MORTAR MIXES SHALL BE IN ACCORDANCE WITH BS 5628-1:2005. ALL PIPES TO BE EITHER EXTRA STRENGTH PVC TO BS 65 OR PVC TO BS 4660 OR BS 5481 "UPONOR ULTRARIB"

REVISIONS

REV	DESCRIPTION	DATE	BY
P01	FIRST ISSUE	20/02/26	KB

Aval Consulting Group
 CIVIL, ENVIRONMENT & STRUCTURAL ENGINEERS
 Transportation Planning : Environmental Consultants
 www.avalconsulting.co.uk, Email: contact@avalconsulting.co.uk
 Company Number: 11922039

Client Name:
DS SQUARED ARCHITECTS

Project Title:
35 BROOKDENE DRIVE

Drawing Title:
CONSTRUCTION DETAILS

Date:	20.02.2026	Drawn By:	KB
Scale:	AS SHOWN	Checked:	DL
Status:	PLANNING	Approved:	WR

Drawing No. **AVAL/94063/4000/001** Rev. **P01**

