



**CERTIFICATE OF DESIGN, INSTALLATION AND
DETECTION AND ALARM COMMISSIONING OF A FIRE
SYSTEM OF GRADE B, C, D, E, OR F IN A DWELLING**

Details of Client

Issued in accordance with BS 5839-6 : 2013

Client :	Current Occupier
Address :	4 Covert Northwood London
	PostCode: HA6 2UD

Details of the Fire Detection and Alarm System

The System Is :

Address :	4 The Covert Northwood, London	New <input checked="" type="checkbox"/>
Extent of the fire detection and alarm system covered by this certificate	Dwelling Only	Modification <input type="checkbox"/>
	PostCode: HA6 2UD	N/A <input type="checkbox"/>

Description of System Grade and System Category

System Grade : B N/A C N/A D E N/A F N/A System Category : LD1 N/A LD2 N/A LD3 PD1 N/A PD2 N/A

Commissioning

(See Note 1) A tick in the box indicates the inspection or test has been performed and the results are satisfactory
N/A indicates an inspection or test is not appropriate

Test buttons checked	<input checked="" type="checkbox"/>	Simulated smoke or aerosol test	<input checked="" type="checkbox"/>	Dedicated circuit(s) provided	<input checked="" type="checkbox"/>	Sound level test instrument used	(See Note 2)
All alarm warning devices operate	<input checked="" type="checkbox"/>	Heat Test	<input type="checkbox"/> N/A	Protective device labelled	<input checked="" type="checkbox"/>	Model and Serial no.	11090332
Silencing system checked	<input checked="" type="checkbox"/>	Bedroom sound level (Clause 13.2)	<input checked="" type="checkbox"/>	Audible and Visual indication of mains failure	<input checked="" type="checkbox"/>	Serial No. of associated Electrical Installations Certificate or Minor Electrical Installation Works Certificate (See Note 1)	N/A

User Instructions

Tick boxes to indicate that the written information has been issued to the user

I/We the undersigned declare that the occupier* of the dwelling (or owner in the case of a house in multiple occupancy) has been provided with written information about essential aspects of the operation and maintenance of the system, as follows :

Operation of the system	<input checked="" type="checkbox"/>	Routine testing of the system	<input checked="" type="checkbox"/>	Checking the system on reoccupation of the dwelling after a vacation etc.	<input checked="" type="checkbox"/>
Action to be taken in the event of an alarm signal	<input checked="" type="checkbox"/>	Servicing and maintenance of the system (including intervals at which any batteries should be replaced)	<input checked="" type="checkbox"/>	The need to avoid contamination of detectors by paint	<input checked="" type="checkbox"/>
Avoidance of false alarms and action in the event of a false alarm	<input checked="" type="checkbox"/>	The need to keep clear space around all detectors and manual call points	<input checked="" type="checkbox"/>	As-fitted drawing	<input checked="" type="checkbox"/>
Warning that apparent false alarm from carbon monoxide detector may not be false alarm	<input type="checkbox"/> N/A	Special precautions relevant to any lithium batteries used in the system	<input type="checkbox"/> N/A		

**In the case of a newly-built property and where the future occupier is unknown, the User Instructions
should be issued to the builder for onward transmission to the purchaser together with the related electrical safety certificate.*

Certificate of Design, Installation and Commissioning

We, being the person(s) responsible (as indicated by our signature(s) below), for the design, installation and commissioning of the fire alarm system, particulars of which are set out above, CERTIFY that the said work for which We have been responsible complies to the best of our knowledge and belief with the recommendations of BS 5839: Part 6 for the system described above, except for the variations, if any, stated below:

Variations(if any)

The extent of liability of the signatory / signatories is limited to the work described above as the subject of this certificate.

For the design, installation and commissioning of the system:

This certificate has been reviewed by the Qualified Supervisor:

Name:	Hubert Szewczyk	Name:	Bruce Martin
Signature:		Date:	25-04-16
		Date:	25-04-16

Details of Approved Contractor

Trading title	Ardmore Construction Limited		
Address :	Byrne House Jeffreys Road Brimsdown, Middlesex	NICEIC Enrolment No (Essential information)	016730
		Branch Number (If Applicable)	001
	PostCode: EN3 7UB		

Note 1. The electrical safety aspects of the fire detection and alarm system must also be certified in accordance with BS 7671: 'Requirements for Electrical Installations' by issuing an electrical safety certificate of a form which meets the requirements of BS 7671 such as a 'Domestic Electrical Installation Certificate' or, where appropriate, a 'Minor Electrical Installation Works Certificate'.

Note 2. An instrument complying with BS EN 61672, Class 2, with slow response and A weighting (see clause 13.2), is suitable for measuring the sound level.

Note 3. This certificate may be required by an authority responsible for enforcement of fire safety legislation, such as the building control authority or housing authority. The recipient of this certificate might rely on the certificate as evidence of compliance with legislation. Liability could arise on the part of any organisation or person that issues a certificate without due care in ensuring its validity.