

DETERM TEST SCHEDULE				DATE	ENGR
DATE	TEST	SIZE	MODE		
D01	SOFTEN	300x217	D066-08	0.162	AD/MSD
D02	SOFTEN	300x217	D066-08	0.162	AD/MSD
D03	SOFTEN	300x217	D066-08	0.162	AD/MSD
D04	SOFTEN	300x217	D066-08	0.162	AD/MSD
D05	SOFTEN	300x217	D066-08	0.162	AD/MSD
D06	SOFTEN	300x217	D066-08	0.162	AD/MSD
D07	SOFTEN	300x217	D066-08	0.162	AD/MSD
D08	SOFTEN	300x217	D066-08	0.162	AD/MSD
D09	SOFTEN	300x217	D066-08	0.162	AD/MSD
D10	SOFTEN	300x217	D066-08	0.162	AD/MSD
D11	SOFTEN	300x217	D066-08	0.162	AD/MSD
D12	SOFTEN	300x217	D066-08	0.162	AD/MSD
D13	SOFTEN	300x217	D066-08	0.162	AD/MSD
D14	SOFTEN	300x217	D066-08	0.162	AD/MSD

LOUVRE SCHEDULE			FINISH
REF.	MANUFACTURE	SIZE	m ³ /S
WL1	SOVEREIGN	1000x800	0.9
WL2	SOVEREIGN	800x500	0.45
WL3	SOVEREIGN	800x500	0.45
WL4	SOVEREIGN	200x150	0.038
		WALL	SILVER

[illegible]

EQUIPMENT SCHEDULE
CAS10 – CAS10 (9 TOTAL)
 MANUFACTURER – DAIKIN
 MODEL – FUA71A – UNDER CEILING CASSETTES
 WEIGHT – 25KG
 PIPE CONNECTION SIZE – 3/8" LIQUID & 5/8" GAS

2001-03-03 TOTAL
MANUFACTURER - DAIKIN
MODEL - RZA200D

PIPE CONNECTION SIZE- 3/8" LIQUID & 7/8" GAS
ELECTRICS- 3PH 20AMP
COUNTRIES (4 TOTAL)

MANUFACTURER- DAIKIN
MODEL- FDA125A
WEIGHT- 45KG

PIPE CONNECTION SIZE- 3/8" LIQUID & 5/8" GAS
CU04-05 (2 TOTAL)
MANUFACTURER- DAIKIN

MODEL- R2A250D
WEIGHT- 117KG
PIPE CONNECTION SIZE- 3/8" LIQUID & 7/8" GAS

ELECTRONICS CITY ZORIN
 AC6
 MANUFACTURER - DAIKIN
 MODEL EVASZED ROUND FLOW CASSETTE 2 ELW

WEIGHT - 23.5KG
PIPE CONNECTION SIZE - 1/4" LIQUID & 3/8" GAS
C116

MANUFACTURER - DAIKIN
MODEL - RZAG35A
WEIGHT - 52KG

TYPE CONNECTION SIZE - 1/4 LIQUID & 3/8 GAS
ELECTRICS - 1PH 16AMP
DH01

MODEL- AS TYPE B 2100
WEIGHT- 70Kg
ELECTRICS - 3PH

EF1
MANUFACTURER- VENT AXIA
MODEL- ACM100T

ELLECTRONICS - 1971-2004
CONTROLS - LINKED IN WITH BMS
AHU01
MANUFACTURED - COVERED

DUTY- 1.32m³/sec EA & 1.35m³/sec SA
SIZE- 2920L x 1970W x 1795H
ELECTRICS- 3PH 5 AMP

FILTERS- G4 2 @ 596x596x47
WEIGHT- 930KG

Journal of Management Inquiry 26(4) 391–407 © The Author(s) 2017. Reprints and permissions: sagepub.com/journalsPermissions.nav

Journal of Management Inquiry 25(4) 399–414 © The Author(s) 2016. Reprints and permissions: sagepub.com/journalsPermissions.nav DOI: 10.1177/1056492616666001

–	FIRST ISSUE FOR APPROVAL	15.12.22
EDITED	REVISION	DATE

PROJECT	
DIXONS CARPHONE - HAYES - NEW STORE	

CLIENT	TITLE
	PROPOSED INSTALLATION FOR THE NEW CURRY'S STORE AT UNIT 3 LOWBARDY

TENDER DWG No,	RETAIL PARK, HAYES, UB3 3EX.
----------------	------------------------------

N/A
EXTERNAL DRAWINGS USED:

DC - 5251 HAYES NS FINAL CO2 - REV 'B'

GCN LTD
Air Conditioning - Heating - Electrical - Design - Installation
Nationwide Air Conditioning Mechanical Services

Mill Lane, Bramley,
Leeds LS13 3HE

 Fax: 0113 236 0069
Email: info@ccnac.co.uk

DRAWN R.FLYNN	DATE 13.12.22	DRAWING NUMBER J5039-1	REV -
------------------	------------------	---------------------------	----------