



<p>0  20m</p> <p>Dig Sites Area:  Line: </p> <p>Date Requested: 11/01/2023          Job Reference: 28144725          Site Location: 506653 185723          Requested by: Mr Chris Klausen          Your Scheme/Reference: TPO 389</p> <p>Scale: 1:500 (When plotted at A4)</p>		<p><b>Voltages (V)</b></p> <table border="1"> <tr> <td>LV (Low Voltage) and Services</td> <td>Up to 1,000V</td> </tr> <tr> <td>HV (High Voltage)</td> <td>Over 1,000V to 11,000V</td> </tr> <tr> <td>EHV (Extra High Voltage)</td> <td>22,000V to 132,000V</td> </tr> <tr> <td>Transmission</td> <td>275,000V and 400,000V</td> </tr> </table> <p><b>NORMAL DEPTH TO THE TOP OF THE CABLE WHEN LAID</b></p> <table border="1"> <tr> <td>Footpath/Unmade</td> <td>0.45m</td> <td>0.45m</td> <td>0.6m</td> <td>0.8m</td> </tr> <tr> <td>Road Crossing</td> <td>0.6m</td> <td>0.6m</td> <td>0.75m</td> <td>0.9m</td> </tr> <tr> <td>Agricultural</td> <td>1m</td> <td>1m</td> <td>1m</td> <td>1.1m</td> </tr> </table> <p><b>Legend</b></p> <ul style="list-style-type: none"> <li>Service Cable</li> <li>2 - 3.3kV</li> <li>6.6kV</li> <li>11kV</li> <li>22kV</li> <li>33kV</li> <li>66kV</li> <li>132kV</li> <li>275kV</li> <li>400kV</li> <li>Fibre Optic</li> <li>Pilot Cable</li> </ul> <p><b>Distribution Structures (Electric)</b></p> <ul style="list-style-type: none"> <li>Pole, Existing Location</li> <li>Pole Structure, Existing Location - Single</li> <li>Pole Structure, Existing Location - H</li> </ul> <p><b>Line:</b> </p> <p><b>Duct Route:</b> </p> <p><b>Cross Section Route:</b> </p> <p><b>Warning:</b> There may have been subsequent alteration to the surface levels. Trial holes must be undertaken to determine position and depths of cables. HS (G) 47 Booklet from the Health and Safety Executive – Avoiding Danger from Buried Cables – should be consulted before commencing excavation work.</p> <p><b>WHEN WORKING IN THE VICINITY OF OVERHEAD LINES THE HEALTH AND SAFETY GUIDANCE NOTES G56 SHOULD BE CONSULTED (AVAILABLE FROM THE HSE WEBSITE)</b></p>	LV (Low Voltage) and Services	Up to 1,000V	HV (High Voltage)	Over 1,000V to 11,000V	EHV (Extra High Voltage)	22,000V to 132,000V	Transmission	275,000V and 400,000V	Footpath/Unmade	0.45m	0.45m	0.6m	0.8m	Road Crossing	0.6m	0.6m	0.75m	0.9m	Agricultural	1m	1m	1m	1.1m
LV (Low Voltage) and Services	Up to 1,000V																								
HV (High Voltage)	Over 1,000V to 11,000V																								
EHV (Extra High Voltage)	22,000V to 132,000V																								
Transmission	275,000V and 400,000V																								
Footpath/Unmade	0.45m	0.45m	0.6m	0.8m																					
Road Crossing	0.6m	0.6m	0.75m	0.9m																					
Agricultural	1m	1m	1m	1.1m																					
<p> N E W S</p> <p><b>Scottish &amp; Southern Electricity Networks</b></p> <p><b>Southern Electric Power Distribution plc</b>          Registered Office: No.1 Forbury Place          43 Forbury Road Reading RG1 3JH          Registered In England &amp; Wales No.04094290</p> <p>If you're unsure &amp; need to seek advice before commencing excavations, please contact:          General Enquiries: 0800 048 3516</p> <p>Subject to revision – Master held by SSEN Asset Data Team:  <a href="mailto:Asset.Data@sse.com">Asset.Data@sse.com</a>          01256 337 294</p>																									