



Report VA5077.240228.NIA

109 Pinner Road, Northwood

Noise Impact Assessment

13 March 2024

**London Interiors
Unit 8 Bowman Trading Estate
Westmoreland Road
London
NW99RL**

01962 461016
0203 8650332
mail@ventaacoustics.com

registered company no. 10139494

Contents

1. Introduction	1
2. Design Criterion and Assessment Methodology	1
2.1 London Borough of Hillingdon Requirements.....	1
2.2 BS4142:2014+A1:2019	1
2.3 BS8233:2014	2
3. Site Description	2
4. Environmental Noise Survey	3
4.1 Survey Procedure & Equipment	3
4.2 Automated Survey Results.....	3
4.3 Attended Measurements.....	4
4.4 BS4142 Noise Impact Assessment.....	4
5. Conclusion.....	5

Attachments

VA5077/SP1	Indicative Site Plan
VA5077/TH1-TH2	Environmental Noise Time Histories
Appendix A	Acoustic Terminology

Report Version	Author	Approved	Changes	Date
NIA	Steven Liddell	Jamie Duncan	-	04/03/24

The interpretations and conclusions summarised in this report represent Venta Acoustics' best technical interpretation of the data available to us at the time of assessment. Any information provided by third parties and referred to in this report has not been checked or verified by Venta Acoustics, unless otherwise expressly stated in the document. Venta Acoustics cannot accept any liability for the correctness or validity of the information provided. Due to a degree of uncertainty inherent in the prediction of all parameters, we cannot, and do not guarantee the accuracy or correctness of any interpretation and we shall not, except in the case of gross or wilful negligence on our part, be liable for any loss, cost, damages or expenses incurred or sustained by anyone resulting from any interpretations, predictions or conclusions made by the company or employees. The findings and conclusions are relevant to the period of the site survey works, and should not be relied upon to represent site conditions at later dates. Where additional information becomes available which may affect the findings of our assessment, the author reserves the right to review the information, reassess the findings and modify the conclusions accordingly.

1. Introduction

Retrospective approval is being sought for a kitchen supply and extract fan at 109 Pinner Road, Northwood.

Venta Acoustics has been commissioned by London Interiors to undertake an assessment of the potential noise impact of these proposals in support of an application for planning permission.

An environmental noise survey has been undertaken to determine the background noise levels at the most affected noise sensitive receptors. These levels are used to undertake an assessment of the likely impact with reference to the planning requirements of London Borough of Hillingdon.

2. Design Criterion and Assessment Methodology

2.1 London Borough of Hillingdon Requirements

It is understood that the London Borough of Hillingdon require that noise from commercial uses should ideally be at least 5dB below the local background noise level as assessed at the most affected noise sensitive receivers. Where justified, sound levels up to 5dB above the background sound level may be acceptable.

The assessment is to be undertaken with reference to BS4142:2014.

2.2 BS4142:2014+A1:2019

British Standard BS4142:2014+A1:2019 *Methods for rating and assessing industrial and commercial sound* describes a method for rating and assessing sound of an industrial and/or commercial nature, which includes sound from fixed installations comprising mechanical and/or electrical plant and equipment;

The assessment methodology considers the Specific Sound Level, as measured or calculated at a potential noise sensitive receptor, due to the source under investigation. A correction factor is added to this level to account for the acoustic character of the sound as follows:

Tonality – A correction of up to 6dB depending on the prominence of tones;

Impulsivity - A correction of up to 9dB depending on the prominence of impulsivity;

Other sound characteristics - A 3dB correction may be applied where a distinctive acoustic character is present that is neither tonal nor impulsive;

Intermittency - A 3dB correction may be applied where the specific sound has identifiable on/off conditions.

An estimate of the impact of the source is obtained by subtracting the typical background noise level from the corrected Specific Sound Level.

- Typically, the greater this difference, the greater the magnitude of the impact.
- A difference of around +10 dB or more is likely to be an indication of a significant adverse impact, depending on the context.
- A difference of around +5 dB could be an indication of an adverse impact, depending on the context.
- The lower the rating level is relative to the measured background sound level, the less likely it is that there will be an adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound having a low impact, depending on the context.

2.3 BS8233:2014

BS8233 *Guidance on sound insulation and noise reduction for buildings* provides guidance as to suitable internal noise levels for different areas within residential buildings.

The relevant section of the standard is shown below in Table 2.1.

Activity	Location	07:00 to 23:00	23:00 to 07:00
Resting	Living Room	35 dB L _{Aeq} , 16 hour	-
Dining	Dining Room	40 dB L _{Aeq} , 16 hour	-
Sleeping (daytime resting)	Bedroom	35 dB L _{Aeq} , 16 hour	30 dB L _{Aeq} , 8 hour

Table 2.1 - Excerpt from BS8233: 2014

[dB ref. 20μPa]

3. Site Description

As illustrated on attached site plan VA5077/SP1, the site building is located at ground floor level in a terrace of shops with residential units above. To the rear is a courtyard common to the surrounding retail uses and through which the flats are access via a first floor walkway. The most affected flats are those directly above the premises at a distance of approximately 3m from the plant.

The extract fan and supply fan as well as a condenser unit are located on a small flat roof to the rear of the premises. These plant are at a lower level than the first floor walk way and so are screened from the dwellings above the premises by a wall. The fans are both located on the flat room and orientated to discharge away from the dwellings above. The fans include sound attenuators on the atmospheric side.

It was noted that there are a number of other kitchen extract fans and condenser units within the rear courtyard, servicing the surrounding restaurants.

109 Pinner Road is a takeaway restaurant which operates between 10:30 and 20:00 daily, although the nature of the business is that food is batched prepared and the kitchen is not in use continuously.

4. Environmental Noise Survey

4.1 Survey Procedure & Equipment

In order to establish the existing background noise levels at the site, a noise survey was carried out between Wednesday 21st and Friday 23rd February 2024 at the location shown in site plan VA5077/SP1. This location was chosen to be representative of the background noise level at the most affected noise sensitive receivers.

Continuous 5-minute samples of the L_{Aeq} , L_{Amax} , L_{A10} and L_{A90} sound pressure levels were undertaken at the measurement location.

The weather during the survey period was generally dry with light winds. The background noise data is not considered to have been compromised by these conditions.

Measurements were made generally in accordance with ISO 1996 2:2017 *Acoustics - Description, measurement and assessment of environmental noise – Part 2: Determination of sound pressure levels*.

The following equipment was used in the course of the survey:

Manufacturer	Model Type	Serial No	Calibration	
			Certificate No.	Date
NTi Class 1 Integrating SLM	XL2	A2A-11586-E0	1502936-2	25/7/22
Larson Davis calibrator	CAL200	19816	1506037-1	28/7/23

Table 4.1 – Equipment used for the survey

The calibration of the sound level meter was verified before and after use with no significant calibration drift observed.

4.2 Automated Survey Results

The measured sound levels are shown as time-history plots on the attached charts VA5077/TH1-2.

It can be seen from the time histories that the background noise level is determined by numerous plant servicing the surrounding premises. These continue beyond the operational hours of 109 Pinner Road and the operation of the equipment associated with the premises does not control the acoustic environment.

The typical background noise levels measured were:

Monitoring Period	Typical ¹ L _{A90,5min}
07:00 – 23:00 hours	49 dB
23:00 – 07:00 hours	51 dB
Operational Hours 10:30 – 20:00	55 dB

Table 4.2 – Typical background noise levels

[dB ref. 20 µPa]

¹The typical L_{A90} value is taken as the 10th percentile of all L_{A90} values measured during the relevant period.

4.3 Attended Measurements

During the site visits on 21 February 2024, attended measurements were undertaken with the fans set to their normal operating speed, their maximum operating speed and with the equipment turned off. The equipment listed in Table 4.1 was used for the measurements.

Measurement	Ambient Sound level L _{Aeq}	Notes
1m in front of Extract, Max	70 dB	
1m in front of Extract, Normal Operation Speed	64 dB	
MaxKold Condenser Unit	68dB	1m from unit
1m in front of Supply Air Fan – Max Speed	65 dB	
AM1 – Behind Fans, 1m from window – Max speed	55 dB	Application Fan just identifiable against other fans in the area
AM1 – Behind Fans, 1m from window – Normal Speed	55 dB	Application fan not identifiable relative to existing sound levels
AM1 – Behind Fans, 1m from window - Off	54 dB	Residual Sound Level
AM2 – 8m to the side - Max Speed	59 dB	Fans just identifiable against other fans in the area
AM2 – 8m to the side - Normal Speed	58 dB	
AM2 – 8m to the side - Off	57 dB	Residual Sound Level

Table 4.3 – Results of attended measurements

4.4 BS4142 Noise Impact Assessment

Correcting the measured sound levels for the residual sound, the specific sound levels are derived.

As the area contains existing extract plant and condenser units, the sound from this equipment is not considered to be out of place or of a character that attracts attention. The equipment is not intermittent or impulsive in its use. No character correction is therefore considered appropriate for the sound.

Comparing the resulting rating level to the background sound level results in the indication of the likely impact:

Measurement	Specific Sound Level L_{Aeq}	Feature Correction	Rating Level	Background Sound Level	Result
AM1 – Behind Fans, 1m from window – Max speed	47 dB	0	47 dB	55 dB	-8
AM1 – Behind Fans, 1m from window – Normal Speed	45 dB	0	45 dB	55 dB	-10
AM2 – 8m to the side - Max Speed	55 dB	0	55 dB	55 dB	-0
AM2 – 8m to the side – Normal Speed	53 dB	0	53 dB	55 dB	-2

Table 4.4 – BS4142 Assessment of plant noise

At maximum speed the rating level is at most equal to the existing background sound level. At the normal operating duty the rating level is between 2 and 10 dB below the background sound level.

Within the context of the site, this indicates a low impact.

Sound from the MaxKold refrigeration unit is included in the above assessment as a cumulative level (the plant was operational during the surveys). The refrigeration unit is well screened from the residential elements by the backing walls and so has a lower contribution to the sound levels than the extraction fan.

The rating level of the equipment, being at most 2dB below the background sound level, is considered to meet the requirements of Hillingdon Council with the justification of not meeting 5dB below the background sound being that there is existing extract and cooling plant in the area that is already louder than the assessed plant which operates for longer periods. The assessment has been undertaken to the most affected windows which are understood to be the kitchens (non-noise sensitive), with living rooms on the opposite facades. The top floor windows are likely to be bedrooms but the premises in question closes relatively early and so would not affect bedrooms at night.

Overall, a low impact is expected from the installed equipment.

5. Conclusion

A baseline noise survey has been undertaken by Venta Acoustics to establish the background noise climate in the locality of 109 Pinner Road, Northwood in support of a retrospective planning application for installed building services plant.

A survey of noise levels in the area has been undertaken, leading to a BS4142 assessment of the noise impact of the installed equipment.

Given that there is a significant number of existing extract and cooling plant in the immediate area that generates higher sound levels than the application plant, and that sound from the installed plant is lower than the local background sound level, the assessment indicates a low impact.

The proposed scheme is not expected to have a significant adverse noise impact and the relevant planning requirements are considered to have been met.


Steven Liddell MIOA



109 Pinner Road, Northwood
Environmental Noise Time History: 1

 VENTA ACOUSTICS

Figure VA5077/TH1




109 Pinner Road, Northwood

Environmental Noise Time History: 2

VENTA ACOUSTICS

Figure VA5077/TH2




109 Pinner Road, Northwood

Environmental Noise Time History: 3



Figure VA5077/TH3



APPENDIX A

Acoustic Terminology & Human Response to Broadband Sound

1.1 Acoustic Terminology

The human impact of sounds is dependent upon many complex interrelated factors such as 'loudness', its frequency (or pitch) and variation in level. In order to have some objective measure of the annoyance, scales have been derived to allow for these subjective factors.

Sound	Vibrations propagating through a medium (air, water, etc.) that are detectable by the auditory system.
Noise	Sound that is unwanted by or disturbing to the perceiver.
Frequency	The rate per second of vibration constituting a wave, measured in Hertz (Hz), where 1Hz = 1 vibration cycle per second. The human hearing can generally detect sound having frequencies in the range 20Hz to 20kHz. Frequency corresponds to the perception of 'pitch', with low frequencies producing low 'notes' and higher frequencies producing high 'notes'.
dB(A):	Human hearing is more susceptible to mid-frequency sounds than those at high and low frequencies. To take account of this in measurements and predictions, the 'A' weighting scale is used so that the level of sound corresponds roughly to the level as it is typically discerned by humans. The measured or calculated 'A' weighted sound level is designated as dB(A) or L_A . A notional steady sound level which, over a stated period of time, would contain the same amount of acoustical energy as the actual, fluctuating sound measured over that period (e.g. 8 hour, 1 hour, etc).
L_{eq}:	The concept of L_{eq} (equivalent continuous sound level) has primarily been used in assessing noise from industry, although its use is becoming more widespread in defining many other types of sounds, such as from amplified music and environmental sources such as aircraft and construction. Because L_{eq} is effectively a summation of a number of events, it does not in itself limit the magnitude of any individual event, and this is frequently used in conjunction with an absolute sound limit.
L_{10} & L_{90}:	Statistical L_n indices are used to describe the level and the degree of fluctuation of non-steady sound. The term refers to the level exceeded for $n\%$ of the time. Hence, L_{10} is the level exceeded for 10% of the time and as such can be regarded as a typical maximum level. Similarly, L_{90} is the typical minimum level and is often used to describe background noise. It is common practice to use the L_{10} index to describe noise from traffic as, being a high average, it takes into account the increased annoyance that results from the non-steady nature of traffic flow.
L_{max}:	The maximum sound pressure level recorded over a given period. L_{max} is sometimes used in assessing environmental noise, where occasional loud events occur which might not be adequately represented by a time-averaged L_{eq} value.
D_{nT}	<i>Weighted Standardised Level Difference.</i> As defined in BS EN ISO 717-1, representing the <i>Weighted Level Difference</i> , when standardised for reference receiving room reverberant characteristics.
$D_{n,e}$	Normalised sound insulation of small building elements of fixed dimensions, such as vents, measured in an accredited laboratory test suite in accordance with the procedures laid down in BS EN ISO 10140-2:2010.
$D_{n,f}$	Flanking sound insulation of lightweight elements, such as curtain wall mullions, measured in an accredited laboratory test suite in accordance with the procedures laid down in ISO 10848-2:2006

1.2 Octave Band Frequencies

In order to determine the way in which the energy of sound is distributed across the frequency range, the International Standards Organisation has agreed on "preferred" bands of frequency for sound measurement and analysis. The widest and most commonly used band for frequency measurement and analysis is the Octave Band. In these bands, the upper frequency limit is twice the lower frequency limit, with the band being described by its "centre frequency" which is the

APPENDIX A

Acoustic Terminology & Human Response to Broadband Sound

average (geometric mean) of the upper and lower limits, e.g. 250 Hz octave band extends from 176 Hz to 353 Hz. The most commonly used octave bands are:

Octave Band Centre Frequency Hz | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000

1.3 Human Perception of Broadband Noise

Because of the logarithmic nature of the decibel scale, it should be borne in mind that sound levels in dB(A) do not have a simple linear relationship. For example, 100dB(A) sound level is not twice as loud as 50dB(A). It has been found experimentally that changes in the average level of fluctuating sound, such as from traffic, need to be of the order of 3dB before becoming definitely perceptible to the human ear. Data from other experiments have indicated that a change in sound level of 10dB is perceived by the average listener as a doubling or halving of loudness. Using this information, a guide to the subjective interpretation of changes in environmental sound level can be given.

Change in Sound Level dB	Subjective Impression	Human Response
0 to 2	Imperceptible change in loudness	Marginal
3 to 5	Perceptible change in loudness	Noticeable
6 to 10	Up to a doubling or halving of loudness	Significant
11 to 15	More than a doubling or halving of loudness	Substantial
16 to 20	Up to a quadrupling or quartering of loudness	Substantial
21 or more	More than a quadrupling or quartering of loudness	Very Substantial

1.4 Earth Bunds and Barriers - Effective Screen Height

When considering the reduction in sound level of a source provided by a barrier, it is necessary to establish the "effective screen height". For example if a tall barrier exists between a sound source and a listener, with the barrier close to the listener, the listener will perceive the sound as being louder if he climbs up a ladder (and is closer to the top of the barrier) than if he were standing at ground level. Equally if he sat on the ground the sound would seem quieter than if he were standing. This is explained by the fact that the "effective screen height" is changing with the three cases above. In general, the greater the effective screen height, the greater the perceived reduction in sound level.

Similarly, the attenuation provided by a barrier will be greater where it is aligned close to either the source or the listener than where the barrier is midway between the two.