



Ed Laughton <elaughton@hillington.gov.uk>

Re: Planning Consultation for 59872/APP/2015/665

Peter Higginbottom <phigginbottom@hillington.gov.uk>
To: Robert Williams <rwilliams2@hillington.gov.uk>

10 March 2015 at 13:36

Robert

Having looked at the plans I do not agree that only 1 bin is easily accessible. There are two doors into the bin store (one from inside the restaurant/venue) and double doors outside. 3 are very accessible while there is a gap of at least 750mm between the two rows of bins which is surely more than enough for people to walk between them.

Peter

On 10 March 2015 at 13:30, Peter Higginbottom <phigginbottom@hillington.gov.uk> wrote:

Robert

Thanks for this. Is the number of bins sufficient?

Peter

On 10 March 2015 at 12:57, Robert Williams <rwilliams2@hillington.gov.uk> wrote:

Peter,

The problem with the design shown is that the bins are incorrectly aligned. The only way this would work is if they have a caretaker who rotates the bins on an almost daily basis.

Thanks,
Robert

On 10 March 2015 at 12:40, Peter Higginbottom <phigginbottom@hillington.gov.uk> wrote:

Robert

This is not a residential block. Please can you review the plans again and give your comments based on the use of the building as the energy centre, music venue or restaurant and cafe. Once I have full comments I will go back to the developer regarding the alignment of the bins.

Thanks,
Peter

On 10 March 2015 at 12:38, Robert Williams <rwilliams2@hillington.gov.uk> wrote:

Please see the attached memo with my comments.

I have a concern about the size of the bin chamber and alignment of bins there in.

If the bins were placed as shown on the plan only the bin at the end of the line would be easily accessible. For practicality of use the bins would be better rotated by 90 degrees and have the back of the container (hinge side) against the wall.

I am not sure how many residents will be using the block - however the number of containers required can be calculated by multiplying the number of households by the 170 litres (use 240 for 3 bedroom) and dividing by 1,100 litres.

I have highlighted other key points on the memo attached.

Thanks,

Robert Williams
Waste Development Manager
Residents Services
London Borough of Hillington
Telephone Number: 01895 556116

On 24 February 2015 at 15:33, <PlanningEConsult@hillington.gov.uk> wrote:

MEMORANDUM

Residents Services

FROM: Residents Services
Planning Section

TO: Waste Strategy
Colin Russell
Waste Services
Block A, Harlington Road Depot

AREA: Central and South Area Team