



Project name

Shell and Core

Vinyl Square - Commercial Unit

As designed

Date: Wed Sep 07 15:21:20 2022

Administrative information

Building Details

Address: Address 1, City, Postcode

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.15

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.15

BRUKL compliance check version: v5.6.b.0

Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

Criterion 1: The calculated CO₂ emission rate for the building must not exceed the target

| | |
|--|---------------------|
| CO ₂ emission rate from the notional building, kgCO ₂ /m ² .annum | 27.4 |
| Target CO ₂ emission rate (TER), kgCO ₂ /m ² .annum | 27.4 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m ² .annum | 16.5 |
| Are emissions from the building less than or equal to the target? | BER =< TER |
| Are as built details the same as used in the BER calculations? | Separate submission |

Criterion 2: The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Values which do not achieve the standards in the Non-Domestic Building Services Compliance Guide and Part L are displayed in red.

Building fabric

| Element | U _a -Limit | U _a -Calc | U _i -Calc | Surface where the maximum value occurs* |
|--|-----------------------|----------------------|----------------------|--|
| Wall** | 0.35 | 0.12 | 0.12 | CM000001:Surf[4] |
| Floor | 0.25 | 0.13 | 0.13 | CM000001:Surf[0] |
| Roof | 0.25 | 0.11 | 0.11 | CM000001:Surf[1] |
| Windows***, roof windows, and rooflights | 2.2 | 1.2 | 1.2 | CM000001:Surf[2] |
| Personnel doors | 2.2 | 2.2 | 2.2 | G_000008:Surf[2] |
| Vehicle access & similar large doors | 1.5 | - | - | No Vehicle access doors in building |
| High usage entrance doors | 3.5 | - | - | No High usage entrance doors in building |

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]

U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]

U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]

* There might be more than one surface where the maximum U-value occurs.

** Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

*** Display windows and similar glazing are excluded from the U-value check.

N.B.: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air Permeability | Worst acceptable standard | This building |
|--|---------------------------|---------------|
| m ³ /(h.m ²) at 50 Pa | 10 | 3 |

Building services

The standard values listed below are minimum values for efficiencies and maximum values for SFPs. Refer to the Non-Domestic Building Services Compliance Guide for details.

| | |
|---|-------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | >0.95 |

1- Commercial System

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 3 | 3.5 | 0 | - | 0.75 |
| Standard value | 2.5* | 2.6 | N/A | N/A | 0.5 |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | YES |

* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. For types <=12 kW output, refer to EN 14825 for limiting standards.

"No HWS in project, or hot water is provided by HVAC system"

Local mechanical ventilation, exhaust, and terminal units

| ID | System type in Non-domestic Building Services Compliance Guide |
|----|---|
| A | Local supply or extract ventilation units serving a single area |
| B | Zonal supply system where the fan is remote from the zone |
| C | Zonal extract system where the fan is remote from the zone |
| D | Zonal supply and extract ventilation units serving a single room or zone with heating and heat recovery |
| E | Local supply and extract ventilation system serving a single area with heating and heat recovery |
| F | Other local ventilation units |
| G | Fan-assisted terminal VAV unit |
| H | Fan coil units |
| I | Zonal extract system where the fan is remote from the zone with grease filter |

| Zone name | SFP [W/(l/s)] | | | | | | | | | HR efficiency | |
|----------------|---------------|-----|-----|-----|-----|-----|-----|-----|---|---------------|----------|
| | A | B | C | D | E | F | G | H | I | | |
| Standard value | 0.3 | 1.1 | 0.5 | 1.9 | 1.6 | 0.5 | 1.1 | 0.5 | 1 | Zone | Standard |
| COMMERCIAL | - | - | - | 1.1 | - | - | - | - | - | - | N/A |

Shell and core configuration

| Zone | Assumed shell? |
|---------------------------------|----------------|
| COMMERCIAL | YES |
| COMMERCIAL CYCLE/REFUSE STORAGE | NO |
| COMMERCIAL BOH & PLANT | NO |

| Zone name | Luminous efficacy [lm/W] | | | General lighting [W] |
|---------------------------------|--------------------------|------|--------------|----------------------|
| | Luminaire | Lamp | Display lamp | |
| Standard value | 60 | 60 | 22 | |
| COMMERCIAL | - | 95 | 60 | 2874 |
| COMMERCIAL CYCLE/REFUSE STORAGE | 95 | - | - | 34 |
| COMMERCIAL BOH & PLANT | 95 | - | - | 243 |

Criterion 3: The spaces in the building should have appropriate passive control measures to limit solar gains

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|------------|--------------------------------|-----------------------|
| COMMERCIAL | NO (-14.1%) | NO |

Criterion 4: The performance of the building, as built, should be consistent with the calculated BER

Separate submission

Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place

Separate submission

EPBD (Recast): Consideration of alternative energy systems

| | |
|---|----|
| Were alternative energy systems considered and analysed as part of the design process? | NO |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | NO |

Technical Data Sheet (Actual vs. Notional Building)

| Building Global Parameters | | Building Use | | |
|---|--------|--------------|--------|---|
| | Actual | Notional | % Area | Building Type |
| Area [m ²] | 407.8 | 407.8 | 100 | A1/A2 Retail/Financial and Professional services |
| External area [m ²] | 673.5 | 673.5 | | A3/A4/A5 Restaurants and Cafes/Drinking Est./Takeaways |
| Weather | LON | LON | | B1 Offices and Workshop businesses |
| Infiltration [m ³ /hm ² @ 50Pa] | 3 | 3 | | B2 to B7 General Industrial and Special Industrial Groups |
| Average conductance [W/K] | 175.03 | 249.28 | | B8 Storage or Distribution |
| Average U-value [W/m ² K] | 0.26 | 0.37 | | C1 Hotels |
| Alpha value* [%] | 10 | 10 | | C2 Residential Institutions: Hospitals and Care Homes |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

| |
|--|
| A2 Residential Institutions: Residential schools |
| C2 Residential Institutions: Universities and colleges |
| C2A Secure Residential Institutions |
| Residential spaces |
| D1 Non-residential Institutions: Community/Day Centre |
| D1 Non-residential Institutions: Libraries, Museums, and Galleries |
| D1 Non-residential Institutions: Education |
| D1 Non-residential Institutions: Primary Health Care Building |
| D1 Non-residential Institutions: Crown and County Courts |
| D2 General Assembly and Leisure, Night Clubs, and Theatres |
| Others: Passenger terminals |
| Others: Emergency services |
| Others: Miscellaneous 24hr activities |
| Others: Car Parks 24 hrs |
| Others: Stand alone utility block |

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|----------------|--------------|-------------|
| Heating | 0.12 | 0.43 |
| Cooling | 13.82 | 12.02 |
| Auxiliary | 3.65 | 2.28 |
| Lighting | 14.23 | 38.75 |
| Hot water | 1.26 | 1.33 |
| Equipment* | 62.75 | 62.75 |
| TOTAL** | 33.09 | 54.8 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.

** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|-----------------------|--------|----------|
| Photovoltaic systems | 0 | 0 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 131.43 | 167.86 |
| Primary energy* [kWh/m ²] | 96.77 | 161.65 |
| Total emissions [kg/m ²] | 16.5 | 27.4 |

* Primary energy is net of any electrical energy displaced by CHP generators, if applicable.

HVAC Systems Performance

| System Type | Heat dem MJ/m ² | Cool dem MJ/m ² | Heat con kWh/m ² | Cool con kWh/m ² | Aux con kWh/m ² | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|---|-------------------------------|-------------------------------|--------------------------------|--------------------------------|-------------------------------|---------------|---------------|------------------|------------------|
| [ST] Split or multi-split system, [HS] Heat pump (electric): air source, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 1.7 | 174.8 | 0.2 | 18.6 | 4.9 | 2.94 | 2.62 | 3 | 3.5 |
| | Notional | 5.3 | 220.1 | 0.6 | 16.1 | 3.1 | 2.56 | 3.79 | ---- |
| [ST] No Heating or Cooling | | | | | | | | | |
| Actual | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | Notional | 0 | 0 | 0 | 0 | 0 | 0 | 0 | ---- |

Key to terms

| | |
|--------------------------------|---|
| Heat dem [MJ/m ²] | = Heating energy demand |
| Cool dem [MJ/m ²] | = Cooling energy demand |
| Heat con [kWh/m ²] | = Heating energy consumption |
| Cool con [kWh/m ²] | = Cooling energy consumption |
| Aux con [kWh/m ²] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |

Key Features

The Building Control Body is advised to give particular attention to items whose specifications are better than typically expected.

Building fabric

| Element | Ui-Typ | Ui-Min | Surface where the minimum value occurs* |
|---------------------------------------|--------|--------|--|
| Wall | 0.23 | 0.12 | CM000001:Surf[4] |
| Floor | 0.2 | 0.13 | CM000001:Surf[0] |
| Roof | 0.15 | 0.11 | CM000001:Surf[1] |
| Windows, roof windows, and rooflights | 1.5 | 1.2 | CM000001:Surf[2] |
| Personnel doors | 1.5 | 2.2 | G_000008:Surf[2] |
| Vehicle access & similar large doors | 1.5 | - | No Vehicle access doors in building |
| High usage entrance doors | 1.5 | - | No High usage entrance doors in building |

Ui-Typ = Typical individual element U-values [W/(m²K)] Ui-Min = Minimum individual element U-values [W/(m²K)]

* There might be more than one surface where the minimum U-value occurs.

| Air Permeability | Typical value | This building |
|--|---------------|---------------|
| m ³ /(h.m ²) at 50 Pa | 5 | 3 |