

CERTIFICATE OF COMPLIANCE

Copies to: Customer; Water Company; Installer (retain for records)

NEW SUPPLY Yes No Internal External

Water Company
Application/Reference Number: **DS0060445 DS0060447**

Member's Name:	Mark Aldous	Membership No:	GW8858
Company Name:	Dig & Connect	Membership Expiry Date:	
Telephone Number:	07746 586 214	Email address:	

Address where work carried out (please include plot numbers where applicable):

Cowley Business Park, Uxbridge
Otter house and Waterside House

Plot No:					
1	2				

Name and address of the person who commissioned the work (the customer):

Joel Rothbart

Holly House, 214-218 High Road, London N15 4NP

Telephone Number:		Email address:	
-------------------	--	----------------	--

Please give a brief description of the work completed and its location within the premises:

**We have laid 63mm Barrier Pipe at both waterside house and otter house, all pipework has been laid to depth and Backfilled in accordance with Water regs.
63mm barrier pipe was used to prevent any contamination issues with the potable water supply.**

I confirm that the work carried out complies with the Water Supply (Water Fittings) Regulations 1999, Water Supply (Water Fittings) (Scotland) Byelaws 2014 or Water Supply (Water Fittings) Regulations (Northern Ireland) 2009.

Signed: 

Date:

11/12/25

Print: **M. Aldous**

Certificate or reference No: