

HBPLC-FM-QA-152 - Drainage Check Sheet

Form Reference	F1.1365883
Owned By	Gerti Qamili (Harringtons Builders)
Date	16/06/2022 09:44:48
Status	Closed
Project Name	369 - Grand Union Village
Project Reference	369
Location	369 - Grand Union Village

Date of Inspection	16/06/2022
Location	369 - Grand Union Village
Inspected By	Gerti Qamili

Document Name	Type	Created By	Date
Location Mark Up.png	Unknown	Gerti Qamili (Harringtons Builders)	16/06/2022 09:46:35

Drawing Ref	FS0729-HYD-XX-ZZ-DR-C-7010
Specification Ref	C01

Pre-Construction Phase

- A.Ensure all relevant risk assessments and method statements are approved and operatives briefed.
- B.Check all relevant designs/drawings are approved and operatives working to latest revisions.
- C.Check that all materials used are approved and have been stored in accordance with manufacturers guidelines.
- D.Ensure all required permits are issued to carry out the works, such as: Permit to load, permit to dig etc.

Construction Phase

Pipe Run Location (Mh to Mh)	Foul Man hole 6-5
------------------------------	-------------------

Phase A (Excavation & Pipe Install)					
#	Check Item	Completed	Comment	Inspected By:	Date
1	Excavation level	Yes		Gerti Qamili	16/06/2022
2	Trench width	Yes	600	Gerti Qamili	16/06/2022
3	Pipe diameter/Type	Yes	PVC 100mm	Gerti Qamili	16/06/2022
4	Pipe Connections/Joints	Yes		Gerti Qamili	16/06/2022
5	Bed Type	Yes	Shingles	Gerti Qamili	16/06/2022
6	Surround Type	Yes	Shingles	Gerti Qamili	16/06/2022
7	Line and Level	Yes		Gerti Qamili	16/06/2022
8	Identification/Warning Tape	No		Gerti Qamili	16/06/2022
9	Interim Pipe Test	Yes		Gerti Qamili	16/06/2022

Images

#3



[16/06/2022 09:47:06](#)

Phase A Sign-Off				
#	Check Item	Signature	Date	Comment
1	HBPLC Sign-off	G.Qamili (Harringtons Builders) 16/06/2022 09:46:03	16/06/2022	

#	Check Item	Signature	Date	Comment
2	Client Sign-off	C.Taylor (ISG) 16/06/2022 14:17:19		

Phase B (Backfill & Reinstatement)

#	Check Item	Completed	Comment	Inspected By:	Date
1	Backfill Material	Yes	Crush	Gerti Qamili	16/06/2022
2	Backfilling/Reinstatement	Yes		Gerti Qamili	16/06/2022
3	Compaction	Yes		Gerti Qamili	16/06/2022
4	Final Pipe Test	Yes		Gerti Qamili	16/06/2022
5	Other	No		Gerti Qamili	16/06/2022

Final Sign-Off

#	Check Item	Signature	Date	Comment
1	HBPLC Sign-off	G.Qamili (Harringtons Builders) 16/06/2022 09:46:18	16/06/2022	
2	Client Sign-off	C.Taylor (ISG) 16/06/2022 14:17:22		

Post-Construction

1. Ensure all pipes are clean and clear of any construction debris.
2. Issue handover certificate to the client once all post-construction activities are completed, (as-built survey, CCTV survey, snagging and NCR close-out).

Comments

Third Party Sign-Off (Optional)

#	Check Item	Signature	Date	Comment
1	Third Party Sign-Off			