

Final Report

Report No.:	18-26478-1		
Initial Date of Issue:	06-Sep-2018		
Client	Apex Contracting		
Client Address:	191 Fengate Peterborough Northamptonshire PE1 5BH		
Contact(s):	Luke Boekestyn		
Project	Horton Road		
Quotation No.:		Date Received:	04-Sep-2018
Order No.:		Date Instructed:	04-Sep-2018
No. of Samples:	3		
Turnaround (Wkdays):	2	Results Due:	05-Sep-2018
Date Approved:	06-Sep-2018		
Approved By:			
Details:	Glynn Harvey, Laboratory Manager		

Bulk Identification Certificate

Client: Apex Contracting
Site Address:
Date Sampled: 28-Aug-2018
Date Received: 04-Sep-2018

Your Ref.:
Project: Horton Road
Job Number: 18-26478
No Samples:
Date Reported: 06-Sep-2018

Sample No.	Sample ID	Sample Ref.	Description	SOP	Accred.	Laboratory	Material	Result
681445	Slab A1			2185	U	COVENTRY	Cement	Chrysotile Crocidolite
681446	Slab A2			2185	U	COVENTRY	Cement	Chrysotile Crocidolite
681447	Slab A3			2185	U	COVENTRY	Cement	Chrysotile Crocidolite

The in-house procedure SOP2185 is in accordance with the requirements of Appendix 2 of the Analyst Guide (HSG 248).

The results relate only to items tested as supplied by the client.

Comments and interpretations are beyond the scope of UKAS accreditation.

Samples associated with asbestos in building surveys are retained for six months (HSG 264 refers)

SOP	Title	Parameters included	Method summary
2185	Asbestos	Asbestos	Polarised light microscopy

Report Information

Key

- U UKAS accredited
- M MCERTS and UKAS accredited
- N Unaccredited
- S This analysis has been subcontracted to a UKAS accredited laboratory that is accredited for this analysis
- SN This analysis has been subcontracted to a UKAS accredited laboratory that is not accredited for this analysis
- T This analysis has been subcontracted to an unaccredited laboratory
- I/S Insufficient Sample
- U/S Unsuitable Sample
- N/E not evaluated
- < "less than"
- > "greater than"

Comments or interpretations are beyond the scope of UKAS accreditation

The results relate only to the items tested

Uncertainty of measurement for the determinands tested are available upon request

None of the results in this report have been recovery corrected

All results are expressed on a dry weight basis

The following tests were analysed on samples as received and the results subsequently corrected to a dry weight basis TPH, BTEX, VOCs, SVOCs, PCBs, Phenols

For all other tests the samples were dried at < 37°C prior to analysis

All Asbestos testing is performed at the indicated laboratory

Issue numbers are sequential starting with 1 all subsequent reports are incremented by 1

Sample Deviation Codes

- A - Date of sampling not supplied
- B - Sample age exceeds stability time (sampling to extraction)
- C - Sample not received in appropriate containers
- D - Broken Container
- E - Insufficient Sample (Applies to LOI in Trommel Fines Only)

Sample Retention and Disposal

All soil samples will be retained for a period of 45 days from the date of receipt

All water samples will be retained for 14 days from the date of receipt

Charges may apply to extended sample storage

If you require extended retention of samples, please email your requirements to:

customerservices@chemtest.com