



7th July 2025

Michael Briginshaw
Deputy Team Leader
North Area Planning Team
Hillingdon Council

RE: Merck Sharpe Dohme
Ref: (72870/APP/2025/1095)

Michael,

Please see responses below regarding recommendation and requests from LLFA .

Demonstrate calculation which include Area 2.

This has been included on pages 52 to 62 of the revised report

Provide Maintenance tasks for filter drains, swales and water tanks.

Maintenance schedule has been revised to suit.

Evidence of consent to watercourse

This report needs to be issued to the relevant people in the Council.

Provide greenfield, existing and proposed runoffs for 1 in 100 year 6 hour storm event.

This has been included on pages 28 to 30 of the revised report

Design Return Period	Storm Duration	Greenfield Runoff Rate (l/s)	Existing Runoff Rate (l/s)	Proposed Runoff Rate (l/s)
1 in 1 year	6 hours	20.0 l/s	27.3 l/s	34.6 l/s
1 in 30 year	6 hours	51.2 l/s	64.5 l/s	77.0 l/s
1 in 100 year	6 hours	69.5 l/s	81.9 l/s	93.9 l/s

COYLE KENNEDY
Consulting Engineers

Third Floor
GW Business Centre
Great West House
Great West Road
Brentford TW8 9DF
England

Tel: +44 (0)203 393 1174
Fax: +44 (0)203 004 1234

website: www.coylekennedy.com
email: mail@coylekennedy.com

Irish Office:
GFSC
Moncenageisha Road
Galway
Ireland

Tel: +353 (0)91 752000
Fax: +353 (0)91 753000

Coyle Kennedy Limited
Registered in Ireland 346183

Directors:
Brian Coyle BE CEng MIEI MInstuctE
Tadhg Kennedy BE MEngSc CEng MIEI MInstuctE



236

Yours Sincerely,

Senan Pyne

COYLE KENNEDY
Consulting Engineers