

Notes:  
 1. All drawings to be read in conjunction with all drawings relevant to project.

2. Do not scale from drawings, any discrepancy should be notified immediately.

3. Glazing:  
 Outer - 8mm Satinova Toughened  
 Cavity - 16mm Argon  
 Inner - 8.8mm Clear Laminated  
 'Low E'

4. Aluminium to be P.P.C RAL Colour  
 RAL -

5. All Rafters, Head And Cill Transoms To Be 105mm, Midspan Transoms To Be 100mm

6. All Rooflights Require a minimum 5° slope, if you require anything less please consult our head office.

7. The upstand is to be built and fully weathered by others.  
 The upstand **must** be built to the sizes shown in this drawing. Failure to do so could result in improper fitment and incur costs due to additional visits to site.

8. Rooflight to Achieve a TN66/67 Non Fragility Rating.

REV No	DESCRIPTION	OWN	CHMD	DATE	APR
--------	-------------	-----	------	------	-----



Naturalight Systems Ltd  
 Accessory House  
 Barrington Industrial Estate  
 Bedlington  
 Northumberland  
 NE22 7DQ  
 Tel: (01670) 530333  
 Fax: (01670) 824540  
 info@Naturalight.co.uk  
 www.Naturalight.co.uk



Project:  
 Brunel University

Description:  
 Dual-Pitch - Plan View

Drawn By: N.G	Checked By: N/A	Approved By: N/A
------------------	--------------------	---------------------

Date Drawn: 11.07.2023	Job Number: 35130	Scale: See DWG
---------------------------	----------------------	-------------------

Drawing No.:  
 NLS-35130-CD-001

Direction Of Fall @ 23°




Direction Of Fall @ 51°



Plan View

Scale: 1:20 @ A3



Flush Silicone Joint  
 At Transom Location

All Aluminium Flashings PPC To  
 Match Framework Colour - **TBC**

Glazing:  
 Outer - 8mm Satinova Toughened  
 Cavity - 16mm Argon  
 Inner - 8.8mm Clear Laminated  
 'Low E'

