

Co-op Funeralcare
940-942 Uxbridge Road
Hayes
Greater London
UB4 0RL

Plant Noise Impact Assessment Report

On behalf of



Project Reference: 90469 | Revision: - | Date: 17th May 2022

T: 01252 519881
W: noisesolutions.co.uk
E: hello@noisesolutions.co.uk

Noise Solutions Ltd, Unit 5, Oriel Court, Omega Park, Alton, GU34 2YT Reg no. 3483481



Document Information

Project Name : Co-op Funeralcare, 940-942 Uxbridge Road, Hayes
Project Reference : 90469
Report Title : Plant Noise Impact Assessment
Doc Reference : 90469/NIA
Date : 17th May 2022

| | Name | Qualifications | Initials | Date |
|---|------------------------|-------------------|----------|---------------------------|
| Prepared by: | Kartikeyan Subramaniam | MEng(Hons), AMIOA | KS | 17 th May 2022 |
| Reviewed and approved by: | Nigel Chandler | BSc(Hons), MIOA | NAC | 20 th May 2022 |
| For and on behalf of Noise Solutions Ltd | | | | |

| Revision | Date | Description | Prepared | Reviewed/Approved |
|----------|------|-------------|----------|-------------------|
| | | | | |
| | | | | |

Noise Solutions Ltd (NSL) disclaims any responsibility to the Client and others in respect of any matters outside the scope of this report. This report has been prepared with reasonable skill, care and diligence within the terms of the Contract with the Client and generally in accordance with the appropriate ACE Agreement and taking account of the manpower, resources, investigations and testing devoted to it by agreement with the Client. This report is confidential to the Client and NSL (Noise Solutions Ltd) accepts no responsibility of whatsoever nature to third parties to whom this report or any part thereof is made known. Any such party relies upon the report at their own risk.

© Noise Solutions Ltd (NSL) 2022

Reg no. 3483481 Trading office Unit 5, Oriel Court, Omega Park, Alton, Hampshire, GU34 2YT

Contents

| | | |
|------------|--|----------|
| 1.0 | Introduction | 1 |
| 2.0 | Details of development proposals..... | 1 |
| 3.0 | Nearest noise-sensitive receptors..... | 1 |
| 4.0 | Existing noise climate | 2 |
| 5.0 | Noise assessment criteria | 3 |
| | London Borough of Hillingdon | 3 |
| | National Planning Policy Framework | 4 |
| | BS 4142:2014 Methods for rating and assessing industrial and commercial sound..... | 5 |
| | Summary of criteria | 7 |
| 6.0 | Plant noise impact assessment..... | 7 |
| | Context and uncertainties..... | 8 |
| 7.0 | Summary | 8 |

Appendices

| | |
|------------|--|
| Appendix A | Acoustic terminology |
| Appendix B | Photograph of site showing areas of interest |
| Appendix C | Proposed site and layout drawings |
| Appendix D | Environmental sound survey |
| Appendix E | Plant information and manufacturer published sound pressure levels |
| Appendix F | Plant noise calculations |

Executive Summary

Noise Solutions Limited has undertaken a plant noise impact assessment to assess new plant serving the Co-operative Funeralcare on Uxbridge Road, Hayes.

To control noise from the new plant to meet local authority requirements, attenuation will be required as outlined below and described within this report:

- Both extract and supply systems to be fitted with suitable attenuators.

1.0 Introduction

- 1.1. Noise Solutions Ltd (NSL) has been commissioned by Co-operative to undertake a noise assessment for new ventilation plant serving the Co-op Funeralcare at Uxbridge Rd in Hayes.
- 1.2. An environmental sound survey has been undertaken to establish the prevailing background sound levels at a location representative of the sound levels outside the nearest noise sensitive receptors to the site.
- 1.3. Cumulative plant noise emissions for the proposed plant have been predicted at the nearest noise-sensitive receptors and assessed against the requirements of the local authority.
- 1.4. To assist with the understanding of this report a glossary of acoustic terms can be found in [Appendix A](#). An in-depth glossary of acoustic terms can be viewed online at www.acoustic-glossary.co.uk.

2.0 Details of development proposals

- 2.1. The Co-op Funeralcare occupies the ground floor unit of 940-942 Uxbridge Rd. New ventilation plant is proposed to be installed to replace the existing plant on site. The plant will comprise of two centrifugal extract fans for the supply intake (SF) and the extract (EF) systems. All the ventilation fans will be located internally.
- 2.2. The supply intake is located at the flat roof on the first-floor level on the roof of the building. The extract fans duct terminates vertically at the first-floor level to rear of the building.
- 2.3. The proposed extract and supply intake systems may operate between 07.00 and 23.00 hours daily whilst the Funeralcare office is open and will be switched off outside these hours.
- 2.4. The site layout plans, and locations of the proposed plant are shown in [Appendix C](#). Noise data for the proposed plant is presented in [Appendix E](#).

3.0 Nearest noise-sensitive receptors

- 3.1. The surrounding area is a mix of commercial and residential in use.
- 3.2. The nearest and potentially most affected receptor will be the residential flats (Receptor R1) above the Funeralcare premises. Windows of Receptor R1 are approximately 9m from the supply intake and extract fan termination.
- 3.3. An aerial photograph showing the site and surrounding area is provided in [Appendix B](#).

4.0 Existing noise climate


4.1. An environmental noise survey was undertaken to establish the typical background sound levels. Measurements were made at a location representative of the noise climate outside the façades of the nearest noise sensitive receptors to the proposed plant during the quietest times at which the plant will operate.

4.2. The results of the survey are summarised below. The full set of measurement results and details of the survey methodology are presented in [Appendix D](#).

Table 1 Summary of survey results

| Measurement period | Range of recorded sound pressure levels (dB) | | | |
|----------------------------------|--|--------------------|-------------------|-------------------|
| | $L_{Aeq(15mins)}$ | $L_{Amax(15mins)}$ | $L_{A10(15mins)}$ | $L_{A90(15mins)}$ |
| Daytime (07.00 – 23.00 hours) | 53-68 | 69-96 | 55-67 | 41-51 |
| Night-time (23.00 – 07.00 hours) | 42-58 | 59-79 | 44-61 | 36-48 |

Figure 1 Histogram of operating hours L_{A90} background sound pressure levels




4.3. Further statistical analysis has been carried out on the data, and the mean, mode and median values are shown in Table 2 below.

Table 2 Statistical analysis of $L_{A90,15min}$ levels during the daytime period

| dB, L_{A90} daytime period | |
|------------------------------|----|
| mean | 46 |
| modal | 47 |
| median | 47 |

4.4. In order to be robust, the recorded value of 42dB has been selected to be representative of the background sound level in this area during operational hours.

Figure 2 Histogram of non-operating hours L_{A90} background sound pressure levels



4.5. Further statistical analysis has been carried out on the data and the mean, mode and median values are shown in Table 3 below.

Table 3 Statistical analysis of $L_{A90,15min}$ levels during the night-time period

| dB, L_{A90} night-time period | |
|---------------------------------|----|
| mean | 41 |
| modal | 37 |
| median | 41 |

4.6. In order to be robust, the recorded value of 37dB has been selected to be representative of the background sound level in this area during operational hours.

4.7. Therefore, the following values are considered representative of the existing background sound pressure levels at nearby noise sensitive premises:

- 42dB L_{A90} during the daytime period; and
- 37dB L_{A90} during the night-time period.

5.0 Noise assessment criteria

London Borough of Hillingdon

5.1. The London Boroughs of Hillingdon, Hounslow and Richmond Upon Thames adopted a Supplementary Planning Document relating to noise generating development in July 2014. Section 6.0 of the document states:

The Boroughs recognise the contribution of industrial and commercial developments in helping to achieve wider sustainable development goals. However, there are many kinds of industrial and commercial developments that have the potential to generate noise. In

the Boroughs some of the most commonly occurring noise issues with commercial developments are associated with building services plant, usually air-conditioning equipment or kitchen extraction systems. In addition to plant noise, noise associated with deliveries or collections and an increase in traffic noise levels may also impact on local residents.

5.2. For industrial and commercial development, the following criteria are to be applied:

Figure 3. Table 2 in Supplementary Planning Document

Table 2: New Industrial and Commercial Development - External Noise Standards

| Noise Impact From Relevant Proposed Industrial Or Commercial Premises Or Plant | Development Outcome |
|--|---|
| Rating Level (LAr,Tr) is at least 5 dB(A) below the Background Level LA90 | Normally acceptable |
| Rating level (LAr,Tr) is no more than 5 dB(A) above the Background Level LA90 | Acceptable only if there are overriding economic or social reasons for development to proceed |
| Rating level (LAr,Tr) is more than 5 dB(A) above the Background Level LA90 | Normally unacceptable |

Note: All terms as defined in BS4142

National Planning Policy Framework

5.3. A new edition of NPPF was published in July 2021 and came into effect immediately. The original National Planning Policy Framework (NPPF¹) was published in March 2012, with revisions in July 2018 and February 2019 - this document replaced the existing Planning Policy Guidance Note 24 (PPG 24) "Planning and Noise." The 2021 revised edition contains no new directions or guidance with respect to noise, and hence, all previous references remain extant. The paragraph references quoted below relate to the July 2021 edition.

5.4. Paragraph 174 of the NPPF states that the planning system should contribute to and enhance the natural and local environment by (amongst others) *"preventing both new and existing development from contributing to or being put at unacceptable risk from, or being adversely affected by unacceptable levels of soil, water or noise pollution or land stability."*

5.5. The NPPF goes on to state in Paragraph 185:

"planning policies and decisions should ...

a) *Mitigate and reduce to a minimum potential adverse impacts resulting from noise from new development, - and avoid noise giving rise to significant adverse impacts on health and quality of life;*

¹ National Planning Policy Framework, DCLG, March 2012

b) *identify and protect tranquil areas which have remained relatively undisturbed by noise and are prized for their recreational and amenity value for this reason ...*

5.6. The NPPF document does not refer to any other documents or British Standards regarding noise other than the Noise Policy Statement for England (NPSE²).

5.7. Paragraph 2 of the NPPF states that *"planning law requires that applications for planning permission must be determined in accordance with the development plan unless material considerations indicate otherwise."*

5.8. Paragraph 12 of the NPPF states that *"The presumption in favour of sustainable development does not change the statutory status of the development plan as the starting point for decision making. Where a planning application conflicts with an up-to-date development plan (including any neighbourhood plans that form part of the development plan), permission should not usually be granted. Local planning authorities may take decisions that depart from an up-to-date development plan, but only if material considerations in a particular case indicate that the plan should not be followed".*

5.9. Paragraph 119 states that *"Planning policies and decisions should promote an effective use of land in meeting the need for homes and other uses, while safeguarding and improving the environment and ensuring safe and healthy living conditions. Strategic policies should set out a clear strategy for accommodating objectively assessed needs, in a way that makes as much use as possible of previously-developed or 'brownfield' land".*

BS 4142:2014 Methods for rating and assessing industrial and commercial sound

5.10. BS 4142:2014 is intended to be used to assess the likely effects of sound on people residing in nearby dwellings. The scope of BS 4142:2014 includes *"sound from fixed plant installations which comprise mechanical and electrical plant and equipment"*.

5.11. The procedure contained in BS 4142:2014 is to quantify the *"specific sound level"*, which is the measured or predicted level of sound from the source in question over a one-hour period for the daytime and a 15-minute period for the night-time. Daytime is defined in the standard as 07:00 to 23:00 hours, and night-time as 23:00 to 07:00 hours.

5.12. The specific sound level is converted to a rating level by adding penalties on a sliding scale to account for either potentially tonal or impulsive elements. The standard sets out objective methods for determining the presence of tones or impulsive elements but notes that it is acceptable to subjectively determine these effects.

² Noise Policy Statement for England, DEFRA, March 2010

5.13. The penalty for tonal elements is between 0dB and 6dB, and the standard notes: *"Subjectively, this can be converted to a penalty of 2 dB for a tone which is just perceptible at the noise receptor, 4 dB where it is clearly perceptible, and 6 dB where it is highly perceptible."*

5.14. The penalty for impulsive elements is between 0dB and 9dB, and the standard notes: *"Subjectively, this can be converted to a penalty of 3 dB for impulsivity which is just perceptible at the noise receptor, 6 dB where it is clearly perceptible, and 9 dB where it is highly perceptible."*

5.15. The assessment outcome results from a comparison of the rating level with the background sound level. The standard states:

- *Typically, the greater this difference, the greater the magnitude of the impact.*
- *A difference of around +10 dB or more is likely to be an indication of a significant adverse impact, depending on the context;*
- *A difference of around +5 dB is likely to be an indication of an adverse impact, depending on the context;*
- *The lower the rating level is relative to the measured background sound level, the less likely it is that the specific sound source will have an adverse impact or a significant adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact, depending on the context.*

5.16. The standard does state that *"adverse impacts include, but are not limited to, annoyance and sleep disturbance. Not all adverse impacts will lead to complaints and not every complaint is proof of an adverse impact."*

5.17. The standard goes on to note that: *"Where background sound levels and rating levels are low, absolute levels might be as, or more, relevant than the margin by which the rating level exceeds the background. This is especially true at night."*

5.18. In addition to the margin by which the Rating Level of the specific sound source exceeds the Background Sound Level, the 2014 edition places emphasis upon an appreciation of the context, as follows:

"An effective assessment cannot be conducted without an understanding of the reason(s) for the assessment and the context in which the sound occurs/will occur. When making assessments and arriving at decisions, therefore, it is essential to place the sound in context."

5.19. BS 4142:2014 requires uncertainties in the assessment to be considered, and where the uncertainty is likely to affect the outcome of the assessment, steps should be taken to reduce the uncertainty.

Summary of criteria

5.20. Based on London Borough of Hillingdon's typical requirements, it is considered appropriate that the cumulative plant noise rating level of proposed plant should be controlled to a level that does not exceed 5dB below the representative L_{A90} background sound level at the nearest residential property. Noise from the new plant should therefore not exceed the limits shown in the table below:

Table 4 Plant noise emissions limits at receptor

| Receptor | Period | Cumulative plant rating level, dB(A) |
|------------------|----------------------------------|--------------------------------------|
| R1 (Residential) | Daytime (07.00 – 23.00 hours) | 37 |
| | Night-time (23.00 – 07.00 hours) | 32 |

6.0 Plant noise impact assessment

6.1. Cumulative noise emissions from the new proposed plant have been predicted at the nearest residential properties to the site based on the noise output information shown in [Appendix E](#).

6.2. Noise levels for the proposed fans have been predicted taking into account ductwork system losses, aperture size, directivity of sound propagation, screening and distance attenuation. Predictions are inclusive of atmospheric-side attenuation fitted to the ventilation systems as detailed in Table 5.

Table 5: Proposed atmospheric side attenuators to ventilation systems

| Attenuator | Insertion losses dB, at octave band centre frequencies (Hz) | | | | | | | |
|--------------|---|-------|-------|-------|------|------|------|------|
| | 63Hz | 125Hz | 250Hz | 500Hz | 1kHz | 2kHz | 4kHz | 8kHz |
| SF (Intake) | 6 | 12 | 24 | 38 | 45 | 42 | 38 | 29 |
| EF (Extract) | 6 | 12 | 24 | 38 | 45 | 42 | 38 | 29 |

6.3. The predictions during operating hours have been based on the proposed plant operating simultaneously at full capacity. It has been assumed that all plant items will operate only during the hours when the Funeralcare is open.

6.4. It should be noted that the proposed plant is not anticipated to exhibit any tonal or impulsive characteristics providing it is well maintained. All proposed external plant will be inverter driven and, therefore, will gently ramp up and down depending on the demands on the various systems. To be robust, however, a +3dB feature correction as advised in BS 4142:2014 has been applied for the possible presence of "...characteristics that are neither tonal nor impulsive, though otherwise are readily distinctive against the residual acoustic environment...".

6.5. Table 6 below summarises the assessment of predicted noise rating levels. The full set of calculations is presented in [Appendix F](#).

Table 6: Assessment of predicted noise levels at the nearest noise sensitive receptors

| Receptor | Period | Predicted rating level 1m from receptor, L_{Aeq} (dB) | Design criterion (dB) | Difference (dB) |
|-------------|----------------------------------|---|-----------------------|-----------------|
| Receptor R1 | Daytime (07.00 – 01.00 hours) | 34 | 37 | -3 |
| | Night-time (07.00 – 23.00 hours) | n/a* | 32 | n/a |

**Plant is switched off during the night-time period*

6.6. External noise level predictions demonstrate that cumulative noise emissions from the proposed plant meet the proposed criteria given in Table 4 of this report and, therefore, should comply with the criteria typically set by London Borough of Hillingdon Council, providing the specified attenuators are installed.

Context and uncertainties

6.7. Where possible uncertainty in the above assessments has been minimised by taking the following steps:

- Uncertainty in the calculated impacts has been reduced by the use of a well-established calculation method.

6.8. As BS 4142:2014 advises, the impact must be considered within the context of the site and the surrounding acoustic environment. The following must, therefore, also be taken into consideration when determining the potential impact that may be experienced:

- The assessment is undertaken at the nearest noise sensitive windows. The impact on all other nearby windows will be lower due to screening and distance attenuation.
- It should be noted that the above assessment is based on all plant operating at maximum duty. The resulting impact will be lower when plant is operating at a reduced duty (i.e. when the heating/cooling demand of the Funeralcare is reduced).

6.9. Given the results of the above assessment, cumulative noise emissions from fixed plant can be considered of 'low impact' in accordance with BS 4142:2014 methodology.

7.0 Summary

7.1. Noise Solutions Ltd (NSL) has been commissioned by Co-operative to undertake a noise assessment for new ventilation plant serving the Co-op Funeralcare at Uxbridge Rd in Hayes.

- 7.2. The cumulative plant noise emission levels for the proposed plant have been predicted at the most affected noise sensitive receptor and assessed against typical noise criteria from the local authority.

- 7.3. The results of the assessment indicate that, when attenuated as described in this report, the plant will comply with the proposed criteria. Noise should therefore not be a reason for refusal of planning permission.

Appendix A Acoustic terminology


| Parameter | Description |
|---------------------|---|
| Ambient Noise Level | The totally encompassing sound in a given situation at a given time, usually composed of a sound from many sources both distant and near ($L_{Aeq,T}$). |
| Decibel (dB) | A scale for comparing the ratios of two quantities, including sound pressure and sound power. The difference in level between two sounds s_1 and s_2 is given by $20 \log_{10} (s_1/s_2)$. The decibel can also be used to measure absolute quantities by specifying a reference value that fixes one point on the scale. For sound pressure, the reference value is $20\mu\text{Pa}$. The threshold of normal hearing is in the region of 0 dB and 140 dB is the threshold of pain. A change of 1 dB is only perceptible under controlled conditions. |
| $dB(A)$, L_{A_x} | Decibels measured on a sound level meter incorporating a frequency weighting (A weighting) which differentiates between sounds of different frequency (pitch) in a similar way to the human ear. Measurements in $dB(A)$ broadly agree with people's assessment of loudness. A change of 3 $dB(A)$ is the minimum perceptible under normal conditions, and a change of 10 $dB(A)$ corresponds roughly to halving or doubling the loudness of a sound. The background noise in a living room may be about 30 $dB(A)$; normal conversation about 60 $dB(A)$ at 1 metre; heavy road traffic about 80 $dB(A)$ at 10 metres; the level near a pneumatic drill about 100 $dB(A)$. |
| Fast Time Weighting | Setting on sound level meter, denoted by a subscript F, that determines the speed at which the instrument responds to changes in the amplitude of any measured signal. The fast time weighting can lead to higher values than the slow time weighting when rapidly changing signals are measured. The average time constant for the fast response setting is 0.125 (1/8) seconds. |
| Free-field | Sound pressure level measured outside, far away from reflecting surfaces (except the ground), usually taken to mean at least 3.5 metres |
| Façade | Sound pressure level measured at a distance of 1 metre in front of a large sound reflecting object such as a building façade. |
| $L_{Aeq,T}$ | A noise level index called the equivalent continuous noise level over the time period T. This is the level of a notional steady sound that would contain the same amount of sound energy as the actual, possibly fluctuating, sound that was recorded. |
| $L_{max,T}$ | A noise level index defined as the maximum noise level recorded during a noise event with a period T. L_{max} is sometimes used for the assessment of occasional loud noises, which may have little effect on the overall L_{eq} noise level but will still affect the noise environment. Unless described otherwise, it is measured using the 'fast' sound level meter response. |
| $L_{10,T}$ | A noise level index. The noise level exceeded for 10% of the time over the period T. L_{10} can be considered to be the "average maximum" noise level. Generally used to describe road traffic noise. $L_{A10,18h}$ is the A-weighted arithmetic average of the 18 hourly $L_{A10,1h}$ values from 06:00-24:00. |
| $L_{90,T}$ | A noise level index. The noise level that is exceeded for 90% of the measurement time interval, T. It gives an indication of the lower levels of fluctuating noise. It is often used to describe the background noise level and can be considered to be the "average minimum" noise level and is a term used to describe the level to which non-specific noise falls during quiet spells, when there is lull in passing traffic for example. |

Appendix B Photograph of site showing areas of interest



Photograph 1 Courtesy of Google Earth

Appendix C Proposed site and layout drawings



Appendix D Environmental sound survey

Details of environmental sound survey

D.1 Measurements of the existing background sound levels were undertaken between 16.45 hours on Wednesday 23 March and 10.00 hours on Thursday 24 March 2022.

D.2 The sound level meter was programmed to record the A-weighted L_{eq} , L_{90} , L_{10} and L_{max} noise indices for consecutive fifteen-minute sample periods for the duration of the survey.

Measurement position

D.3 The sound level meter was positioned on a lamppost on Gledwood Drive. The approximate location of the microphone is indicated on the plan in [Appendix B](#).

D.4 In accordance with BS 7445-2:1991 '*Description and measurement of environmental noise – Part 2: Guide to the acquisition of data pertinent to land use*', the measurements were undertaken under free-field conditions.

Equipment


D.5 Details of the equipment used during the survey are provided in the table below. The sound level meter was calibrated before and after the survey; no significant change (+/-0.2 dB) in the calibration level was noted.

Environmental noise survey

| Description | Model / serial no. | Calibration date | Calibration certificate no. |
|---------------------------|---------------------------|------------------|-----------------------------|
| Class 1 Sound level meter | Svantek 977 / 36190 | | |
| Condenser microphone | ACO Pacific 7052E / 74975 | 25/05/2021 | 1500077-1 |
| Preamplifier | Svantek SV12L / 10325 | | |
| Calibrator | Svantek SV33A / 73430 | 08/07/2021 | 1500622-1 |

Weather conditions

D.6 Weather conditions were determined both at the start and on completion of the survey. It is considered that the meteorological conditions were appropriate for environmental noise measurements. The table below presents the weather conditions recorded on site at the beginning and end of the survey.


| Weather Conditions | | | | |
|--|-------------------------------------|--|---------------------|---------------|
| Measurement Location | Date/Time | Description | Beginning of Survey | End of Survey |
| As indicated on Appendix B | 16.45 23 Mar - 10.00 24 Mar 2022 | Temperature (°C) | 19 | 16 |
| | | Precipitation: | No | No |
| | | Cloud cover (oktas - see guide) | 1 | 0 |
| Cloud Cover Symbol Scale in oktas (eighths)  0 Sky completely clear 1 2 3 4 Sky half cloudy 5 6 7 8 Sky completely cloudy (9) Sky obstructed from view | | Presence of fog/snow/ice | No | No |
| | | Presence of damp roads/wet ground | No | No |
| | | Wind Speed (m/s) | 0.3 | 0.3 |
| | | Wind Direction | SE | SE |
| | | Conditions that may cause temperature inversion (i.e. calm nights with no cloud) | No | No |

Results

D.7 The results of the environmental survey are considered to be representative of the background sound pressure levels at the façades of the nearest noise sensitive receptors during the quietest times at which the plant will operate.

D.8 The predominant noise source affecting the area at the start and end of the survey was light traffic noise.

Co-op Funeralcare, Uxbridge Rd, Hayes
Wednesday 23 - Thursday 24 Mar 2022



Appendix E Plant information and manufacturer published sound pressure levels

| Ref | Make / Model | | Sound Power Level. dB @ octave band centre frequency, Hz | | | | | | | |
|-----|---------------------------------|-----------------|--|-----|-----|-----|----|----|----|----|
| | | | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k |
| SF | Auto Extract Systems / FB-075-3 | In-duct intake | 53 | 76 | 82 | 89 | 90 | 86 | 79 | 70 |
| EF | Auto Extract Systems / FB-075-3 | In-duct exhaust | 53 | 76 | 82 | 89 | 90 | 86 | 79 | 70 |

Appendix F Plant noise calculations

Summary

| Plant | Resultant at Receptor (dBA) |
|-------|-----------------------------|
| | R1 |
| SF | 28 |
| EF | 28 |

| | |
|--|-----------|
| Operational Hours (07.00-23.00 Hours) | R1 |
| Cumulative | 31 |
| BS 4142:2014 feature correction | 3 |
| BS 4142:2014 rating level | 34 |
| Target | 37 |
| Excess | -3 |

Supply Intake Fan (SF)

| Description |
|---|
| Source noise level (unattenuated) |
| System losses |
| Atmospheric side attenuator |
| Sound power level leaving terminal |

| Notes. | Sound level (dB) at octave band centre frequencies (Hz) | | | | | | | | dBA |
|---------------|---|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| In-duct L_w | 53 | 76 | 82 | 89 | 90 | 86 | 79 | 70 | 93 |
| | -12 | -8 | -4 | -3 | -3 | -4 | -5 | -5 | |
| I.L. | -6 | -12 | -24 | -38 | -45 | -42 | -38 | -29 | |
| | 35 | 56 | 54 | 48 | 42 | 40 | 36 | 36 | 50 |

| Receptor R1 | V angle | H angle | 200 x 600 (0,0) | | 1 | 2 | 3 | 4 | 5 | 6 | 6 | 6 | | |
|---------------------------------|-----------|---------|-----------------|----|----------|----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| Directivity correction | 0 | 0 | 200 x 600 (0,0) | | 1 | 2 | 3 | 4 | 5 | 6 | 6 | 6 | | |
| Distance correction | 9 | m | 9 m | | -27 | -27 | -27 | -27 | -27 | -27 | -27 | -27 | | |
| Screening correction | Screened: | 0 | $\delta =$ | -9 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | | |
| Surface corrections etc | | | | | | | | | | | | | | |
| Resultant at Receptor R1 | | | | | L_p | 9 | 31 | 30 | 25 | 20 | 19 | 15 | 15 | 28 |

Extract Termination (EF)

| Description |
|---|
| Source noise level (unattenuated) |
| System losses |
| Atmospheric side attenuator |
| Sound power level leaving terminal |

| Notes. | Sound level (dB) at octave band centre frequencies (Hz) | | | | | | | | dBA |
|---------------|---|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| In-duct L_w | 53 | 76 | 82 | 89 | 90 | 86 | 79 | 70 | 93 |
| | -13 | -9 | -5 | -3 | -3 | -3 | -3 | -3 | |
| I.L. | -6 | -12 | -24 | -38 | -45 | -42 | -38 | -29 | |
| | 34 | 55 | 53 | 48 | 42 | 41 | 38 | 38 | 50 |

| Receptor R1 | V angle | H angle | 200 x 600 (0,0) | | 1 | 2 | 3 | 4 | 5 | 6 | 6 | 6 | | |
|---------------------------------|-----------|------------|-----------------|----------|----------|----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| Directivity correction | 0 | 0 | 200 x 600 (0,0) | | 1 | 2 | 3 | 4 | 5 | 6 | 6 | 6 | | |
| Distance correction | 9 | m | 9 m | | -27 | -27 | -27 | -27 | -27 | -27 | -27 | -27 | | |
| Screening correction | Screened: | $\delta =$ | -9 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | | |
| Surface corrections etc | | | | | | | | | | | | | | |
| Resultant at Receptor R1 | | | | | L_p | 8 | 30 | 29 | 25 | 20 | 20 | 17 | 17 | 28 |