



## Air Quality Statement 3

LBH Response

Block 4, Union Park

July 2025



## Air Quality Statement 3

Block 4, Union Park

July 2025

HDR Consulting Limited UK

204 West George Street  
Glasgow  
G2 2PQ

Document Control:

Project no.	Project
13528D	Block 4, Union Park

Report No.	Ver/rev	Written By:	Checked by:	Authorised by:	Date
13528D	Rev0 Draft	R. Boakes	J. Ferguson-Moore	J. Ferguson-Moore	26/06/2025
	V1				09/07/2025

These appendices have been prepared for the exclusive use of the commissioning party and may not be reproduced without prior written permission from Phlorum Limited.

All work has been carried out within the terms of the brief using all reasonable skill, care and diligence.

No liability is accepted by Phlorum for the accuracy of data or opinions provided by others in the preparation of these appendices, or for any use of these appendices other than for the purpose for which they were produced.

### Phlorum Limited

Southern Office: Unit 12, Hunns Mere Way, Woodingdean, Brighton, East Sussex, BN2 6AH

T: 01273 307 167 E: [info@phlorum.com](mailto:info@phlorum.com) W: [www.phlorum.com](http://www.phlorum.com)

## LBH Response

---

In March 2025, Phlorum prepared an Environmental Statement (ES) Chapter (*Chapter 6 Air Quality*) for the development of a fourth data centre block (UP4) at the Union Park Data Centre Campus in Hayes (UB3 4QQ). The planning application (Ref: 75111/APP/2025/739) was submitted to the London Borough of Hillingdon (LBH) on the 18<sup>th</sup> of March 2025.

The London Borough of Hillingdon (LBH) has provided an initial comment to the Air Quality Chapter and its associated Appendices<sup>1</sup>, with the following request:

*"The Air Quality Officer is unable to finalise the damage cost calculations as the testing regime time has not been provided - only the total figures have been submitted. Please can you send these over? We would also be grateful if you could provide the generator (gen set) data sheet specifications as soon as possible."*

In response to this request, Phlorum confirms that all of the information requested by the Air Quality Officer has already been provided in either ES Chapter 6 or Appendix 6.

### Testing Regime Information

Within ES Chapter 6, Table 6.4 details the predicted emission rates associated with each component of the testing regime, and highlights what these testing scenarios are. For ease, Table 6.4 is replicated below.

**Table 6.4 Time-Weighted Pollutant Emission Rates for UP3 and UP4**

Generator Scenario	Scenario Details	Pollutant	Emission Rate (g.s <sup>-1</sup> )
Monthly Testing	Generators run simultaneously off-load for 15 minutes.	NO <sub>x</sub>	0.209
		PM <sub>10</sub>	0.005
		PM <sub>2.5</sub>	0.005
Quarterly Testing	Generators run simultaneously at 80% load for an hour.	NO <sub>x</sub>	1.473
		PM <sub>10</sub>	0.021
		PM <sub>2.5</sub>	0.021
Annual Testing	Generators run independently at 100% load for 2 hours.	NO <sub>x</sub>	1.214
		PM <sub>10</sub>	0.018
		PM <sub>2.5</sub>	0.018

---

<sup>1</sup> Phlorum (March 2025). Appendix 6: Air Quality – Block 4, Union Park.

For clarity, the annual test supersedes the requirement for one of the quarterly tests. The one annual and three remaining quarterly tests supersede the requirement for four monthly tests. In total, there are eight monthly tests, three quarterly tests and one annual test per annum.

In Appendix 6.4, Table A6.4.4 provides all the numerical inputs required to determine the total annual emissions from the standby generators. For convenience, this table is replicated below. The duration of each test and the total hours of each test per annum are both provided in this table. To be clear, the engine loads differ in Table A6.4.4 to those in Table 6.4 because the specification sheet does not provide emissions data at 0% and 80% loads.

**Table A6.4.4: Generator Emission Calculation Inputs**

Parameter	Monthly Testing	Quarterly Testing	Annual Testing	Grid Failure
<b>Fuel Type<sup>a</sup></b>	Diesel	Diesel	Diesel	Diesel
<b>No. of Generators</b>	14	14	14	12
<b>Engine Load (%)</b>	10%	75%	100%	100%
<b>Unabated NOx emission rate (g/s)</b>	0.837	4.064	6.063	6.063
<b>NOx emission rate with SCR (g/s)</b>	0.033	0.178	0.244	0.244
<b>PM2.5 emission rate (g/s)<sup>b</sup></b>	0.005	0.021	0.018	0.018
<b>Duration of each test +1.1% (hrs)<sup>c</sup></b>	0.253	1.011	2.022	2.022
<b>Hours of operation per annum +1.1% (hrs)<sup>c</sup></b>	2.022	3.033	2.022	2.022
<b>Total NO<sub>x</sub> emissions (g/annum)<sup>d</sup></b>	85266.5	73545.4	36200.3	31028.8
<b>Total NO<sub>x</sub> emissions (tonnes/annum)</b>	0.08527	0.07355	0.03620	0.03101
<b>Total NO<sub>x</sub> emissions on HVO Fuel (tonnes/annum)<sup>e</sup></b>	<b>0.07802</b>	<b>0.06729</b>	<b>0.03312</b>	<b>0.02839</b>
<b>Total PM<sub>2.5</sub> emissions (g/annum)</b>	468.497	3159.173	1872.291	1604.821
<b>Total PM<sub>2.5</sub> emissions (tonnes/annum)</b>	0.0004685	0.0031592	0.0018723	0.0016048
<b>Total PM<sub>2.5</sub> emissions on HVO Fuel (tonnes/annum)<sup>e</sup></b>	<b>0.0004006</b>	<b>0.0027011</b>	<b>0.0016008</b>	<b>0.0013721</b>

Notes:

a) all generators are anticipated to run on Hydrotreated Vegetable Oil (HVO) fuel

b) assumes 100% of all PM emitted from the generators is PM<sub>2.5</sub>, which is extremely conservative

c) planned annual maintenance was recorded by the Applicant to take on average 1.1% longer than anticipated due to problems identified during testing, so all test durations account for this additional period

d) assumes emissions will be unabated for the first 20 minutes of each test, which is 5 minutes longer than is realistically anticipated

e) For the adjacent permitted Data Centres (App Ref: 75111/APP/2022), LBH agreed that HVO fuels would reduce NO<sub>x</sub> emissions by 8.5% and PM<sub>2.5</sub> emissions by 14.5%, compared with diesel.

## Generator Data Sheet Specifications

Appendix 6.3 provides details of the pollutant dispersion modelling inputs used for the assessment of the standby generators, beyond the information already provided in the main ES Chapter 6. Within this Appendix 6.3 are screenshots showing the data sheet specifications for the standby generators (i.e. MTU 20V4000 G94LF). These are replicated below, for completeness.

Revision					
Change Index					

### Motordaten

#### engine data

	Genset	Marine	O & G	Rail	C & I
Application	x				
Engine model	20V4000G94LF				
Application group	3D				
Emission Stage/Optimisation	NEA Singapore for ORDE				
Test cycle	D2				
fuel sulphur content [ppm]	7				
mg/mN <sup>3</sup> values base on residual oxygen value of [%]	measured				

### Motor Röhremissionen\*

#### Engine raw emissions\*

Cycle point	[·]	n1	n2	n3	n4	n5	n6	n7	n8
Power (P/PN)	[·]	1	0,75	0,50	0,25	0,10			
Power	[kW]	3307	2480	1653	827	331			
Speed (n/nN)	[·]	1	1	1	1	1			
Speed	[rpm]	1500	1499	1499	1500	1499			
Exhaust temperature after turbine	[°C]	482	427	434	403	268			
Exhaust massflow	[kg/h]	19196	15930	12083	7485	5323			
Exhaust back pressure (total)	[mbar]	52	32	14	5	0			
NOx	[g/kWh]	6,6	5,9	4,8	4,4	9,1			
	[mg/mN <sup>3</sup> ]	1641	1326	930	676	776			
CO	[g/kWh]	0,3	0,4	1,0	1,4	2,8			
	[mg/mN <sup>3</sup> ]	77	85	192	219	233			
HC	[g/kWh]	0,05	0,07	0,09	0,16	0,72			
	[mg/mN <sup>3</sup> ]	13	14	18	25	60			
O2	[%]	9,9	11,2	11,9	13,1	15,8			
Particulate measured	[g/kWh]	0,02	0,03	0,10	0,18	0,05			
	[mg/mN <sup>3</sup> ]	5	6	19	27	4			
Particulate calculated	[g/kWh]	-	-	-	-	-			
	[mg/mN <sup>3</sup> ]	-	-	-	-	-			
Dust (only TA-Luft)	[mg/mN <sup>3</sup> ]	-	-	-	-	-			
FSN	[·]	0,2	0,2	0,6	1,0	0,1			
NO/NO <sub>2</sub> **	[·]	-	-	-	-	-			
CO <sub>2</sub>	[g/kWh]	645,7	632,1	669,3	721,6	844,5			
	[mg/mN <sup>3</sup> ]	155278	136196	126261	109200	70577			
SO <sub>2</sub>	[g/kWh]	0,003	0,003	0,003	0,003	0,004			
	[mg/mN <sup>3</sup> ]	0,7	0,6	0,6	0,5	0,3			

\* Emission data measurement procedures are consistent with the respective emission evaluation process. Noncertified engines are measured to sales data (TVL/TECN) standard conditions.

These boundary conditions might not be representative for detailed dimensioning of exhaust gas aftertreatment, in this case it is recommended to contact the responsible department for more information.

Measurements are subject to variation. The nominal emission data shown is subject to instrumentation, measurement, facility, and engine-to-engine variations.

All data applies to an engine in new condition. Over extended operating time deterioration may occur which might have an impact on emission. Exhaust temperature depends on engine ambient conditions.

\*\* No standard test. To be measured on demand.

**Motordaten**

engine data

	<b>Genset</b>	<b>Marine</b>	<b>O &amp; G</b>	<b>Rail</b>	<b>C &amp; I</b>
Application	X				
Engine model	20V4000G94LF				
Application group	3D				
Emission Stage/Optimisation	NEA Singapore for ORDE				
Test cycle	D2				
fuel sulphur content [ppm]	7				
mg/m <sup>3</sup> values base on residual oxygen value of [%]	5				

**Motor Rohemissionen\***

Engine raw emissions\*

Cycle point	[·]	n1	n2	n3	n4	n5	n6	n7	n8
Power (P/PN)	[·]	1	0,75	0,50	0,25	0,10			
Power	[kW]	3307	2480	1653	827	331			
Speed (n/nN)	[·]	1	1	1	1	1			
Speed	[rpm]	1500	1499	1499	1500	1499			
Exhaust temperature after turbine	[°C]	482	427	434	403	268			
Exhaust massflow	[kg/h]	19196	15930	12083	7485	5323			
Exhaust back pressure (total)	[mbar]	52	32	14	5	0			
NOx	[g/kWh]	6,6	5,9	4,8	4,4	9,1			
	[mg/m <sup>3</sup> ]	2362	2172	1639	1375	2411			
CO	[g/kWh]	0,3	0,4	1,0	1,4	2,8			
	[mg/m <sup>3</sup> ]	111	139	339	445	723			
HC	[g/kWh]	0,05	0,07	0,09	0,16	0,72			
	[mg/m <sup>3</sup> ]	19	23	29	50	187			
O2	[%]	5,0	5,0	5,0	5,0	5,0			
Particulate measured	[g/kWh]	0,02	0,03	0,10	0,18	0,05			
	[mg/m <sup>3</sup> ]	7	10	33	55	13			
Particulate calculated	[g/kWh]	-	-	-	-	-			
	[mg/m <sup>3</sup> ]	-	-	-	-	-			
Dust (only TA-Luft)	[mg/m <sup>3</sup> ]	-	-	-	-	-			
FSN	[·]	0,2	0,2	0,6	1,0	0,1			
NO/NO <sub>2</sub> **	[·]	-	-	-	-	-			
CO <sub>2</sub>	[g/kWh]	645,7	632,1	669,3	721,6	844,5			
	[mg/m <sup>3</sup> ]	223605	223061	222522	222035	219215			
SO <sub>2</sub>	[g/kWh]	0,003	0,003	0,003	0,003	0,004			
	[mg/m <sup>3</sup> ]	1,0	1,0	1,0	1,0	1,0			

\* Emission data measurement procedures are consistent with the respective emission evaluation process. Noncertified engines are measured to sales data (TVU/TEN) standard conditions.

These boundary conditions might not be representative for detailed dimensioning of exhaust gas aftertreatment, in this case it is recommended to contact the responsible department for more information.

Measurements are subject to variation. The nominal emission data shown is subject to instrumentation, measurement, facility, and engine-to-engine variations.

All data applies to an engine in new condition. Over extended operating time deterioration may occur which might have an impact on emission. Exhaust temperature depends on engine ambient conditions.

\*\* No standard test. To be measured on demand.

Aenderungsbeschreibung/Description of Revision Kommt von/Frequency

Angabe Sauerstoffgehalt im Abgas bei Bezug auf 5% angepasst

All rights reserved. Schutzrechtsvermerkungen vorbehalten. Weitergabe, Veröffentlichung oder sonstige Verwendung ohne Zustimmung nicht gestattet. Zuverleihvermerkungen verbieten aus Schutzrechtsgründen.

mtu	mtu	mtu	WORD	Datum/ Date	Name	Projekt-Nutzungs-Nr. Project/Order No. Verwendbarer Typ Applicable to Model		Formatseite A3			
						Material-Nr./Material No.	EDS 4000 1162				
				Erstellt: Drawn: 09-09-17	zwillers			Benennung/ Title <b>EDS 4000 1162</b> <b>Emissionsdatenblatt</b> <b>Emission Data Sheet</b>			
				Bearb. Change: 13:37:26	zwillers						
				Inhalt Content: 10-04-2017	Locher						
				Gepr. Checked: 20-09-2017	Kneffel						
				Motortyp / Engine Type: 20V4000G94LF							
				Zzeichnungs-Nr./Drawing No. <b>ZNG00005084</b>							
								Blatt/ Sheet <b>5</b> vor/ of <b>6</b>			
Aenderungs-Nr./Revision No.	Kommt von/Frequency	Bearbeitungsstatus/Workcycle									
5.1		In Arbeit									

Pos. 2	CATALYST	SCR-700/1-A-S816.45-50-A48.7.5-10-DK
--------	----------	--------------------------------------



### general data

Engine:	MTU 20V4000G94LF
Fuel:	Diesel
Operation of engine:	$\lambda > 1$
Exhaust gas mass flow:	19196 kg/h
Exhaust gas temperature:	475 °C
Maximum Exhaust gas temperature:	505 °C
Maximum Exhaust gas pressure:	0,1 barg
Pressure Los (total):	45 mbar
Urea consumption (32,5%):	appr. 52,3 L/h
Urea consumption (32,5%):	appr. 10 at 200h m³/a
sound pressure level at SCR inlet *	91 @ 1 m dB(A)
sound pressure level after SCR *	70 @ 1 m dB(A)

\*only achieved when honeycombs are built in the SCR.

### Emissions [5% O<sub>2</sub>]

	Before Catalytic Converter	After Catalytic Converter	
CO	< 111	< 111	mg/Nm <sup>3</sup>
NOx	< 2362	< 95	mg/Nm <sup>3</sup>
CH <sub>2</sub> O	< 19	< 19	mg/Nm <sup>3</sup>
NH <sub>3</sub>		< 5	mg/Nm <sup>3</sup>

### Equipment SCR

#### SCR

Number of rows SCR	5	pc.
Number of empty rows	0	pc.

#### Oxi

Number of rows Oxi	1	pc.
Number of empty rows	0	pc.

### Material

Material injection	Stainless steel
Material flanges injection	Stainless steel
Material housing	Steel
Material flanges housing	Steel

### Installation and connection

Place of installation	Inside installation; no ex zone
	Outdoor installation by arrangement
Min. ambient temperature	5 °C
Max. ambient temperature	40 °C
Exhaustgas piping inlet	700/10 DN/PN
Exhaustgas piping outlet	800/10 DN/PN



## Phlorum Limited

### Head Office & Registered Office:

Unit 12

Hunns Mere Way

Woodingdean

Brighton

East Sussex

BN2 6AH

**T:** 01273 307 167

### Western Office:

One Caspian Point

Pierhead Street

Cardiff Bay

Cardiff

CF10 4DQ

**T:** 029 2092 0820

[info@phlorum.com](mailto:info@phlorum.com)

[www.phlorum.com](http://www.phlorum.com)

Registered in England & Wales. Reg No. 4967256