



Ref: MDR/J5651a

11th July 2024

KRS Steel Services Ltd

Unit 6 Meadway Industrial Estate

429 Meadway

Kitts Green

Birmingham

B33 0DX

For the attention of Mr A Marsh

Dear Sirs

Re: Pepe's Piri Piri, 3 Byron Place, Uxbridge, UX10 0LZ - Proposed Kitchen Supply & Extract Ventilation Systems - External Noise Assessment

Further to the receipt of your ventilation design information, we are pleased to forward our noise assessment for the proposed kitchen supply & extract ventilation systems as follows:-

We visited the site on 9/7/24 to inspect the proposed location for the proposed ventilation systems. The nearest residential windows to the proposed supply intake and extract discharge positions are 1st floor windows on the rear of the building. The extract discharge & supply intake on the rear façade will be approximately 4m from the nearest window. The intended operation times for the site are from 11.00hrs to 23.00hrs. At 22.30hrs on the rear access flat roof area to the 1st floor flats, 1m in front of the 1st floor residential windows, the background noise level was 44.0dB LA₉₀ 30min; a level primarily created by traffic noise in the locality.



Ref: MDR/J5651a

The instrumentation used for the noise measurements was a Rion NL-52 precision grade real time analysing sound level meter, serial number 00231668. The instrument was calibration checked before and after the measurements and seen to be calibrated correctly. Please see the attached current certificate of calibration. The noise measurements were undertaken in satisfactory weather condition, with no significant wind or precipitation.

The design criteria we advise to be applied to the proposed ventilation systems external noise to be measured at 4m distance from the extract discharge and 4m distance from the supply intake, as a combined noise level, is to be at least 10dB below the prevailing background $LA_{90,t}$ values measured on 9/7/24, equating to no more than 34dBA at the nearest windows. BS4142:2014 assessment methodology compares the background noise level with a plant rating noise level. For this site, the noise- controlled ventilation systems will have no distinct tonal characteristics or intermittency which would require correction to the plant source noise to derive a rating level. Controlling the proposed plant noise sources to be at least 10dBA below background ensures no adverse addition to the background noise level outside the nearest residential windows.

For the proposed kitchen extract ventilation system, the fan discharge silencer advised would be a splitter silencer, 20% free area, typically 750mm wide x 750mm high x 2400mm long. The silencer should reduce the radiated discharge noise to approximately 29dBA at 4m distance.

For the proposed kitchen supply air ventilation system, the fan intake silencer would be a circular 5silencer with pod, typically 355mm i/d x 510mm o/d x 315mm long. The silencer should reduce the radiated intake noise to 31dBA at 4m distance.

The combined noise level of the extract discharge at 4m & supply intake at 4m equates to 33dBA.

In addition, the fans and ductwork systems should be supported off the building structure using anti-vibration mounts/hangers to avoid vibration transmission into the structure.



Ref: MDR/J5621a

We have attached our noise level design calculation sheets and supporting information for your reference.

We trust the noise assessment meets with your approval and we remain.

Yours faithfully

M D Randall BSc(Eng) CEng MCIBSE MIOA





CERTIFICATE OF CALIBRATION



0653

Date of Issue: 09 January 2024

Calibrated at & Certificate issued by:

ANV Measurement Systems
Beaufort Court
17 Roebuck Way
Milton Keynes MK5 8HL
Telephone 01908 642846 Fax 01908 642814
E-Mail: info@noise-and-vibration.co.uk
Web: www.noise-and-vibration.co.uk
Acoustics Noise and Vibration Ltd trading as ANV Measurement Systems

Certificate Number: UCRT24/1042

Page 1 of 2 Pages
Approved Signatory

K. Mistry

Customer ANV Measurement Systems
Beaufort Court
17 Roebuck Way
Milton Keynes
MK5 8HL

Order No.	ANV MS HIRE			
Description	Sound Level Meter / Pre-amp / Microphone / Associated Calibrator			
Identification	Manufacturer	Instrument	Type	Serial No. / Version
	Rion	Sound Level Meter	NL-52	00231668
	Rion	Firmware		2.0
	Rion	Pre Amplifier	NH-25	21612
	Rion	Microphone	UC-59	04713
	Rion	Calibrator	NC-75	34334830
			Calibrator adaptor type if applicable	NC-75-022
Performance Class	1			
Test Procedure	TP 2.SLM 61672-3 TPS-49 <i>Procedures from IEC 61672-3:2006 were used to perform the periodic tests.</i>			
Type Approved to IEC 61672-1:2002	YES	Approval Number	21.21 / 13.02	
	<i>If YES above there is public evidence that the SLM has successfully completed the applicable pattern evaluation tests of IEC 61672-2:2003</i>			
Date Received	05 January 2024 ANV Job No. UKAS24/01009			
Date Calibrated	09 January 2024			

The sound level meter submitted for testing has successfully completed the class 1 periodic tests of IEC 61672-3:2006, for the environmental conditions under which the tests were performed. As public evidence was available, from an independent testing organisation responsible for approving the results of pattern evaluation tests performed in accordance with IEC 61672-2:2003, to demonstrate that the model of sound level meter fully conformed to the requirements in IEC 61672-1:2002, the sound level meter submitted for testing conforms to the class 1 requirements of IEC 61672-1:2002.

Previous Certificate	Dated	Certificate No.	Laboratory
	24 January 2023	UCRT23/1113	0653

This certificate is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to the SI system of units and/or to units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.



CERTIFICATE OF CALIBRATION

Certificate Number

UCRT24/1042

UKAS Accredited Calibration Laboratory No. 0653

Page 2 of 2 Pages

Sound Level Meter Instruction manual and data used to adjust the sound levels indicated.

SLM instruction manual title	Sound Level Meter	NL-42 / NL-52
SLM instruction manual ref / issue	11-03	
SLM instruction manual source	Manufacturer	
Internet download date if applicable	N/A	
Case corrections available	Yes	
Uncertainties of case corrections	Yes	
Source of case data	Manufacturer	
Wind screen corrections available	Yes	
Uncertainties of wind screen corrections	Yes	
Source of wind screen data	Manufacturer	
Mic pressure to free field corrections	Yes	
Uncertainties of Mic to F.F. corrections	Yes	
Source of Mic to F.F. corrections	Manufacturer	
Total expanded uncertainties within the requirements of IEC 61672-1:2002	Yes	
Specified or equivalent Calibrator	Specified	
Customer or Lab Calibrator	Lab Calibrator	
Calibrator adaptor type if applicable	NC-75-022	
Calibrator cal. date	18 December 2023	
Calibrator cert. number	UCRT23/2596	
Calibrator cal cert issued by	0653	
Calibrator SPL @ STP	94.01	dB
Calibrator frequency	1000.00	Hz
Reference level range	25 - 130	dB

Accessories used or corrected for during calibration - Extension Cable & Wind Shield WS-15

Note - if a pre-amp extension cable is listed then it was used between the SLM and the pre-amp.

Environmental conditions during tests	Start	End	
Temperature	22.26	22.33	± 0.30 °C
Humidity	32.8	33.7	± 3.00 %RH
Ambient Pressure	102.21	102.22	± 0.03 kPa

Response to associated Calibrator at the environmental conditions above.

Initial indicated level	94.0	dB	Adjusted indicated level	94.0	dB
The uncertainty of the associated calibrator supplied with the sound level meter ±				0.10	dB

Self Generated Noise This test is currently not performed by this Lab.

Microphone installed (if requested by customer) = Less Than N/A dB A Weighting

Uncertainty of the microphone installed self generated noise ± N/A dB

Microphone replaced with electrical input device - UR = Under Range indicated

Weighting	A	C	Z
	11.9 dB	UR	17.1 dB

Uncertainty of the electrical self generated noise ± 0.12 dB

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor $k=2$, providing a coverage probability of approximately 95%. The uncertainty evaluation has been carried out in accordance with UKAS requirements.

For the test of the frequency weightings as per paragraph 12. of IEC 61672-3:2006 the actual microphone free field response was used.

The acoustical frequency tests of a frequency weighting as per paragraph 11 of IEC 61672-3:2006 were carried out using an electrostatic actuator.

END

Calibrated by: C. Hirlev

R 3

Additional Comments The results on this certificate only relate to the items calibrated as identified above.


None




Ref: MDR/FS651



Ref: Mary/JS651



LOG: WORK/JSGS1



Ref: MDR/FS651



Design Smart(1)

Pop6's UxBRIDGE, UX100LZ - EXTRACT DISCHARGES Noise

Ref: WWR/JSGS1



Design Sheet 2

Popps (UXBRIDGE, UX10 0LZ) — SUPPLY / INTAKE NOISE

	LIA	63	125	250	500	1k	2k	4k	8k
SUPPLY FAN BETA SEL									
3SS/2-1A2 SWL	/	47	64	70	75	71	71	64	
315Ø Duct 1m	/	0	0	0	0	0	0	0	
FILTER	/	3	3	3	3	3	3	3	
800 SoundBono	/	0	1	8	7	4	3	3	
INTAKE 800x600 0.46m ² Gr	/	2	0	0	0	0	0	0	
SWL @ INTAKE	/	42	60	59	65	67	65	59	
SWL → SPL @ 4m	/	20	20	20	20	20	20	20	
HEMISPHERICAL RADIATION									
SPL @ 4m	/	22	40	39	45	47	45	38	
'A' WEIGHTING	/	-16	-9	-3	0	+1	+1	-1	
	/	6	31	36	45	48	46	37	
		31	46	50	50	50	50	37	
		46	50						
									51dB(A) 10
SILVERGRAN LOQUACON									
CPS 315-10 CIRCULAR	/	7	18	14	22	25	22	19	
SILVERGRAN 315mm Ø, 315mm ^{1/2}	/	0	23	22	23	23	24	18	
× 605mm ^{1/2} × 315mm LONG			23		26		27	18	
					28		28		
* RESULTANT SPL @ 4m WITH SILENT						31dB(A) 10			
* COMBINED SUPPLY INTAKE @ 4m 31						31dB(A) 10			
* EXTRACT DISCHARGE @ 4m 29						29			

Ref: Wm/JSGS



Woods Air Movement
Fan Selector - Technical Datasheet



Project :
Quotation :

Customer :

Project Code :
Date : Wednesday, June 26, 2024



PowerBox3

Powerbox3 80-630-3

Lead time may vary based on stock availability at time of order. Please refresh the lead time in the project or reselect the fan before placing an order.

PRODUCT

Model Code Powerbox3 80-630-3

Fan Diameter 630 mm

Installation Type D

PERFORMANCE

Requested Duty 2.10 m³/s @ 930 Pa (Static)

Outlet Dynamic Pressure 11.0 Pa

Velocity 4.29 m/s

MOTOR

Motor Rating 4.64 kW [Integral Frame]

Full Load Current 8.47 A

Starting Current 8.47 A

Electrical Supply 380 - 415 Volts 50 Hz 3 Phase

Motor Winding Standard

Motor Type Class F Insulation

EFFICIENCY GRADES

Regulation 1253 - 2014

UVU Efficiency 51.6% (ErP Compliant) ✓

Nominal Flow Rate 2.44 m³/s @ 753 Pa

Effective Input Power 3.56 kW

Nominal RPM 1250 rpm

ENVIRONMENT

Air Density 1.2 kg/m³ / 20 °C / 0 m / 40% RH

Smoke Venting No Smoke Venting

Operating Environment Normal

RUNNING COSTS

Power from mains 3.58 kW


Energy Consumption 7,152.97 kWh [2,000.00 h/Year]

Running Cost / Year £1,788.24

CO₂ per Year 2,514.70 kgCO₂e

SFP value 1.70 W/l/s @ Actual Duty

PRODUCT DIMENSIONS



This drawing shows dimensions that should be used as a guide only and are subject to change. Certified drawings are available on request.

MECHANICAL

Operating Temperatures -20 °C to 50 °C (95% Max Relative Humidity)


Weight 114kg

COMMENTS

Lang_PowerBoxInverter

FAN PERFORMANCE CURVE

— 1318 rpm ○ Requested ● Actual



ACOUSTICS

Sound Spectrum (Hz) Overall Distance (3 m)

63 125 250 500 1k 2k 4k 8k Lw* LwA* LpA @ 3 m **

Inlet 94 99 90 84 85 86 83 79 101 92 71

Outlet 95 105 89 87 86 86 85 82 106 94 74

Breakout 80 91 79 61 57 55 55 48 92 77 56

Sound Data At Requested Duty, * Lw dB re 10⁻² W, ** dBA re 2x10⁻⁵ Pa

FAN & ACCESSORIES

Item Description	Qty
Powerbox3 80-630-3	1

Axial Way
Colchester Essex CO4 5DZ
+44 (0) 1206 222 555
UK

Copyright Fläkt Woods Limited t/a Woods Air Movement (UK) 2003 - 2024
Version 14/6/2024 Rev.35274 (19/6/2024 Rev.1 PRODUCTION)

EXTRACT FAN
POP? MORE/LESS



Multiflow SEL

Performance, SFP & Electrical Data

AC

SINGLE Phase - 220V to 240V / 50Hz

Product Image	Product Code	Speed r/min	Airflow SFP	Airflow m³ / s @ static Pressure Pa												At Best Efficiency Point			Peak Amps	dBA @ 3m	
				0	25	50	75	100	150	200	250	300	350	400	500	Overall Efficiency %	FMEG	Input kW			
 	SEL250/2-1AC	2684	m³ / s	0.453	0.442	0.431	0.419	0.407	0.380	0.350	0.313	0.108	0.064	0.031		46.9	65.7	0.162	0.70	Inlet 51 Outlet 53 Breakout 29	
	SEL315/2B-1AC	2776	m³ / s	0.975	0.963	0.951	0.938	0.924	0.894	0.862	0.828	0.791	0.750	0.703	0.230		52.7	66.2	0.515	2.40	Inlet 55 Outlet 61 Breakout 40
	SEL315/2A-1AC	2819	m³ / s	0.654	0.644	0.633	0.621	0.608	0.579	0.545	0.506	0.459	0.388	0.150	0.057		50.8	67.4	0.263	1.20	Inlet 54 Outlet 58 Breakout 37
	SEL355/2-1AC	2776	m³ / s	1.372	1.358	1.344	1.330	1.315	1.283	1.250	1.215	1.177	1.137	1.093	0.988		50.5	61.2	0.955	4.30	Inlet 59 Outlet 63 Breakout 42
	SEL355/4-1AC	1438	m³ / s	0.714	0.691	0.663	0.629	0.590	0.484	0.488	0.030						46.8	66	0.150	0.70	Inlet 43 Outlet 45 Breakout 26
	SEL400/4-1AC	1440	m³ / s	0.957	0.930	0.900	0.866	0.825	0.700	0.287	0.135	0.053					45.8	63.4	0.211	0.90	Inlet 39 Outlet 53 Breakout 39
	SEL450/4-1AC	1435	m³ / s	1.445	1.414	1.380	1.345	1.307	1.223	1.119	0.950	0.265	0.159	0.063			50.0	64.2	0.445	2.40	Inlet 50 Outlet 55 Breakout 34
	SEL500/4-1AC	1352	m³ / s	1.950	1.902	1.857	1.814	1.772	1.685	1.591	1.479	1.315	0.343	0.196			48.7	60.5	0.747	3.30	Inlet 54 Outlet 55 Breakout 46
	SEL560/4-1AC	1401	m³ / s	2.645	2.610	2.571	2.530	2.485	2.380	2.253	2.094	1.883	1.491	0.693	0.339		49.0	59.3	1.035	5.50	Inlet 61 Outlet 64 Breakout 54
	SEL630/4-1AC	1371	m³ / s	3.887	3.831	3.775	3.717	3.660	3.544	3.425	3.304	3.176	3.039	2.887	2.447		55.3	62.3	2.140	9.60	Inlet 62 Outlet 64 Breakout 53
			W / (L/s)	0.33	0.34	0.35	0.37	0.38	0.42	0.47	0.52	1.14	2.07	4.48							
			W / (L/s)	0.50	0.51	0.52	0.53	0.54	0.57	0.60	0.63	0.67	0.71	0.76	1.66						
			W / (L/s)	0.39	0.40	0.40	0.42	0.43	0.46	0.50	0.55	0.60	0.66	1.36	4.03						
			W / (L/s)	0.64	0.65	0.66	0.67	0.68	0.70	0.73	0.77	0.81	0.85	0.89	0.99						
			W / (L/s)	0.20	0.21	0.22	0.24	0.26	0.31	1.28	4.60										

Data in accordance with ErP Directive 327/2011 of the European Parliament. Peak Amps @ 230V / 1PH / 50Hz.
The overall A-weighted sound pressure level is at a distance of 3m with spherical free-field propagation. It is expressed in dB re-20µPa and is presented for comparative purposes only.

Supply Fan SCL 355/2-1AC

RGS: Mon/15/2011

Elta Fans Limited has a policy of continuous product development and improvement and therefore reserves the right to supply products which may differ from those illustrated and described in this publication. Confirmation of dimensions and data will be supplied on request.

Tel: 01384 275800 Fax: 01384 275810 Email: bs@eltafans.co.uk Visit: eltaselect.com Twitter: @eltaselect & @eltafans

3



Multiflow SEL

Sound Data

SINGLE Phase - 220V to 240V / 50Hz

Product Code		Sound Power Level dBW @ Octave Band Hz								Total dB
		63Hz	125Hz	250Hz	500Hz	1 kHz	2 kHz	4 kHz	8 kHz	
SEL250/2-1AC	Inlet	-	36	47	57	63	66	67	56	70
	Outlet	-	41	57	63	69	69	65	54	74
	Breakout	-	36	35	34	45	44	41	35	49
SEL315/2B-1AC	Inlet	-	48	64	69	70	70	69	66	76
	Outlet	-	50	70	75	78	75	71	65	81
	Breakout	-	46	50	52	57	54	53	46	61
SEL315/2A-1AC	Inlet	-	49	83	68	70	69	66	57	75
	Outlet	-	50	69	73	75	73	66	58	79
	Breakout	-	44	46	49	53	51	49	45	57
SEL355/2-1AC	Inlet	-	47	64	70	76	74	71	64	79
	Outlet	-	54	70	76	80	77	72	64	83
	Breakout	-	45	55	55	58	56	55	45	63
SEL355/4-1AC	Inlet	-	44	55	58	60	57	55	44	64
	Outlet	-	54	56	62	63	57	53	41	67
	Breakout	-	42	39	40	43	39	39	25	48
SEL400/4-1AC	Inlet	-	49	56	67	64	63	57	47	70
	Outlet	-	61	60	71	70	65	60	50	75
	Breakout	-	48	44	58	57	49	48	37	61
SEL450/4-1AC	Inlet	-	58	62	66	67	65	59	50	72
	Outlet	-	64	65	72	72	67	62	52	77
	Breakout	-	52	60	61	62	56	50	39	66
SEL500/4-1AC	Inlet	29	80	86	70	71	67	63	52	75
	Outlet	29	86	86	73	71	67	63	52	77
	Breakout	-	41	61	68	63	59	53	39	65
SEL560/4-1AC	Inlet	-	68	78	78	75	75	60	59	83
	Outlet	-	72	81	84	78	75	70	61	87
	Breakout	-	69	76	75	67	65	58	50	79
SEL630/4-1AC	Inlet	-	89	75	80	78	75	68	61	84
	Outlet	-	72	78	83	80	77	73	62	86
	Breakout	-	67	73	72	66	66	60	49	77

Data provided at standard air density of 1.2 kg/m³. Tests and preparation of the sound data have been carried out at operating point with the highest static efficiency. The Sound Power Level Spectra are in dB re-1pW.



Ref: MR/JS651

Please Note:
Why not use the facility in our "Fans by Elta" interactive CD Rom to do the work for you?
Tests and preparation of the sound data have been carried out in accordance with EN 160 3741:2011-01.
The Sound Power Level Spectra are in dB re-1pW.

Elta Fans Limited has a policy of continuous product development and improvement and therefore reserves the right to supply products which may differ from those illustrated and described in this publication. Confirmation of dimensions and data will be supplied on request.

Tel: 01384 275800 Fax: 01384 275810 Email: bs@eltafans.co.uk Visit: eltaselect.com Twitter: @eltaselect & @eltafans

4