



NOT FOR CONSTRUCTION

					HS2 accepts no responsibility for any circumstances which arise from the reproduction of this document after alteration, amendment or abbreviation or if it is issued in part or issued incompletely in any way.
					© Crown Copyright and database right 2018. All rights reserved. Ordnance Survey Licence number 100049190
					© Crown Copyright material is reproduced with the permission of Land Registry under delegated authority from the Controller of HMSO. This material was last updated on 2018 and may not be copied, distributed, sold or published without the formal permission of Land Registry. Only an official copy of a title plan or register obtained from the Land Registry may be used for legal or other official purposes.
P01	WRAP_Schedule 17 Re-Submission	AS	NP		
C01	WRAP_Schedule 17 Re-Submission	AS	NP	LN	
Rev	Description	Drawn	Checked	Con App	HS2 App
					Scale with caution as distortion can occur.

Legends/Notes:

- All dimensions are in millimetres unless noted otherwise.
- All levels are in metres relative to OD (Ordnance Datum, Newlyn) unless noted otherwise.
- Chainages are expressed in metres and measured from Euston Station.
- Global coordinates are indicated by Eastings (E) and Northings (N) to the project snake grid.
- All angles are in degrees (0° 360°) unless noted otherwise.
- Dimensions are not to be scaled from the drawing.
- The location of fencing is for approval.
- Background illumination at the head house and main gate operates dusk till dawn during periods of non-occupancy at the site. The target average illuminance in the lit areas is 5 lux.
- Maintenance illumination at the head house, hard standing, main gate and if required, the track access road, operates in hours of darkness during maintenance operations only. The target average illuminance in the lit areas is 10 lux.
- Security illumination at the head house, hard standing and main gate operates in hours of darkness upon detection of unauthorised access only. The target average illuminance in the lit areas is 20 lux, to support CCTV operations.

HS2
 Registered in England Registration No. 06791686
 Registered office: 2 Snow Hill, Queensway, Birmingham, B4 6GA

OFFICIAL

Creator/Originator
 SCS JV - Design House

Zone	West Ruislip Portal		Project/Contract	HS2-MWCC SCS Sector S2	
Design Stage	Detailed Design		Discipline/Function	Electrical	
Drawing Title	West Ruislip Portal MEP Engineering Drawing Schedule 17 Plans and Specifications Lighting Background Lux Levels		Drawn	Checked	Approved
			A.Sloan	N.Phelps	M.Gaby
			Date	Scale	Size
			20/12/19	1:500	A1
			Drawing No.	Rev.	
			1MC04-SCJ_SDH-EL-DGA-SS05_SL07-480110	C01	