



Project name

18 Pield Heath-Baseline

As designed

Date: Fri Apr 01 16:24:48 2022

Administrative information

Building Details

Address: London, UB8 3NF

Certification tool

Calculation engine: SBEM

Calculation engine version: v5.6.b.0

Interface to calculation engine: Virtual Environment

Interface to calculation engine version: v7.0.13

BRUKL compliance check version: v5.6.b.0

Certifier details

Name: SyntegraENG

Telephone number: 01184028520

Address: 63 Milford Rd, Reading, RG1 8LG

Criterion 1: The calculated CO₂ emission rate for the building must not exceed the target

CO ₂ emission rate from the notional building, kgCO ₂ /m ² .annum	40.4
Target CO ₂ emission rate (TER), kgCO ₂ /m ² .annum	40.4
Building CO ₂ emission rate (BER), kgCO ₂ /m ² .annum	40.2
Are emissions from the building less than or equal to the target?	BER =< TER
Are as built details the same as used in the BER calculations?	Separate submission

Criterion 2: The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Values which do not achieve the standards in the Non-Domestic Building Services Compliance Guide and Part L are displayed in red.

Building fabric

Element	U _a -Limit	U _a -Calc	U _i -Calc	Surface where the maximum value occurs*
Wall**	0.35	0.36	1.79	"FY000002_W17_A0"
Floor	0.25	0.22	0.22	"MN000000_F"
Roof	0.25	0.19	1.09	"LF000001_C_A0"
Windows***, roof windows, and rooflights	2.2	1.6	1.6	"SL000000_W4_O0"
Personnel doors	2.2	1.67	1.67	"ST000000_W3_O0"
Vehicle access & similar large doors	1.5	-	-	"No external vehicle access doors"
High usage entrance doors	3.5	-	-	"No external high usage entrance doors"

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]

U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]

U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]

* There might be more than one surface where the maximum U-value occurs.

** Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

*** Display windows and similar glazing are excluded from the U-value check.

N.B.: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

Air Permeability	Worst acceptable standard	This building
m ³ /(h.m ²) at 50 Pa	10	3

Building services

The standard values listed below are minimum values for efficiencies and maximum values for SFPs. Refer to the Non-Domestic Building Services Compliance Guide for details.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	YES
Whole building electric power factor achieved by power factor correction	<0.9

1- Gas Boiler

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	0.91	-	-	-	-
Standard value	0.91*	N/A	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					YES

* Standard shown is for gas single boiler systems <=2 MW output. For single boiler systems >2 MW or multi-boiler systems, (overall) limiting efficiency is 0.86. For any individual boiler in a multi-boiler system, limiting efficiency is 0.82.

1- SYST0000-DHW

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	Hot water provided by HVAC system	-
Standard value	N/A	N/A

Local mechanical ventilation, exhaust, and terminal units

ID	System type in Non-domestic Building Services Compliance Guide
A	Local supply or extract ventilation units serving a single area
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal supply and extract ventilation units serving a single room or zone with heating and heat recovery
E	Local supply and extract ventilation system serving a single area with heating and heat recovery
F	Other local ventilation units
G	Fan-assisted terminal VAV unit
H	Fan coil units
I	Zonal extract system where the fan is remote from the zone with grease filter

Zone name	SFP [W/(l/s)]										HR efficiency	
	ID of system type	A	B	C	D	E	F	G	H	I		
Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard	
Ass Bath	0.4	-	-	-	-	-	-	-	-	-	-	N/A
WC	0.4	-	-	-	-	-	-	-	-	-	-	N/A
Gf_Br 014	0.4	-	-	-	-	-	-	-	-	-	-	N/A
Gf_Br 015	0.4	-	-	-	-	-	-	-	-	-	-	N/A
GF_Br 016	0.4	-	-	-	-	-	-	-	-	-	-	N/A
GF_BR 017	0.4	-	-	-	-	-	-	-	-	-	-	N/A
Gf_BR018	0.4	-	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 019	0.4	-	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 020	0.4	-	-	-	-	-	-	-	-	-	-	N/A
Gf_BR021	0.4	-	-	-	-	-	-	-	-	-	-	N/A
WC	0.4	-	-	-	-	-	-	-	-	-	-	N/A
Assisted Bath	0.4	-	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 013	0.4	-	-	-	-	-	-	-	-	-	-	N/A
GF_BR 012	0.4	-	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 011	0.4	-	-	-	-	-	-	-	-	-	-	N/A

Zone name	SFP [W/(l/s)]									HR efficiency	
	A	B	C	D	E	F	G	H	I		
ID of system type	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
Gf_BR 01	0.4	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 02	0.4	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 03	0.4	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 04	0.4	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 05	0.4	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 06	0.4	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 07	0.4	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 08	0.4	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 010	0.4	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 09	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 022	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 023	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 024	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 025	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 026	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 027	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 028	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 031	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 030	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 033	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 034	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 035	0.4	-	-	-	-	-	-	-	-	-	N/A
1st f_Br 039	0.4	-	-	-	-	-	-	-	-	-	N/A
1st_Br 040	0.4	-	-	-	-	-	-	-	-	-	N/A
1st f_Br 041	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 042	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 043	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 044	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 045	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_Assisted Bath	0.4	-	-	-	-	-	-	-	-	-	N/A
1st f_BR 036	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR046	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 038	0.4	-	-	-	-	-	-	-	-	-	N/A
1st f_BR 037	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_WC	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 032	0.4	-	-	-	-	-	-	-	-	-	N/A
1st F_Assisted Bathroom	0.4	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 047	0.4	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 049	0.4	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 050	0.4	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 051	0.4	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 052	0.4	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 053	0.4	-	-	-	-	-	-	-	-	-	N/A

Zone name	SFP [W/(l/s)]									HR efficiency		
	A	B	C	D	E	F	G	H	I			
ID of system type	Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
2nd F_BR 055	0.4	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 054	0.4	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 056	0.4	-	-	-	-	-	-	-	-	-	N/A	
2nd F_Assisted Bathroom	0.4	-	-	-	-	-	-	-	-	-	N/A	
1st_BR 029	0.4	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 048	0.4	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 058	0.4	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 057	0.4	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 059	0.4	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 060	0.4	-	-	-	-	-	-	-	-	-	N/A	
WC	0.4	-	-	-	-	-	-	-	-	-	N/A	
WC	0.4	-	-	-	-	-	-	-	-	-	N/A	
WC	0.4	-	-	-	-	-	-	-	-	-	N/A	

General lighting and display lighting		Luminous efficacy [lm/W]				
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]	
Sluice	-	60	60	22		
Stairs	-	60	60	-	25	
Ass Bath	-	60	60	-	46	
Stairs	-	60	60	-	48	
Manager office	60	-	-	-	144	
Drugs Room	60	-	-	-	120	
Foyer GF 6	-	60	60	-	56	
Admin Room	60	-	-	-	206	
WC	-	60	60	-	21	
Foyer GF 4	-	60	60	-	109	
Gf_BED 014	-	60	60	-	66	
Gf_Br 014	-	60	60	-	24	
Gf_Br 015	-	60	60	-	24	
Gf_BED 015	-	60	60	-	65	
GF_Br 016	-	60	60	-	24	
GF_BED 016	-	60	60	-	65	
GF_BED 017	-	60	60	-	68	
GF_BR 017	-	60	60	-	26	
Gf_BR018	-	60	60	-	23	
Gf_BED 018	-	60	60	-	67	
Gf_BED 019	-	60	60	-	63	
Gf_BR 019	-	60	60	-	24	
Gf_BR 020	-	60	60	-	24	
Gf_BED 020	-	60	60	-	62	
Gf_BR021	-	60	60	-	25	
Gf_BED 021	-	60	60	-	59	

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
WC	-	60	60	22	19
Assisted Bath	-	60	60	-	59
LIFT	-	60	60	-	24
GF_Dining/ Lounge Room	-	60	60	-	304
Gf_BR 013	-	60	60	-	26
Gf_BED 013	-	60	60	-	61
Gf_BED 012	-	60	60	-	65
GF_BR 012	-	60	60	-	23
Gf_BED 011	-	60	60	-	65
Gf_BR 011	-	60	60	-	23
Gf_BED 01	-	60	60	-	65
Gf_BR 01	-	60	60	-	24
Gf_BR 02	-	60	60	-	24
Gf_BED 02	-	60	60	-	62
Gf_BR 03	-	60	60	-	24
Gf_BED 03	-	60	60	-	66
Gf_BR04	-	60	60	-	24
Gf_BED 04	-	60	60	-	65
Gf_BR 05	-	60	60	-	24
Gf_BED 05	-	60	60	-	65
Gf_BR 06	-	60	60	-	24
Gf_BED 06	-	60	60	-	63
Gf_BED 07	-	60	60	-	71
Gf_BR 07	-	60	60	-	24
Gf_BR 08	-	60	60	-	26
Gf_BED 08	-	60	60	-	66
Gf_BR 010	-	60	60	-	24
Gf_BED 010	-	60	60	-	63
Gf_BED 09	-	60	60	-	63
Gf_BR 09	-	60	60	-	24
Dining Room	-	60	60	-	187
Foyer GF 5	-	60	60	-	200
Foyer 1 & Sitting area	-	60	60	-	183
1st F_BED 022	-	60	60	-	65
1st F_BR 022	-	60	60	-	24
1st F_BR 023	-	60	60	-	24
1st F_BED 023	-	60	60	-	62
1st F_Sluice	-	60	60	-	31
1st F_BR 024	-	60	60	-	24
1st F_BED 024	-	60	60	-	66
1st F_BR 025	-	60	60	-	24
1st F_BED 025	-	60	60	-	65
1st F_BR 026	-	60	60	-	24

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
1st_BED 026	-	60	60	22	65
1st_F_BR 027	-	60	60	-	24
1st_F_BED 027	-	60	60	-	63
1st_F_BED 028	-	60	60	-	71
1st_F_BR 028	-	60	60	-	24
1st_F_BED 029	-	60	60	-	66
1st_F_Foyer 6	-	60	60	-	56
1st_F_Stairs	-	60	60	-	48
1st_F_BR 031	-	60	60	-	24
1st_F_BED 031	-	60	60	-	63
1st_F_BED 030	-	60	60	-	63
1st_F_BR 030	-	60	60	-	24
1st_F_Drugs Room	-	60	60	-	43
1st_F_BR 033	-	60	60	-	21
1st_F_BED 033	-	60	60	-	60
1st_F_Stairs case	-	60	60	-	46
Stairs and Main entrance	-	60	60	-	80
1st_F_dining room extension	-	60	60	-	39
1st_F_BR 034	-	60	60	-	25
1st_F_BED 034	-	60	60	-	60
1st_F_BED 035	-	60	60	-	60
1st_F_BR 035	-	60	60	-	25
1st_F_Foyer 1 & Sitting area	-	60	60	-	183
1ST_f_Stairs	-	60	60	-	48
1st_f_BED 039	-	60	60	-	66
1st_f_Br 039	-	60	60	-	24
1st_Br 040	-	60	60	-	24
1st_F_BED 040	-	60	60	-	65
1st_f_Br 041	-	60	60	-	24
1st_f_BED 041	-	60	60	-	65
1st_F_BED 042	-	60	60	-	68
1st_F_BR 042	-	60	60	-	26
1st_F_BR 043	-	60	60	-	23
1st_F_BED 043	-	60	60	-	67
1st_F_044	-	60	60	-	63
1st_F_BR 044	-	60	60	-	24
1st_F_BR 045	-	60	60	-	24
1st_F_BED 045	-	60	60	-	62
1st_F_Assisted Bath	-	60	60	-	59
1st_F_LIFT	-	60	60	-	24
1st_f_BR 036	-	60	60	-	23
1st_F_BR046	-	60	60	-	25
1st_F_BED 046	-	60	60	-	59

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
1st F_BR 038	-	60	60	22	
1st F_BED 038	-	60	60	-	61
1st f_BED 037	-	60	60	-	65
1st f_BED 036	-	60	60	-	65
1st f_BR 037	-	60	60	-	23
1st F_WC	-	60	60	-	30
Foyer 3	-	60	60	-	50
Foyer 2	-	60	60	-	35
1st F_BR 032	-	60	60	-	23
1st F_BED 032	-	60	60	-	62
1st F_Assisted Bathroom	-	60	60	-	47
1st F_Foyer 5	-	60	60	-	200
1st F_Foyer 4	-	60	60	-	38
1st F_Dning / Lounge room	-	60	60	-	382
1st F_Foyer 3	-	60	60	-	41
1st F_Store	60	-	-	-	53
2nd F_BED 047	-	60	60	-	65
2nd F_BR 047	-	60	60	-	24
2nd F_BED 048	-	60	60	-	62
1st F_Sluice (1)	-	60	60	-	31
2nd F_BR 049	-	60	60	-	24
2nd F_BED 049	-	60	60	-	66
2nd F_BR 050	-	60	60	-	24
2nd F_BED 050	-	60	60	-	65
2nd F_BR 051	-	60	60	-	24
2nd F_BED 051	-	60	60	-	65
2nd F_BR 052	-	60	60	-	24
2nd F_BED 052	-	60	60	-	63
2nd F_BED 053	-	60	60	-	71
2nd F_BR 053	-	60	60	-	24
1st F_Foyer 6 (1)	-	60	60	-	56
1st F_Stairs (1)	-	60	60	-	48
2nd F_BR 055	-	60	60	-	24
2nd F_BED 055	-	60	60	-	63
2nd F_BED 054	-	60	60	-	63
2nd F_BR 054	-	60	60	-	24
1st F_Stairs case (1)	-	60	60	-	46
2nd F_BR 056	-	60	60	-	23
2nd F_BED 056	-	60	60	-	62
2nd F_Assisted Bathroom	-	60	60	-	47
2nd F_Foyer 3	-	60	60	-	38
1st_BR 029	-	60	60	-	26
2nd F_Store	60	-	-	-	71

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
2nd F_BR 048	-	60	60	22	24
2nd F_Foyer 4	-	60	60	-	39
2nd F_Foyer 5	-	60	60	-	165
2nd F_Drugs Room	-	60	60	-	43
2nd F_BR 058	-	60	60	-	22
2nd F_BED 057	-	60	60	-	60
2nd F_BR 057	-	60	60	-	21
2nd F_BED 058	-	60	60	-	76
2nd F_BR 059	-	60	60	-	22
2nd F_BED 059	-	60	60	-	72
2nd F_BED 060	-	60	60	-	63
2nd F_BR 060	-	60	60	-	23
2nd F_Dining/Lounge Room	-	60	60	-	343
1st F_Foyer 2	-	60	60	-	35
2nd F_Foyer 1	-	60	60	-	28
stairs	-	60	60	-	48
Archive Store	60	-	-	-	205
Staff Room	60	-	-	-	351
Hairn and beauty	-	60	60	-	146
Training/Conference Room	60	-	-	-	697
Plant Room	60	-	-	-	213
WC	-	60	60	-	33
Cooms Room	60	-	-	-	122
Stairs	-	60	60	-	46
Entrance	-	60	60	22	180
Lift + DW	-	60	60	-	34
kitchen	-	60	60	-	578
store	60	-	-	-	40
Store	60	-	-	-	43
Female change	-	60	60	-	62
Male Change	-	60	60	-	62
Store	60	-	-	-	239
Stairs	-	60	60	-	48
Kitchen change	-	60	60	-	92
Laundry Room	-	60	60	-	517
Cinema	60	-	-	-	379
Lift	-	60	60	-	24
Private Family Room	60	-	-	-	332
Sensory Room	-	60	60	-	166
Activity Room	60	-	-	-	588
WC	-	60	60	-	34
Foyer 1	-	60	60	-	118
WC	-	60	60	-	30

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
Office space	60	-	-	-	193
Meeting Room	60	-	-	-	408
Foyer 4	-	60	-	-	188
Foyer 2	-	60	-	-	20
Foyer 3	-	60	-	-	122

Criterion 3: The spaces in the building should have appropriate passive control measures to limit solar gains

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
Manager office	NO (-78.4%)	NO
Drugs Room	N/A	N/A
Admin Room	NO (-77.4%)	NO
Gf_BED 014	NO (-78.6%)	NO
Gf_BED 015	NO (-78.6%)	NO
GF_BED 016	NO (-78.6%)	NO
GF_BED 017	NO (-88.7%)	NO
Gf_BED 018	NO (-85%)	NO
Gf_BED 019	NO (-72.8%)	NO
Gf_BED 020	NO (-72.4%)	NO
Gf_BED 021	NO (-64.7%)	NO
GF_Dining/ Lounge Room	NO (-77.1%)	NO
Gf_BED 013	NO (-84.2%)	NO
Gf_BED 012	NO (-71.4%)	NO
Gf_BED 011	NO (-67.1%)	NO
Gf_BED 01	NO (-73.2%)	NO
Gf_BED 02	NO (-72.8%)	NO
Gf_BED 03	NO (-83.9%)	NO
Gf_BED 04	NO (-72.7%)	NO
Gf_BED 05	NO (-72.7%)	NO
Gf_BED 06	NO (-73.3%)	NO
Gf_BED 07	NO (-76.7%)	NO
Gf_BED 08	NO (-83.9%)	NO
Gf_BED 010	NO (-77.9%)	NO
Gf_BED 09	NO (-77.9%)	NO
Dining Room	NO (-58.6%)	NO
1st F_BED 022	NO (-73.2%)	NO
1st F_BED 023	NO (-72.8%)	NO
1st F_Sluice	NO (-63.3%)	NO
1st F_BED 024	NO (-83.9%)	NO
1st F_BED 025	NO (-72.7%)	NO
1st _BED 026	NO (-72.7%)	NO
1st F_BED 027	NO (-73.3%)	NO
1st F_BED 028	NO (-76.7%)	NO
1st F_BED 029	NO (-83.9%)	NO

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
1st F_BED 031	NO (-77.9%)	NO
1st F_BED 030	NO (-77.9%)	NO
1st F_Drugs Room	N/A	N/A
1st F_BED 033	NO (-59.6%)	NO
1st F_dining room extension	NO (-55.8%)	NO
1st F_BED 034	NO (-62%)	NO
1st F_BED 035	NO (-52.1%)	NO
1st f_BED 039	NO (-78.6%)	NO
1st F_BED 040	NO (-78.6%)	NO
1st f_BED 041	NO (-78.6%)	NO
1st F_BED 042	NO (-88.7%)	NO
1st F_BED 043	NO (-85%)	NO
1st_F 044	NO (-72.8%)	NO
1st F_BED 045	NO (-72.4%)	NO
1st F_BED 046	NO (-64.7%)	NO
1st F_BED 038	NO (-84.2%)	NO
1st f_BED 037	NO (-71.4%)	NO
1st f_BED 036	NO (-67.1%)	NO
1st F_BED 032	NO (-63.5%)	NO
1st F_Dning / Lounge room	NO (-73%)	NO
2nd F_BED 047	NO (-73.2%)	NO
2nd F_BED 048	NO (-72.8%)	NO
1st F_Sluice (1)	NO (-63.3%)	NO
2nd F_BED 049	NO (-83.9%)	NO
2nd F_BED 050	NO (-72.7%)	NO
2nd F_BED 051	NO (-72.7%)	NO
2nd F_BED 052	NO (-73.3%)	NO
2nd F_BED 053	NO (-76.7%)	NO
2nd F_BED 055	NO (-77.9%)	NO
2nd F_BED 054	NO (-77.9%)	NO
2nd F_BED 056	NO (-63.5%)	NO
2nd F_Drugs Room	N/A	N/A
2nd F_BED 057	NO (-62.1%)	NO
2nd F_BED 058	NO (-74.1%)	NO
2nd F_BED 059	NO (-65.7%)	NO
2nd F_BED 060	NO (-67.4%)	NO
2nd F_Dining/Lounge Room	NO (-79.9%)	NO
Staff Room	N/A	N/A
Training/Conference Room	N/A	N/A
Cooms Room	N/A	N/A
Entrance	N/A	N/A
Cinema	NO (-65.6%)	NO
Private Family Room	NO (-79.4%)	NO
Activity Room	NO (-86.7%)	NO
Office space	N/A	N/A
Meeting Room	NO (-79.3%)	NO

Criterion 4: The performance of the building, as built, should be consistent with the calculated BER

Separate submission

Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place

Separate submission

EPBD (Recast): Consideration of alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	NO
Is evidence of such assessment available as a separate submission?	NO
Are any such measures included in the proposed design?	NO

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters		Building Use		
	Actual	Notional	% Area	Building Type
Area [m ²]	3624.4	3624.4		A1/A2 Retail/Financial and Professional services
External area [m ²]	3905.7	3905.7		A3/A4/A5 Restaurants and Cafes/Drinking Est./Takeaways
Weather	LON	LON		B1 Offices and Workshop businesses
Infiltration [m ³ /hm ² @ 50Pa]	3	3		B2 to B7 General Industrial and Special Industrial Groups
Average conductance [W/K]	1402.62	1759.23		B8 Storage or Distribution
Average U-value [W/m ² K]	0.36	0.45		C1 Hotels
Alpha value* [%]	18.78	19.43	94	C2 Residential Institutions: Hospitals and Care Homes
			6	C2 Residential Institutions: Residential schools
				C2 Residential Institutions: Universities and colleges
				C2A Secure Residential Institutions
				Residential spaces
				D1 Non-residential Institutions: Community/Day Centre
				D1 Non-residential Institutions: Libraries, Museums, and Galleries
				D1 Non-residential Institutions: Education
				D1 Non-residential Institutions: Primary Health Care Building
				D1 Non-residential Institutions: Crown and County Courts
				D2 General Assembly and Leisure, Night Clubs, and Theatres
				Others: Passenger terminals
				Others: Emergency services
				Others: Miscellaneous 24hr activities
				Others: Car Parks 24 hrs
				Others: Stand alone utility block

Energy Consumption by End Use [kWh/m²]

	Actual	Notional
Heating	38.25	42.91
Cooling	0	0
Auxiliary	4.1	2.2
Lighting	15.86	16.58
Hot water	100.02	100.02
Equipment*	60.53	60.53
TOTAL**	158.23	161.71

* Energy used by equipment does not count towards the total for consumption or calculating emissions.

** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

	Actual	Notional
Photovoltaic systems	0	0
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0

Energy & CO₂ Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m ²]	291.1	344.93
Primary energy* [kWh/m ²]	229.97	230.6
Total emissions [kg/m ²]	40.2	40.4

* Primary energy is net of any electrical energy displaced by CHP generators, if applicable.

HVAC Systems Performance

System Type	Heat dem MJ/m ²	Cool dem MJ/m ²	Heat con kWh/m ²	Cool con kWh/m ²	Aux con kWh/m ²	Heat SSEEF	Cool SSEER	Heat gen SEFF	Cool gen SEER
[ST] Central heating using water: radiators, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity									
Actual	117.7	173.4	38.3	0	4.1	0.86	0	0.91	0
Notional	126.5	218.4	42.9	0	2.2	0.82	0	----	----

Key to terms

Heat dem [MJ/m ²]	= Heating energy demand
Cool dem [MJ/m ²]	= Cooling energy demand
Heat con [kWh/m ²]	= Heating energy consumption
Cool con [kWh/m ²]	= Cooling energy consumption
Aux con [kWh/m ²]	= Auxiliary energy consumption
Heat SSEEF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type

Key Features

The Building Control Body is advised to give particular attention to items whose specifications are better than typically expected.

Building fabric

Element	U _{i-Typ}	U _{i-Min}	Surface where the minimum value occurs*
Wall	0.23	0.26	"SL000000_W4"
Floor	0.2	0.22	"MN000000_F"
Roof	0.15	0.18	"MN000000_C"
Windows, roof windows, and rooflights	1.5	1.6	"SL000000_W4_O0"
Personnel doors	1.5	1.67	"ST000000_W3_O0"
Vehicle access & similar large doors	1.5	-	"No external vehicle access doors"
High usage entrance doors	1.5	-	"No external high usage entrance doors"

U_{i-Typ} = Typical individual element U-values [W/(m²K)] U_{i-Min} = Minimum individual element U-values [W/(m²K)]

* There might be more than one surface where the minimum U-value occurs.

Air Permeability	Typical value	This building
m ³ /(h.m ²) at 50 Pa	5	3

SBEM Main Calculation Output Document

Fri Apr 01 16:24:42 2022

v5.6.b.0


Building name

18 Pield Heath-Baseline

Building type: C2 Residential Institutions - Hospitals and Care Homes

SBEM is an energy calculation tool for the purpose of assessing and demonstrating compliance with Building Regulations (Part L for England and Wales, Section 6 for Scotland, Part F for Northern Ireland, and Building Bye-laws Jersey Part 11) and to produce Energy Performance Certificates and Building Energy Ratings. Although the data produced by the tool may be of use in the design process, **SBEM is not intended as a building design tool.**

Building Energy Performance and CO2 emissions





0 kgCO2/m2 displaced by the use of renewable sources.



Building area is 3624.4 m2

Annual Energy Consumption

(Pie chart including Equipment end-use)





(Pie chart excluding Equipment end-use)





(*) Although energy consumption by equipment is shown in the graphs for information, this end-use has not been included in the total results of the building or the calculation of the ratings.

Annual Heating Demand



Annual Cooling Demand





Project name

18 Pield Heath-Be Lean (Targeted)

As designed

Date: Mon Apr 04 09:24:33 2022

Administrative information

Building Details

Address: London, UB8 3NF

Certification tool

Calculation engine: SBEM

Calculation engine version: v5.6.b.0

Interface to calculation engine: Virtual Environment

Interface to calculation engine version: v7.0.13

BRUKL compliance check version: v5.6.b.0

Certifier details

Name: SyntegraENG

Telephone number: 01184028520

Address: 63 Milford Rd, Reading, RG1 8LG

Criterion 1: The calculated CO₂ emission rate for the building must not exceed the target

CO ₂ emission rate from the notional building, kgCO ₂ /m ² .annum	40.4
Target CO ₂ emission rate (TER), kgCO ₂ /m ² .annum	40.4
Building CO ₂ emission rate (BER), kgCO ₂ /m ² .annum	39.5
Are emissions from the building less than or equal to the target?	BER =< TER
Are as built details the same as used in the BER calculations?	Separate submission

Criterion 2: The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Values which do not achieve the standards in the Non-Domestic Building Services Compliance Guide and Part L are displayed in red.

Building fabric

Element	U _a -Limit	U _a -Calc	U _i -Calc	Surface where the maximum value occurs*
Wall**	0.35	0.28	1.79	"FY000002_W17_A0"
Floor	0.25	0.16	0.16	"MN000000_F"
Roof	0.25	0.17	1.09	"LF000001_C_A0"
Windows***, roof windows, and rooflights	2.2	1.29	1.29	"SL000000_W4_O0"
Personnel doors	2.2	1.03	1.03	"ST000000_W3_O0"
Vehicle access & similar large doors	1.5	-	-	"No external vehicle access doors"
High usage entrance doors	3.5	-	-	"No external high usage entrance doors"

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]

U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]

U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]

* There might be more than one surface where the maximum U-value occurs.

** Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

*** Display windows and similar glazing are excluded from the U-value check.

N.B.: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

Air Permeability	Worst acceptable standard	This building
m ³ /(h.m ²) at 50 Pa	10	3

Building services

The standard values listed below are minimum values for efficiencies and maximum values for SFPs. Refer to the Non-Domestic Building Services Compliance Guide for details.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	YES
Whole building electric power factor achieved by power factor correction	<0.9

1- Gas Boiler

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	0.91	-	-	-	-
Standard value	0.91*	N/A	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					YES

* Standard shown is for gas single boiler systems <=2 MW output. For single boiler systems >2 MW or multi-boiler systems, (overall) limiting efficiency is 0.86. For any individual boiler in a multi-boiler system, limiting efficiency is 0.82.

1- SYST0000-DHW

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	Hot water provided by HVAC system	-
Standard value	N/A	N/A

Local mechanical ventilation, exhaust, and terminal units

ID	System type in Non-domestic Building Services Compliance Guide
A	Local supply or extract ventilation units serving a single area
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal supply and extract ventilation units serving a single room or zone with heating and heat recovery
E	Local supply and extract ventilation system serving a single area with heating and heat recovery
F	Other local ventilation units
G	Fan-assisted terminal VAV unit
H	Fan coil units
I	Zonal extract system where the fan is remote from the zone with grease filter

Zone name	ID of system type	SFP [W/(l/s)]									HR efficiency	
		A	B	C	D	E	F	G	H	I		
Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard	
Ass Bath	0.3	-	-	-	-	-	-	-	-	-	N/A	
wc	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_Br 014	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_Br 015	0.3	-	-	-	-	-	-	-	-	-	N/A	
GF_Br 016	0.3	-	-	-	-	-	-	-	-	-	N/A	
GF_BR 017	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_BR018	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_BR 019	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_BR 020	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_BR021	0.3	-	-	-	-	-	-	-	-	-	N/A	
WC	0.3	-	-	-	-	-	-	-	-	-	N/A	
Assisted Bath	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_BR 013	0.3	-	-	-	-	-	-	-	-	-	N/A	
GF_BR 012	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_BR 011	0.3	-	-	-	-	-	-	-	-	-	N/A	

Zone name	SFP [W/(l/s)]									HR efficiency	
	A	B	C	D	E	F	G	H	I		
ID of system type	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
Gf_BR 01	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 02	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 03	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 04	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 05	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 06	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 07	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 08	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 010	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 09	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 022	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 023	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 024	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 025	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 026	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 027	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 028	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 031	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 030	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 033	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 034	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 035	0.3	-	-	-	-	-	-	-	-	-	N/A
1st f_Br 039	0.3	-	-	-	-	-	-	-	-	-	N/A
1st_Br 040	0.3	-	-	-	-	-	-	-	-	-	N/A
1st f_Br 041	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 042	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 043	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 044	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 045	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_Assisted Bath	0.3	-	-	-	-	-	-	-	-	-	N/A
1st f_BR 036	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR046	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 038	0.3	-	-	-	-	-	-	-	-	-	N/A
1st f_BR 037	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_WC	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 032	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_Assisted Bathroom	0.3	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 047	0.3	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 049	0.3	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 050	0.3	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 051	0.3	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 052	0.3	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 053	0.3	-	-	-	-	-	-	-	-	-	N/A

Zone name	SFP [W/(l/s)]									HR efficiency		
	A	B	C	D	E	F	G	H	I			
ID of system type	Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
2nd F_BR 055	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 054	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 056	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_Assisted Bathroom	0.3	-	-	-	-	-	-	-	-	-	N/A	
1st_BR 029	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 048	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 058	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 057	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 059	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 060	0.3	-	-	-	-	-	-	-	-	-	N/A	
WC	0.3	-	-	-	-	-	-	-	-	-	N/A	
WC	0.3	-	-	-	-	-	-	-	-	-	N/A	
WC	0.3	-	-	-	-	-	-	-	-	-	N/A	

General lighting and display lighting		Luminous efficacy [lm/W]				
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]	
Sluice	-	60	60	22		
Stairs	-	60	-	-	25	
Ass Bath	-	60	-	-	48	
Stairs	-	60	-	-	48	
Manager office	60	-	-	-	144	
Drugs Room	60	-	-	-	120	
Foyer GF 6	-	60	-	-	56	
Admin Room	60	-	-	-	206	
WC	-	60	-	-	21	
Foyer GF 4	-	60	-	-	109	
Gf_BED 014	-	60	-	-	66	
Gf_Br 014	-	60	-	-	24	
Gf_Br 015	-	60	-	-	24	
Gf_BED 015	-	60	-	-	65	
GF_Br 016	-	60	-	-	24	
GF_BED 016	-	60	-	-	65	
GF_BED 017	-	60	-	-	68	
GF_BR 017	-	60	-	-	26	
Gf_BR018	-	60	-	-	23	
Gf_BED 018	-	60	-	-	67	
Gf_BED 019	-	60	-	-	63	
Gf_BR 019	-	60	-	-	24	
Gf_BR 020	-	60	-	-	24	
Gf_BED 020	-	60	-	-	62	
Gf_BR021	-	60	-	-	25	
Gf_BED 021	-	60	-	-	59	

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
WC	-	60	60	22	19
Assisted Bath	-	60	60	-	59
LIFT	-	60	60	-	24
GF_Dining/ Lounge Room	-	60	60	-	304
Gf_BR 013	-	60	60	-	26
Gf_BED 013	-	60	60	-	61
Gf_BED 012	-	60	60	-	65
GF_BR 012	-	60	60	-	23
Gf_BED 011	-	60	60	-	65
Gf_BR 011	-	60	60	-	23
Gf_BED 01	-	60	60	-	65
Gf_BR 01	-	60	60	-	24
Gf_BR 02	-	60	60	-	24
Gf_BED 02	-	60	60	-	62
Gf_BR 03	-	60	60	-	24
Gf_BED 03	-	60	60	-	66
Gf_BR04	-	60	60	-	24
Gf_BED 04	-	60	60	-	65
Gf_BR 05	-	60	60	-	24
Gf_BED 05	-	60	60	-	65
Gf_BR 06	-	60	60	-	24
Gf_BED 06	-	60	60	-	63
Gf_BED 07	-	60	60	-	71
Gf_BR 07	-	60	60	-	24
Gf_BR 08	-	60	60	-	26
Gf_BED 08	-	60	60	-	66
Gf_BR 010	-	60	60	-	24
Gf_BED 010	-	60	60	-	63
Gf_BED 09	-	60	60	-	63
Gf_BR 09	-	60	60	-	24
Dining Room	-	60	60	-	187
Foyer GF 5	-	60	60	-	200
Foyer 1 & Sitting area	-	60	60	-	183
1st F_BED 022	-	60	60	-	65
1st F_BR 022	-	60	60	-	24
1st F_BR 023	-	60	60	-	24
1st F_BED 023	-	60	60	-	62
1st F_Sluice	-	60	60	-	31
1st F_BR 024	-	60	60	-	24
1st F_BED 024	-	60	60	-	66
1st F_BR 025	-	60	60	-	24
1st F_BED 025	-	60	60	-	65
1st F_BR 026	-	60	60	-	24

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
1st_BED 026	-	60	60	22	65
1st_F_BR 027	-	60	60	-	24
1st_F_BED 027	-	60	60	-	63
1st_F_BED 028	-	60	60	-	71
1st_F_BR 028	-	60	60	-	24
1st_F_BED 029	-	60	60	-	66
1st_F_Foyer 6	-	60	60	-	56
1st_F_Stairs	-	60	60	-	48
1st_F_BR 031	-	60	60	-	24
1st_F_BED 031	-	60	60	-	63
1st_F_BED 030	-	60	60	-	63
1st_F_BR 030	-	60	60	-	24
1st_F_Drugs Room	-	60	60	-	43
1st_F_BR 033	-	60	60	-	21
1st_F_BED 033	-	60	60	-	60
1st_F_Stairs case	-	60	60	-	46
Stairs and Main entrance	-	60	60	-	80
1st_F_dining room extension	-	60	60	-	39
1st_F_BR 034	-	60	60	-	25
1st_F_BED 034	-	60	60	-	60
1st_F_BED 035	-	60	60	-	60
1st_F_BR 035	-	60	60	-	25
1st_F_Foyer 1 & Sitting area	-	60	60	-	183
1ST_f_Stairs	-	60	60	-	48
1st_f_BED 039	-	60	60	-	66
1st_f_Br 039	-	60	60	-	24
1st_Br 040	-	60	60	-	24
1st_F_BED 040	-	60	60	-	65
1st_f_Br 041	-	60	60	-	24
1st_f_BED 041	-	60	60	-	65
1st_F_BED 042	-	60	60	-	68
1st_F_BR 042	-	60	60	-	26
1st_F_BR 043	-	60	60	-	23
1st_F_BED 043	-	60	60	-	67
1st_F_044	-	60	60	-	63
1st_F_BR 044	-	60	60	-	24
1st_F_BR 045	-	60	60	-	24
1st_F_BED 045	-	60	60	-	62
1st_F_Assisted Bath	-	60	60	-	59
1st_F_LIFT	-	60	60	-	24
1st_f_BR 036	-	60	60	-	23
1st_F_BR046	-	60	60	-	25
1st_F_BED 046	-	60	60	-	59

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
1st F_BR 038	-	60	60	22	
1st F_BED 038	-	60	60	-	61
1st f_BED 037	-	60	60	-	65
1st f_BED 036	-	60	60	-	65
1st f_BR 037	-	60	60	-	23
1st F_WC	-	60	60	-	30
Foyer 3	-	60	60	-	50
Foyer 2	-	60	60	-	35
1st F_BR 032	-	60	60	-	23
1st F_BED 032	-	60	60	-	62
1st F_Assisted Bathroom	-	60	60	-	47
1st F_Foyer 5	-	60	60	-	200
1st F_Foyer 4	-	60	60	-	38
1st F_Dning / Lounge room	-	60	60	-	382
1st F_Foyer 3	-	60	60	-	41
1st F_Store	60	-	-	-	53
2nd F_BED 047	-	60	60	-	65
2nd F_BR 047	-	60	60	-	24
2nd F_BED 048	-	60	60	-	62
1st F_Sluice (1)	-	60	60	-	31
2nd F_BR 049	-	60	60	-	24
2nd F_BED 049	-	60	60	-	66
2nd F_BR 050	-	60	60	-	24
2nd F_BED 050	-	60	60	-	65
2nd F_BR 051	-	60	60	-	24
2nd F_BED 051	-	60	60	-	65
2nd F_BR 052	-	60	60	-	24
2nd F_BED 052	-	60	60	-	63
2nd F_BED 053	-	60	60	-	71
2nd F_BR 053	-	60	60	-	24
1st F_Foyer 6 (1)	-	60	60	-	56
1st F_Stairs (1)	-	60	60	-	48
2nd F_BR 055	-	60	60	-	24
2nd F_BED 055	-	60	60	-	63
2nd F_BED 054	-	60	60	-	63
2nd F_BR 054	-	60	60	-	24
1st F_Stairs case (1)	-	60	60	-	46
2nd F_BR 056	-	60	60	-	23
2nd F_BED 056	-	60	60	-	62
2nd F_Assisted Bathroom	-	60	60	-	47
2nd F_Foyer 3	-	60	60	-	38
1st_BR 029	-	60	60	-	26
2nd F_Store	60	-	-	-	71

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
2nd F_BR 048	-	60	60	22	24
2nd F_Foyer 4	-	60	60	-	39
2nd F_Foyer 5	-	60	60	-	165
2nd F_Drugs Room	-	60	60	-	43
2nd F_BR 058	-	60	60	-	22
2nd F_BED 057	-	60	60	-	60
2nd F_BR 057	-	60	60	-	21
2nd F_BED 058	-	60	60	-	76
2nd F_BR 059	-	60	60	-	22
2nd F_BED 059	-	60	60	-	72
2nd F_BED 060	-	60	60	-	63
2nd F_BR 060	-	60	60	-	23
2nd F_Dining/Lounge Room	-	60	60	-	343
1st F_Foyer 2	-	60	60	-	35
2nd F_Foyer 1	-	60	60	-	28
stairs	-	60	60	-	48
Archive Store	60	-	-	-	205
Staff Room	60	-	-	-	351
Hairn and beauty	-	60	60	-	146
Training/Conference Room	60	-	-	-	697
Plant Room	60	-	-	-	213
WC	-	60	60	-	33
Cooms Room	60	-	-	-	122
Stairs	-	60	60	-	46
Entrance	-	60	60	22	180
Lift + DW	-	60	60	-	34
kitchen	-	60	60	-	578
store	60	-	-	-	40
Store	60	-	-	-	43
Female change	-	60	60	-	62
Male Change	-	60	60	-	62
Store	60	-	-	-	239
Stairs	-	60	60	-	48
Kitchen change	-	60	60	-	92
Laundry Room	-	60	60	-	517
Cinema	60	-	-	-	379
Lift	-	60	60	-	24
Private Family Room	60	-	-	-	332
Sensory Room	-	60	60	-	166
Activity Room	60	-	-	-	588
WC	-	60	60	-	34
Foyer 1	-	60	60	-	118
WC	-	60	60	-	30

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
Office space	60	-	-	-	193
Meeting Room	60	-	-	-	408
Foyer 4	-	60	-	-	188
Foyer 2	-	60	-	-	20
Foyer 3	-	60	-	-	122

Criterion 3: The spaces in the building should have appropriate passive control measures to limit solar gains

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
Manager office	NO (-78.5%)	NO
Drugs Room	N/A	N/A
Admin Room	NO (-77.5%)	NO
Gf_BED 014	NO (-78.8%)	NO
Gf_BED 015	NO (-78.8%)	NO
GF_BED 016	NO (-78.8%)	NO
GF_BED 017	NO (-88.8%)	NO
Gf_BED 018	NO (-85.1%)	NO
Gf_BED 019	NO (-72.9%)	NO
Gf_BED 020	NO (-72.5%)	NO
Gf_BED 021	NO (-64.8%)	NO
GF_Dining/ Lounge Room	NO (-77.2%)	NO
Gf_BED 013	NO (-84.3%)	NO
Gf_BED 012	NO (-71.6%)	NO
Gf_BED 011	NO (-67.3%)	NO
Gf_BED 01	NO (-73.4%)	NO
Gf_BED 02	NO (-72.9%)	NO
Gf_BED 03	NO (-84%)	NO
Gf_BED 04	NO (-72.9%)	NO
Gf_BED 05	NO (-72.9%)	NO
Gf_BED 06	NO (-73.4%)	NO
Gf_BED 07	NO (-76.9%)	NO
Gf_BED 08	NO (-84%)	NO
Gf_BED 010	NO (-78%)	NO
Gf_BED 09	NO (-78%)	NO
Dining Room	NO (-58.8%)	NO
1st F_BED 022	NO (-73.4%)	NO
1st F_BED 023	NO (-72.9%)	NO
1st F_Sluice	NO (-63.5%)	NO
1st F_BED 024	NO (-84%)	NO
1st F_BED 025	NO (-72.9%)	NO
1st _BED 026	NO (-72.9%)	NO
1st F_BED 027	NO (-73.4%)	NO
1st F_BED 028	NO (-76.9%)	NO
1st F_BED 029	NO (-84%)	NO

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
1st F_BED 031	NO (-78%)	NO
1st F_BED 030	NO (-78%)	NO
1st F_Drugs Room	N/A	N/A
1st F_BED 033	NO (-59.8%)	NO
1st F_dining room extension	NO (-56%)	NO
1st F_BED 034	NO (-62.2%)	NO
1st F_BED 035	NO (-52.4%)	NO
1st f_BED 039	NO (-78.8%)	NO
1st F_BED 040	NO (-78.8%)	NO
1st f_BED 041	NO (-78.8%)	NO
1st F_BED 042	NO (-88.8%)	NO
1st F_BED 043	NO (-85.1%)	NO
1st_F 044	NO (-72.9%)	NO
1st F_BED 045	NO (-72.5%)	NO
1st F_BED 046	NO (-64.9%)	NO
1st F_BED 038	NO (-84.3%)	NO
1st f_BED 037	NO (-71.6%)	NO
1st f_BED 036	NO (-67.3%)	NO
1st F_BED 032	NO (-63.7%)	NO
1st F_Dning / Lounge room	NO (-73.1%)	NO
2nd F_BED 047	NO (-73.4%)	NO
2nd F_BED 048	NO (-72.9%)	NO
1st F_Sluice (1)	NO (-63.5%)	NO
2nd F_BED 049	NO (-84%)	NO
2nd F_BED 050	NO (-72.9%)	NO
2nd F_BED 051	NO (-72.9%)	NO
2nd F_BED 052	NO (-73.4%)	NO
2nd F_BED 053	NO (-76.9%)	NO
2nd F_BED 055	NO (-78%)	NO
2nd F_BED 054	NO (-78%)	NO
2nd F_BED 056	NO (-63.7%)	NO
2nd F_Drugs Room	N/A	N/A
2nd F_BED 057	NO (-62.3%)	NO
2nd F_BED 058	NO (-74.2%)	NO
2nd F_BED 059	NO (-65.8%)	NO
2nd F_BED 060	NO (-67.6%)	NO
2nd F_Dining/Lounge Room	NO (-80%)	NO
Staff Room	N/A	N/A
Training/Conference Room	N/A	N/A
Cooms Room	N/A	N/A
Entrance	N/A	N/A
Cinema	NO (-65.8%)	NO
Private Family Room	NO (-79.5%)	NO
Activity Room	NO (-86.7%)	NO
Office space	N/A	N/A
Meeting Room	NO (-79.4%)	NO

Criterion 4: The performance of the building, as built, should be consistent with the calculated BER

Separate submission

Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place

Separate submission

EPBD (Recast): Consideration of alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	NO
Is evidence of such assessment available as a separate submission?	NO
Are any such measures included in the proposed design?	NO

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters		Building Use		
	Actual	Notional	% Area	Building Type
Area [m ²]	3624.4	3624.4		A1/A2 Retail/Financial and Professional services
External area [m ²]	3905.7	3905.7		A3/A4/A5 Restaurants and Cafes/Drinking Est./Takeaways
Weather	LON	LON		B1 Offices and Workshop businesses
Infiltration [m ³ /hm ² @ 50Pa]	3	3		B2 to B7 General Industrial and Special Industrial Groups
Average conductance [W/K]	1103.03	1759.23		B8 Storage or Distribution
Average U-value [W/m ² K]	0.28	0.45		C1 Hotels
Alpha value* [%]	23.88	19.43	94	C2 Residential Institutions: Hospitals and Care Homes
			6	C2 Residential Institutions: Residential schools
				C2 Residential Institutions: Universities and colleges
				C2A Secure Residential Institutions
				Residential spaces
				D1 Non-residential Institutions: Community/Day Centre
				D1 Non-residential Institutions: Libraries, Museums, and Galleries
				D1 Non-residential Institutions: Education
				D1 Non-residential Institutions: Primary Health Care Building
				D1 Non-residential Institutions: Crown and County Courts
				D2 General Assembly and Leisure, Night Clubs, and Theatres
				Others: Passenger terminals
				Others: Emergency services
				Others: Miscellaneous 24hr activities
				Others: Car Parks 24 hrs
				Others: Stand alone utility block

Energy Consumption by End Use [kWh/m²]

	Actual	Notional
Heating	35.04	42.91
Cooling	0	0
Auxiliary	4.02	2.2
Lighting	15.86	16.58
Hot water	100.02	100.02
Equipment*	60.53	60.53
TOTAL**	154.94	161.71

* Energy used by equipment does not count towards the total for consumption or calculating emissions.

** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

	Actual	Notional
Photovoltaic systems	0	0
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0

Energy & CO₂ Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m ²]	285.03	344.93
Primary energy* [kWh/m ²]	225.82	230.6
Total emissions [kg/m ²]	39.5	40.4

* Primary energy is net of any electrical energy displaced by CHP generators, if applicable.

HVAC Systems Performance

System Type	Heat dem MJ/m ²	Cool dem MJ/m ²	Heat con kWh/m ²	Cool con kWh/m ²	Aux con kWh/m ²	Heat SSEEF	Cool SSEER	Heat gen SEFF	Cool gen SEER
[ST] Central heating using water: radiators, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity									
Actual	107.9	177.2	35	0	4	0.86	0	0.91	0
Notional	126.5	218.4	42.9	0	2.2	0.82	0	----	----

Key to terms

Heat dem [MJ/m ²]	= Heating energy demand
Cool dem [MJ/m ²]	= Cooling energy demand
Heat con [kWh/m ²]	= Heating energy consumption
Cool con [kWh/m ²]	= Cooling energy consumption
Aux con [kWh/m ²]	= Auxiliary energy consumption
Heat SSEEF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type

Key Features

The Building Control Body is advised to give particular attention to items whose specifications are better than typically expected.

Building fabric

Element	U _{i-Typ}	U _{i-Min}	Surface where the minimum value occurs*
Wall	0.23	0.17	"SL000000_W4"
Floor	0.2	0.16	"MN000000_F"
Roof	0.15	0.16	"MN000000_C"
Windows, roof windows, and rooflights	1.5	1.29	"SL000000_W4_O0"
Personnel doors	1.5	1.03	"ST000000_W3_O0"
Vehicle access & similar large doors	1.5	-	"No external vehicle access doors"
High usage entrance doors	1.5	-	"No external high usage entrance doors"

U_{i-Typ} = Typical individual element U-values [W/(m²K)] U_{i-Min} = Minimum individual element U-values [W/(m²K)]

* There might be more than one surface where the minimum U-value occurs.

Air Permeability	Typical value	This building
m ³ /(h.m ²) at 50 Pa	5	3

SBEM Main Calculation Output Document

Mon Apr 04 09:24:26 2022

v5.6.b.0


Building name

18 Pield Heath-Be Lean (Target)

Building type: C2 Residential Institutions - Hospitals and Care Homes

SBEM is an energy calculation tool for the purpose of assessing and demonstrating compliance with Building Regulations (Part L for England and Wales, Section 6 for Scotland, Part F for Northern Ireland, and Building Bye-laws Jersey Part 11) and to produce Energy Performance Certificates and Building Energy Ratings. Although the data produced by the tool may be of use in the design process, **SBEM is not intended as a building design tool.**

Building Energy Performance and CO2 emissions





0 kgCO2/m2 displaced by the use of renewable sources.



Building area is 3624.4 m2

Annual Energy Consumption

(Pie chart including Equipment end-use)





(Pie chart excluding Equipment end-use)





(*) Although energy consumption by equipment is shown in the graphs for information, this end-use has not been included in the total results of the building or the calculation of the ratings.

Annual Heating Demand



Annual Cooling Demand





Project name

18 Pield Heath-Be Lean LETI+WWHR

As designed

Date: Mon Apr 04 15:39:02 2022

Administrative information

Building Details

Address: London, UB8 3NF

Certification tool

Calculation engine: SBEM

Calculation engine version: v5.6.b.0

Interface to calculation engine: Virtual Environment

Interface to calculation engine version: v7.0.13

BRUKL compliance check version: v5.6.b.0

Certifier details

Name: SyntegraENG

Telephone number: 01184028520

Address: 63 Milford Rd, Reading, RG1 8LG

Criterion 1: The calculated CO₂ emission rate for the building must not exceed the target

CO ₂ emission rate from the notional building, kgCO ₂ /m ² .annum	40.4
Target CO ₂ emission rate (TER), kgCO ₂ /m ² .annum	40.4
Building CO ₂ emission rate (BER), kgCO ₂ /m ² .annum	35.2
Are emissions from the building less than or equal to the target?	BER =< TER
Are as built details the same as used in the BER calculations?	Separate submission

Criterion 2: The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Values which do not achieve the standards in the Non-Domestic Building Services Compliance Guide and Part L are displayed in red.

Building fabric

Element	U _a -Limit	U _a -Calc	U _i -Calc	Surface where the maximum value occurs*
Wall**	0.35	0.24	1.79	"FY000002_W17_A0"
Floor	0.25	0.08	0.08	"MN000000_F"
Roof	0.25	0.12	1.09	"LF000001_C_A0"
Windows***, roof windows, and rooflights	2.2	0.98	0.98	"SL000000_W4_O0"
Personnel doors	2.2	1.03	1.03	"ST000000_W3_O0"
Vehicle access & similar large doors	1.5	-	-	"No external vehicle access doors"
High usage entrance doors	3.5	-	-	"No external high usage entrance doors"

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]

U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]

U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]

* There might be more than one surface where the maximum U-value occurs.

** Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

*** Display windows and similar glazing are excluded from the U-value check.

N.B.: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

Air Permeability	Worst acceptable standard	This building
m ³ /(h.m ²) at 50 Pa	10	1

Building services

The standard values listed below are minimum values for efficiencies and maximum values for SFPs. Refer to the Non-Domestic Building Services Compliance Guide for details.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	YES
Whole building electric power factor achieved by power factor correction	<0.9

1- Gas Boiler

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	0.91	-	-	-	-
Standard value	0.91*	N/A	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					YES

* Standard shown is for gas single boiler systems <=2 MW output. For single boiler systems >2 MW or multi-boiler systems, (overall) limiting efficiency is 0.86. For any individual boiler in a multi-boiler system, limiting efficiency is 0.82.

1- SYST0000-DHW

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	Hot water provided by HVAC system	-
Standard value	N/A	N/A

Local mechanical ventilation, exhaust, and terminal units

ID	System type in Non-domestic Building Services Compliance Guide
A	Local supply or extract ventilation units serving a single area
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal supply and extract ventilation units serving a single room or zone with heating and heat recovery
E	Local supply and extract ventilation system serving a single area with heating and heat recovery
F	Other local ventilation units
G	Fan-assisted terminal VAV unit
H	Fan coil units
I	Zonal extract system where the fan is remote from the zone with grease filter

Zone name	ID of system type	SFP [W/(l/s)]									HR efficiency	
		A	B	C	D	E	F	G	H	I		
Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard	
Ass Bath	0.3	-	-	-	-	-	-	-	-	-	N/A	
wc	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_Br 014	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_Br 015	0.3	-	-	-	-	-	-	-	-	-	N/A	
GF_Br 016	0.3	-	-	-	-	-	-	-	-	-	N/A	
GF_BR 017	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_BR018	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_BR 019	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_BR 020	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_BR021	0.3	-	-	-	-	-	-	-	-	-	N/A	
WC	0.3	-	-	-	-	-	-	-	-	-	N/A	
Assisted Bath	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_BR 013	0.3	-	-	-	-	-	-	-	-	-	N/A	
GF_BR 012	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_BR 011	0.3	-	-	-	-	-	-	-	-	-	N/A	

Zone name	SFP [W/(l/s)]									HR efficiency	
	A	B	C	D	E	F	G	H	I		
ID of system type	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
Gf_BR 01	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 02	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 03	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 04	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 05	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 06	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 07	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 08	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 010	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 09	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 022	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 023	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 024	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 025	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 026	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 027	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 028	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 031	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 030	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 033	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 034	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 035	0.3	-	-	-	-	-	-	-	-	-	N/A
1st f_Br 039	0.3	-	-	-	-	-	-	-	-	-	N/A
1st_Br 040	0.3	-	-	-	-	-	-	-	-	-	N/A
1st f_Br 041	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 042	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 043	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 044	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 045	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_Assisted Bath	0.3	-	-	-	-	-	-	-	-	-	N/A
1st f_BR 036	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR046	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 038	0.3	-	-	-	-	-	-	-	-	-	N/A
1st f_BR 037	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_WC	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 032	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_Assisted Bathroom	0.3	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 047	0.3	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 049	0.3	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 050	0.3	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 051	0.3	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 052	0.3	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 053	0.3	-	-	-	-	-	-	-	-	-	N/A

Zone name	SFP [W/(l/s)]									HR efficiency		
	A	B	C	D	E	F	G	H	I			
ID of system type	Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
2nd F_BR 055	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 054	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 056	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_Assisted Bathroom	0.3	-	-	-	-	-	-	-	-	-	N/A	
1st_BR 029	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 048	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 058	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 057	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 059	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 060	0.3	-	-	-	-	-	-	-	-	-	N/A	
WC	0.3	-	-	-	-	-	-	-	-	-	N/A	
WC	0.3	-	-	-	-	-	-	-	-	-	N/A	
WC	0.3	-	-	-	-	-	-	-	-	-	N/A	

General lighting and display lighting		Luminous efficacy [lm/W]				
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]	
Sluice	-	60	60	22		
Stairs	-	60	-	-	25	
Ass Bath	-	60	-	-	48	
Stairs	-	60	-	-	48	
Manager office	60	-	-	-	144	
Drugs Room	60	-	-	-	120	
Foyer GF 6	-	60	-	-	56	
Admin Room	60	-	-	-	206	
WC	-	60	-	-	21	
Foyer GF 4	-	60	-	-	109	
Gf_BED 014	-	60	-	-	66	
Gf_Br 014	-	60	-	-	24	
Gf_Br 015	-	60	-	-	24	
Gf_BED 015	-	60	-	-	65	
GF_Br 016	-	60	-	-	24	
GF_BED 016	-	60	-	-	65	
GF_BED 017	-	60	-	-	68	
GF_BR 017	-	60	-	-	26	
Gf_BR018	-	60	-	-	23	
Gf_BED 018	-	60	-	-	67	
Gf_BED 019	-	60	-	-	63	
Gf_BR 019	-	60	-	-	24	
Gf_BR 020	-	60	-	-	24	
Gf_BED 020	-	60	-	-	62	
Gf_BR021	-	60	-	-	25	
Gf_BED 021	-	60	-	-	59	

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
WC	-	60	60	22	19
Assisted Bath	-	60	60	-	59
LIFT	-	60	60	-	24
GF_Dining/ Lounge Room	-	60	60	-	304
Gf_BR 013	-	60	60	-	26
Gf_BED 013	-	60	60	-	61
Gf_BED 012	-	60	60	-	65
GF_BR 012	-	60	60	-	23
Gf_BED 011	-	60	60	-	65
Gf_BR 011	-	60	60	-	23
Gf_BED 01	-	60	60	-	65
Gf_BR 01	-	60	60	-	24
Gf_BR 02	-	60	60	-	24
Gf_BED 02	-	60	60	-	62
Gf_BR 03	-	60	60	-	24
Gf_BED 03	-	60	60	-	66
Gf_BR04	-	60	60	-	24
Gf_BED 04	-	60	60	-	65
Gf_BR 05	-	60	60	-	24
Gf_BED 05	-	60	60	-	65
Gf_BR 06	-	60	60	-	24
Gf_BED 06	-	60	60	-	63
Gf_BED 07	-	60	60	-	71
Gf_BR 07	-	60	60	-	24
Gf_BR 08	-	60	60	-	26
Gf_BED 08	-	60	60	-	66
Gf_BR 010	-	60	60	-	24
Gf_BED 010	-	60	60	-	63
Gf_BED 09	-	60	60	-	63
Gf_BR 09	-	60	60	-	24
Dining Room	-	60	60	-	187
Foyer GF 5	-	60	60	-	200
Foyer 1 & Sitting area	-	60	60	-	183
1st F_BED 022	-	60	60	-	65
1st F_BR 022	-	60	60	-	24
1st F_BR 023	-	60	60	-	24
1st F_BED 023	-	60	60	-	62
1st F_Sluice	-	60	60	-	31
1st F_BR 024	-	60	60	-	24
1st F_BED 024	-	60	60	-	66
1st F_BR 025	-	60	60	-	24
1st F_BED 025	-	60	60	-	65
1st F_BR 026	-	60	60	-	24

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
1st_BED 026	-	60	60	22	65
1st_F_BR 027	-	60	60	-	24
1st_F_BED 027	-	60	60	-	63
1st_F_BED 028	-	60	60	-	71
1st_F_BR 028	-	60	60	-	24
1st_F_BED 029	-	60	60	-	66
1st_F_Foyer 6	-	60	60	-	56
1st_F_Stairs	-	60	60	-	48
1st_F_BR 031	-	60	60	-	24
1st_F_BED 031	-	60	60	-	63
1st_F_BED 030	-	60	60	-	63
1st_F_BR 030	-	60	60	-	24
1st_F_Drugs Room	-	60	60	-	43
1st_F_BR 033	-	60	60	-	21
1st_F_BED 033	-	60	60	-	60
1st_F_Stairs case	-	60	60	-	46
Stairs and Main entrance	-	60	60	-	80
1st_F_dining room extension	-	60	60	-	39
1st_F_BR 034	-	60	60	-	25
1st_F_BED 034	-	60	60	-	60
1st_F_BED 035	-	60	60	-	60
1st_F_BR 035	-	60	60	-	25
1st_F_Foyer 1 & Sitting area	-	60	60	-	183
1ST_f_Stairs	-	60	60	-	48
1st_f_BED 039	-	60	60	-	66
1st_f_Br 039	-	60	60	-	24
1st_Br 040	-	60	60	-	24
1st_F_BED 040	-	60	60	-	65
1st_f_Br 041	-	60	60	-	24
1st_f_BED 041	-	60	60	-	65
1st_F_BED 042	-	60	60	-	68
1st_F_BR 042	-	60	60	-	26
1st_F_BR 043	-	60	60	-	23
1st_F_BED 043	-	60	60	-	67
1st_F_044	-	60	60	-	63
1st_F_BR 044	-	60	60	-	24
1st_F_BR 045	-	60	60	-	24
1st_F_BED 045	-	60	60	-	62
1st_F_Assisted Bath	-	60	60	-	59
1st_F_LIFT	-	60	60	-	24
1st_f_BR 036	-	60	60	-	23
1st_F_BR046	-	60	60	-	25
1st_F_BED 046	-	60	60	-	59

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
1st F_BR 038	-	60	60	22	
1st F_BED 038	-	60	60	-	61
1st f_BED 037	-	60	60	-	65
1st f_BED 036	-	60	60	-	65
1st f_BR 037	-	60	60	-	23
1st F_WC	-	60	60	-	30
Foyer 3	-	60	60	-	50
Foyer 2	-	60	60	-	35
1st F_BR 032	-	60	60	-	23
1st F_BED 032	-	60	60	-	62
1st F_Assisted Bathroom	-	60	60	-	47
1st F_Foyer 5	-	60	60	-	200
1st F_Foyer 4	-	60	60	-	38
1st F_Dning / Lounge room	-	60	60	-	382
1st F_Foyer 3	-	60	60	-	41
1st F_Store	60	-	-	-	53
2nd F_BED 047	-	60	60	-	65
2nd F_BR 047	-	60	60	-	24
2nd F_BED 048	-	60	60	-	62
1st F_Sluice (1)	-	60	60	-	31
2nd F_BR 049	-	60	60	-	24
2nd F_BED 049	-	60	60	-	66
2nd F_BR 050	-	60	60	-	24
2nd F_BED 050	-	60	60	-	65
2nd F_BR 051	-	60	60	-	24
2nd F_BED 051	-	60	60	-	65
2nd F_BR 052	-	60	60	-	24
2nd F_BED 052	-	60	60	-	63
2nd F_BED 053	-	60	60	-	71
2nd F_BR 053	-	60	60	-	24
1st F_Foyer 6 (1)	-	60	60	-	56
1st F_Stairs (1)	-	60	60	-	48
2nd F_BR 055	-	60	60	-	24
2nd F_BED 055	-	60	60	-	63
2nd F_BED 054	-	60	60	-	63
2nd F_BR 054	-	60	60	-	24
1st F_Stairs case (1)	-	60	60	-	46
2nd F_BR 056	-	60	60	-	23
2nd F_BED 056	-	60	60	-	62
2nd F_Assisted Bathroom	-	60	60	-	47
2nd F_Foyer 3	-	60	60	-	38
1st_BR 029	-	60	60	-	26
2nd F_Store	60	-	-	-	71

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
2nd F_BR 048	-	60	60	22	24
2nd F_Foyer 4	-	60	60	-	39
2nd F_Foyer 5	-	60	60	-	165
2nd F_Drugs Room	-	60	60	-	43
2nd F_BR 058	-	60	60	-	22
2nd F_BED 057	-	60	60	-	60
2nd F_BR 057	-	60	60	-	21
2nd F_BED 058	-	60	60	-	76
2nd F_BR 059	-	60	60	-	22
2nd F_BED 059	-	60	60	-	72
2nd F_BED 060	-	60	60	-	63
2nd F_BR 060	-	60	60	-	23
2nd F_Dining/Lounge Room	-	60	60	-	343
1st F_Foyer 2	-	60	60	-	35
2nd F_Foyer 1	-	60	60	-	28
stairs	-	60	60	-	48
Archive Store	60	-	-	-	205
Staff Room	60	-	-	-	351
Hairn and beauty	-	60	60	-	146
Training/Conference Room	60	-	-	-	697
Plant Room	60	-	-	-	213
WC	-	60	60	-	33
Cooms Room	60	-	-	-	122
Stairs	-	60	60	-	46
Entrance	-	60	60	22	180
Lift + DW	-	60	60	-	34
kitchen	-	60	60	-	578
store	60	-	-	-	40
Store	60	-	-	-	43
Female change	-	60	60	-	62
Male Change	-	60	60	-	62
Store	60	-	-	-	239
Stairs	-	60	60	-	48
Kitchen change	-	60	60	-	92
Laundry Room	-	60	60	-	517
Cinema	60	-	-	-	379
Lift	-	60	60	-	24
Private Family Room	60	-	-	-	332
Sensory Room	-	60	60	-	166
Activity Room	60	-	-	-	588
WC	-	60	60	-	34
Foyer 1	-	60	60	-	118
WC	-	60	60	-	30

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
Office space	60	-	-	-	193
Meeting Room	60	-	-	-	408
Foyer 4	-	60	-	-	188
Foyer 2	-	60	-	-	20
Foyer 3	-	60	-	-	122

Criterion 3: The spaces in the building should have appropriate passive control measures to limit solar gains

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
Manager office	NO (-78.6%)	NO
Drugs Room	N/A	N/A
Admin Room	NO (-77.6%)	NO
Gf_BED 014	NO (-78.9%)	NO
Gf_BED 015	NO (-78.9%)	NO
GF_BED 016	NO (-78.9%)	NO
GF_BED 017	NO (-88.8%)	NO
Gf_BED 018	NO (-85.2%)	NO
Gf_BED 019	NO (-73%)	NO
Gf_BED 020	NO (-72.6%)	NO
Gf_BED 021	NO (-65%)	NO
GF_Dining/ Lounge Room	NO (-77.3%)	NO
Gf_BED 013	NO (-84.4%)	NO
Gf_BED 012	NO (-71.7%)	NO
Gf_BED 011	NO (-67.4%)	NO
Gf_BED 01	NO (-73.5%)	NO
Gf_BED 02	NO (-73%)	NO
Gf_BED 03	NO (-84.1%)	NO
Gf_BED 04	NO (-73%)	NO
Gf_BED 05	NO (-73%)	NO
Gf_BED 06	NO (-73.5%)	NO
Gf_BED 07	NO (-77%)	NO
Gf_BED 08	NO (-84.1%)	NO
Gf_BED 010	NO (-78.1%)	NO
Gf_BED 09	NO (-78.1%)	NO
Dining Room	NO (-59%)	NO
1st F_BED 022	NO (-73.5%)	NO
1st F_BED 023	NO (-73%)	NO
1st F_Sluice	NO (-63.7%)	NO
1st F_BED 024	NO (-84.1%)	NO
1st F_BED 025	NO (-73%)	NO
1st _BED 026	NO (-73%)	NO
1st F_BED 027	NO (-73.5%)	NO
1st F_BED 028	NO (-77%)	NO
1st F_BED 029	NO (-84.1%)	NO

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
1st F_BED 031	NO (-78.1%)	NO
1st F_BED 030	NO (-78.1%)	NO
1st F_Drugs Room	N/A	N/A
1st F_BED 033	NO (-60%)	NO
1st F_dining room extension	NO (-56.2%)	NO
1st F_BED 034	NO (-62.4%)	NO
1st F_BED 035	NO (-52.6%)	NO
1st f_BED 039	NO (-78.9%)	NO
1st F_BED 040	NO (-78.9%)	NO
1st f_BED 041	NO (-78.9%)	NO
1st F_BED 042	NO (-88.8%)	NO
1st F_BED 043	NO (-85.2%)	NO
1st_F 044	NO (-73%)	NO
1st F_BED 045	NO (-72.6%)	NO
1st F_BED 046	NO (-65.1%)	NO
1st F_BED 038	NO (-84.4%)	NO
1st f_BED 037	NO (-71.7%)	NO
1st f_BED 036	NO (-67.4%)	NO
1st F_BED 032	NO (-63.9%)	NO
1st F_Dning / Lounge room	NO (-73.3%)	NO
2nd F_BED 047	NO (-73.5%)	NO
2nd F_BED 048	NO (-73%)	NO
1st F_Sluice (1)	NO (-63.7%)	NO
2nd F_BED 049	NO (-84.1%)	NO
2nd F_BED 050	NO (-73%)	NO
2nd F_BED 051	NO (-73%)	NO
2nd F_BED 052	NO (-73.5%)	NO
2nd F_BED 053	NO (-77%)	NO
2nd F_BED 055	NO (-78.1%)	NO
2nd F_BED 054	NO (-78.1%)	NO
2nd F_BED 056	NO (-63.9%)	NO
2nd F_Drugs Room	N/A	N/A
2nd F_BED 057	NO (-62.5%)	NO
2nd F_BED 058	NO (-74.4%)	NO
2nd F_BED 059	NO (-66%)	NO
2nd F_BED 060	NO (-67.8%)	NO
2nd F_Dining/Lounge Room	NO (-80.1%)	NO
Staff Room	N/A	N/A
Training/Conference Room	N/A	N/A
Cooms Room	N/A	N/A
Entrance	N/A	N/A
Cinema	NO (-66%)	NO
Private Family Room	NO (-79.6%)	NO
Activity Room	NO (-86.8%)	NO
Office space	N/A	N/A
Meeting Room	NO (-79.5%)	NO

Criterion 4: The performance of the building, as built, should be consistent with the calculated BER

Separate submission

Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place

Separate submission

EPBD (Recast): Consideration of alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	YES
Is evidence of such assessment available as a separate submission?	YES
Are any such measures included in the proposed design?	YES

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters		Building Use		
	Actual	Notional	% Area	Building Type
Area [m ²]	3624.4	3624.4		A1/A2 Retail/Financial and Professional services
External area [m ²]	3905.7	3905.7		A3/A4/A5 Restaurants and Cafes/Drinking Est./Takeaways
Weather	LON	LON		B1 Offices and Workshop businesses
Infiltration [m ³ /hm ² @ 50Pa]	1	3		B2 to B7 General Industrial and Special Industrial Groups
Average conductance [W/K]	832.96	1759.23		B8 Storage or Distribution
Average U-value [W/m ² K]	0.21	0.45		C1 Hotels
Alpha value* [%]	31.62	19.43	94	C2 Residential Institutions: Hospitals and Care Homes
			6	C2 Residential Institutions: Residential schools
				C2 Residential Institutions: Universities and colleges
				C2A Secure Residential Institutions
				Residential spaces
				D1 Non-residential Institutions: Community/Day Centre
				D1 Non-residential Institutions: Libraries, Museums, and Galleries
				D1 Non-residential Institutions: Education
				D1 Non-residential Institutions: Primary Health Care Building
				D1 Non-residential Institutions: Crown and County Courts
				D2 General Assembly and Leisure, Night Clubs, and Theatres
				Others: Passenger terminals
				Others: Emergency services
				Others: Miscellaneous 24hr activities
				Others: Car Parks 24 hrs
				Others: Stand alone utility block

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Energy Consumption by End Use [kWh/m²]

	Actual	Notional
Heating	30.53	42.91
Cooling	0	0
Auxiliary	4.02	2.2
Lighting	15.86	16.58
Hot water	84.78	100.02
Equipment*	60.53	60.53
TOTAL**	135.19	161.71

* Energy used by equipment does not count towards the total for consumption or calculating emissions.

** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

	Actual	Notional
Photovoltaic systems	0	0
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0

Energy & CO₂ Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m ²]	278.71	344.93
Primary energy* [kWh/m ²]	201.72	230.6
Total emissions [kg/m ²]	35.2	40.4

* Primary energy is net of any electrical energy displaced by CHP generators, if applicable.

HVAC Systems Performance

System Type	Heat dem MJ/m ²	Cool dem MJ/m ²	Heat con kWh/m ²	Cool con kWh/m ²	Aux con kWh/m ²	Heat SSEEF	Cool SSEER	Heat gen SEFF	Cool gen SEER
[ST] Central heating using water: radiators, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity									
Actual	94	184.7	30.5	0	4	0.86	0	0.91	0
Notional	126.5	218.4	42.9	0	2.2	0.82	0	----	----

Key to terms

Heat dem [MJ/m ²]	= Heating energy demand
Cool dem [MJ/m ²]	= Cooling energy demand
Heat con [kWh/m ²]	= Heating energy consumption
Cool con [kWh/m ²]	= Cooling energy consumption
Aux con [kWh/m ²]	= Auxiliary energy consumption
Heat SSEEF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type

Key Features

The Building Control Body is advised to give particular attention to items whose specifications are better than typically expected.

Building fabric

Element	U _{i-Typ}	U _{i-Min}	Surface where the minimum value occurs*
Wall	0.23	0.13	"SL000000_W4"
Floor	0.2	0.08	"MN000000_F"
Roof	0.15	0.11	"MN000000_C"
Windows, roof windows, and rooflights	1.5	0.98	"SL000000_W4_O0"
Personnel doors	1.5	1.03	"ST000000_W3_O0"
Vehicle access & similar large doors	1.5	-	"No external vehicle access doors"
High usage entrance doors	1.5	-	"No external high usage entrance doors"

U_{i-Typ} = Typical individual element U-values [W/(m²K)] U_{i-Min} = Minimum individual element U-values [W/(m²K)]

* There might be more than one surface where the minimum U-value occurs.

Air Permeability	Typical value	This building
m ³ /(h.m ²) at 50 Pa	5	1

SBEM Main Calculation Output Document

Mon Apr 04 15:28:01 2022

v5.6.b.0


Building name

18 Pield Heath-Be Lean LETI+WW

Building type: C2 Residential Institutions - Hospitals and Care Homes

SBEM is an energy calculation tool for the purpose of assessing and demonstrating compliance with Building Regulations (Part L for England and Wales, Section 6 for Scotland, Part F for Northern Ireland, and Building Bye-laws Jersey Part 11) and to produce Energy Performance Certificates and Building Energy Ratings. Although the data produced by the tool may be of use in the design process, **SBEM is not intended as a building design tool.**

Building Energy Performance and CO2 emissions





0 kgCO2/m2 displaced by the use of renewable sources.



Building area is 3624.4 m2

Annual Energy Consumption

(Pie chart including Equipment end-use)





(Pie chart excluding Equipment end-use)





(*) Although energy consumption by equipment is shown in the graphs for information, this end-use has not been included in the total results of the building or the calculation of the ratings.

Annual Heating Demand



Annual Cooling Demand





Project name

18 Pield Heath-Be Green ASHP+WWHR As designed

Date: Mon Apr 04 17:21:39 2022

Administrative information

Building Details

Address: London, UB8 3NF

Certification tool

Calculation engine: SBEM

Calculation engine version: v5.6.b.0

Interface to calculation engine: Virtual Environment

Interface to calculation engine version: v7.0.13

BRUKL compliance check version: v5.6.b.0

Certifier details

Name: SyntegraENG

Telephone number: 01184028520

Address: 63 Milford Rd, Reading, RG1 8LG

Criterion 1: The calculated CO₂ emission rate for the building must not exceed the target

CO ₂ emission rate from the notional building, kgCO ₂ /m ² .annum	33.9
Target CO ₂ emission rate (TER), kgCO ₂ /m ² .annum	33.9
Building CO ₂ emission rate (BER), kgCO ₂ /m ² .annum	25.3
Are emissions from the building less than or equal to the target?	BER =< TER
Are as built details the same as used in the BER calculations?	Separate submission

Criterion 2: The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Values which do not achieve the standards in the Non-Domestic Building Services Compliance Guide and Part L are displayed in red.

Building fabric

Element	U _a -Limit	U _a -Calc	U _i -Calc	Surface where the maximum value occurs*
Wall**	0.35	0.24	1.79	"FY000002_W17_A0"
Floor	0.25	0.08	0.08	"MN000000_F"
Roof	0.25	0.12	1.09	"LF000001_C_A0"
Windows***, roof windows, and rooflights	2.2	0.98	0.98	"SL000000_W4_O0"
Personnel doors	2.2	1.03	1.03	"ST000000_W3_O0"
Vehicle access & similar large doors	1.5	-	-	"No external vehicle access doors"
High usage entrance doors	3.5	-	-	"No external high usage entrance doors"

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]

U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]

U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]

* There might be more than one surface where the maximum U-value occurs.

** Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

*** Display windows and similar glazing are excluded from the U-value check.

N.B.: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

Air Permeability	Worst acceptable standard	This building
m ³ /(h.m ²) at 50 Pa	10	1

Building services

The standard values listed below are minimum values for efficiencies and maximum values for SFPs. Refer to the Non-Domestic Building Services Compliance Guide for details.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	YES
Whole building electric power factor achieved by power factor correction	<0.9

1- ASHP

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	3.5	-	-	-	-
Standard value	2.5*	N/A	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					YES

* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. For types <=12 kW output, refer to EN 14825 for limiting standards.

1- SYST0001-DHW

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	Hot water provided by HVAC system	-
Standard value	N/A	N/A

Local mechanical ventilation, exhaust, and terminal units

ID	System type in Non-domestic Building Services Compliance Guide
A	Local supply or extract ventilation units serving a single area
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal supply and extract ventilation units serving a single room or zone with heating and heat recovery
E	Local supply and extract ventilation system serving a single area with heating and heat recovery
F	Other local ventilation units
G	Fan-assisted terminal VAV unit
H	Fan coil units
I	Zonal extract system where the fan is remote from the zone with grease filter

Zone name	ID of system type	SFP [W/(l/s)]									HR efficiency	
		A	B	C	D	E	F	G	H	I		
Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard	
Ass Bath	0.3	-	-	-	-	-	-	-	-	-	N/A	
wc	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_Br 014	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_Br 015	0.3	-	-	-	-	-	-	-	-	-	N/A	
GF_Br 016	0.3	-	-	-	-	-	-	-	-	-	N/A	
GF_BR 017	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_BR018	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_BR 019	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_BR 020	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_BR021	0.3	-	-	-	-	-	-	-	-	-	N/A	
WC	0.3	-	-	-	-	-	-	-	-	-	N/A	
Assisted Bath	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_BR 013	0.3	-	-	-	-	-	-	-	-	-	N/A	
GF_BR 012	0.3	-	-	-	-	-	-	-	-	-	N/A	
Gf_BR 011	0.3	-	-	-	-	-	-	-	-	-	N/A	

Zone name	SFP [W/(l/s)]									HR efficiency	
	A	B	C	D	E	F	G	H	I		
ID of system type	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
Gf_BR 01	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 02	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 03	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 04	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 05	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 06	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 07	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 08	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 010	0.3	-	-	-	-	-	-	-	-	-	N/A
Gf_BR 09	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 022	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 023	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 024	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 025	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 026	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 027	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 028	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 031	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 030	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 033	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 034	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 035	0.3	-	-	-	-	-	-	-	-	-	N/A
1st f_Br 039	0.3	-	-	-	-	-	-	-	-	-	N/A
1st_Br 040	0.3	-	-	-	-	-	-	-	-	-	N/A
1st f_Br 041	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 042	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 043	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 044	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 045	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_Assisted Bath	0.3	-	-	-	-	-	-	-	-	-	N/A
1st f_BR 036	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR046	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 038	0.3	-	-	-	-	-	-	-	-	-	N/A
1st f_BR 037	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_WC	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_BR 032	0.3	-	-	-	-	-	-	-	-	-	N/A
1st F_Assisted Bathroom	0.3	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 047	0.3	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 049	0.3	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 050	0.3	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 051	0.3	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 052	0.3	-	-	-	-	-	-	-	-	-	N/A
2nd F_BR 053	0.3	-	-	-	-	-	-	-	-	-	N/A

Zone name	SFP [W/(l/s)]									HR efficiency		
	A	B	C	D	E	F	G	H	I			
ID of system type	Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
2nd F_BR 055	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 054	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 056	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_Assisted Bathroom	0.3	-	-	-	-	-	-	-	-	-	N/A	
1st_BR 029	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 048	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 058	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 057	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 059	0.3	-	-	-	-	-	-	-	-	-	N/A	
2nd F_BR 060	0.3	-	-	-	-	-	-	-	-	-	N/A	
WC	0.3	-	-	-	-	-	-	-	-	-	N/A	
WC	0.3	-	-	-	-	-	-	-	-	-	N/A	
WC	0.3	-	-	-	-	-	-	-	-	-	N/A	

General lighting and display lighting		Luminous efficacy [lm/W]				
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]	
Sluice	-	60	60	22		
Stairs	-	60	-	-	25	
Ass Bath	-	60	-	-	48	
Stairs	-	60	-	-	48	
Manager office	60	-	-	-	144	
Drugs Room	60	-	-	-	120	
Foyer GF 6	-	60	-	-	56	
Admin Room	60	-	-	-	206	
WC	-	60	-	-	21	
Foyer GF 4	-	60	-	-	109	
Gf_BED 014	-	60	-	-	66	
Gf_Br 014	-	60	-	-	24	
Gf_Br 015	-	60	-	-	24	
Gf_BED 015	-	60	-	-	65	
GF_Br 016	-	60	-	-	24	
GF_BED 016	-	60	-	-	65	
GF_BED 017	-	60	-	-	68	
GF_BR 017	-	60	-	-	26	
Gf_BR018	-	60	-	-	23	
Gf_BED 018	-	60	-	-	67	
Gf_BED 019	-	60	-	-	63	
Gf_BR 019	-	60	-	-	24	
Gf_BR 020	-	60	-	-	24	
Gf_BED 020	-	60	-	-	62	
Gf_BR021	-	60	-	-	25	
Gf_BED 021	-	60	-	-	59	

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
WC	-	60	60	22	19
Assisted Bath	-	60	60	-	59
LIFT	-	60	60	-	24
GF_Dining/ Lounge Room	-	60	60	-	304
Gf_BR 013	-	60	60	-	26
Gf_BED 013	-	60	60	-	61
Gf_BED 012	-	60	60	-	65
GF_BR 012	-	60	60	-	23
Gf_BED 011	-	60	60	-	65
Gf_BR 011	-	60	60	-	23
Gf_BED 01	-	60	60	-	65
Gf_BR 01	-	60	60	-	24
Gf_BR 02	-	60	60	-	24
Gf_BED 02	-	60	60	-	62
Gf_BR 03	-	60	60	-	24
Gf_BED 03	-	60	60	-	66
Gf_BR04	-	60	60	-	24
Gf_BED 04	-	60	60	-	65
Gf_BR 05	-	60	60	-	24
Gf_BED 05	-	60	60	-	65
Gf_BR 06	-	60	60	-	24
Gf_BED 06	-	60	60	-	63
Gf_BED 07	-	60	60	-	71
Gf_BR 07	-	60	60	-	24
Gf_BR 08	-	60	60	-	26
Gf_BED 08	-	60	60	-	66
Gf_BR 010	-	60	60	-	24
Gf_BED 010	-	60	60	-	63
Gf_BED 09	-	60	60	-	63
Gf_BR 09	-	60	60	-	24
Dining Room	-	60	60	-	187
Foyer GF 5	-	60	60	-	200
Foyer 1 & Sitting area	-	60	60	-	183
1st F_BED 022	-	60	60	-	65
1st F_BR 022	-	60	60	-	24
1st F_BR 023	-	60	60	-	24
1st F_BED 023	-	60	60	-	62
1st F_Sluice	-	60	60	-	31
1st F_BR 024	-	60	60	-	24
1st F_BED 024	-	60	60	-	66
1st F_BR 025	-	60	60	-	24
1st F_BED 025	-	60	60	-	65
1st F_BR 026	-	60	60	-	24

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
1st_BED 026	-	60	60	22	65
1st_F_BR 027	-	60	60	-	24
1st_F_BED 027	-	60	60	-	63
1st_F_BED 028	-	60	60	-	71
1st_F_BR 028	-	60	60	-	24
1st_F_BED 029	-	60	60	-	66
1st_F_Foyer 6	-	60	60	-	56
1st_F_Stairs	-	60	60	-	48
1st_F_BR 031	-	60	60	-	24
1st_F_BED 031	-	60	60	-	63
1st_F_BED 030	-	60	60	-	63
1st_F_BR 030	-	60	60	-	24
1st_F_Drugs Room	-	60	60	-	43
1st_F_BR 033	-	60	60	-	21
1st_F_BED 033	-	60	60	-	60
1st_F_Stairs case	-	60	60	-	46
Stairs and Main entrance	-	60	60	-	80
1st_F_dining room extension	-	60	60	-	39
1st_F_BR 034	-	60	60	-	25
1st_F_BED 034	-	60	60	-	60
1st_F_BED 035	-	60	60	-	60
1st_F_BR 035	-	60	60	-	25
1st_F_Foyer 1 & Sitting area	-	60	60	-	183
1ST_f_Stairs	-	60	60	-	48
1st_f_BED 039	-	60	60	-	66
1st_f_Br 039	-	60	60	-	24
1st_Br 040	-	60	60	-	24
1st_F_BED 040	-	60	60	-	65
1st_f_Br 041	-	60	60	-	24
1st_f_BED 041	-	60	60	-	65
1st_F_BED 042	-	60	60	-	68
1st_F_BR 042	-	60	60	-	26
1st_F_BR 043	-	60	60	-	23
1st_F_BED 043	-	60	60	-	67
1st_F_044	-	60	60	-	63
1st_F_BR 044	-	60	60	-	24
1st_F_BR 045	-	60	60	-	24
1st_F_BED 045	-	60	60	-	62
1st_F_Assisted Bath	-	60	60	-	59
1st_F_LIFT	-	60	60	-	24
1st_f_BR 036	-	60	60	-	23
1st_F_BR046	-	60	60	-	25
1st_F_BED 046	-	60	60	-	59

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
1st F_BR 038	-	60	60	22	
1st F_BED 038	-	60	60	-	61
1st f_BED 037	-	60	60	-	65
1st f_BED 036	-	60	60	-	65
1st f_BR 037	-	60	60	-	23
1st F_WC	-	60	60	-	30
Foyer 3	-	60	60	-	50
Foyer 2	-	60	60	-	35
1st F_BR 032	-	60	60	-	23
1st F_BED 032	-	60	60	-	62
1st F_Assisted Bathroom	-	60	60	-	47
1st F_Foyer 5	-	60	60	-	200
1st F_Foyer 4	-	60	60	-	38
1st F_Dning / Lounge room	-	60	60	-	382
1st F_Foyer 3	-	60	60	-	41
1st F_Store	60	-	-	-	53
2nd F_BED 047	-	60	60	-	65
2nd F_BR 047	-	60	60	-	24
2nd F_BED 048	-	60	60	-	62
1st F_Sluice (1)	-	60	60	-	31
2nd F_BR 049	-	60	60	-	24
2nd F_BED 049	-	60	60	-	66
2nd F_BR 050	-	60	60	-	24
2nd F_BED 050	-	60	60	-	65
2nd F_BR 051	-	60	60	-	24
2nd F_BED 051	-	60	60	-	65
2nd F_BR 052	-	60	60	-	24
2nd F_BED 052	-	60	60	-	63
2nd F_BED 053	-	60	60	-	71
2nd F_BR 053	-	60	60	-	24
1st F_Foyer 6 (1)	-	60	60	-	56
1st F_Stairs (1)	-	60	60	-	48
2nd F_BR 055	-	60	60	-	24
2nd F_BED 055	-	60	60	-	63
2nd F_BED 054	-	60	60	-	63
2nd F_BR 054	-	60	60	-	24
1st F_Stairs case (1)	-	60	60	-	46
2nd F_BR 056	-	60	60	-	23
2nd F_BED 056	-	60	60	-	62
2nd F_Assisted Bathroom	-	60	60	-	47
2nd F_Foyer 3	-	60	60	-	38
1st_BR 029	-	60	60	-	26
2nd F_Store	60	-	-	-	71

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
2nd F_BR 048	-	60	60	22	24
2nd F_Foyer 4	-	60	60	-	39
2nd F_Foyer 5	-	60	60	-	165
2nd F_Drugs Room	-	60	60	-	43
2nd F_BR 058	-	60	60	-	22
2nd F_BED 057	-	60	60	-	60
2nd F_BR 057	-	60	60	-	21
2nd F_BED 058	-	60	60	-	76
2nd F_BR 059	-	60	60	-	22
2nd F_BED 059	-	60	60	-	72
2nd F_BED 060	-	60	60	-	63
2nd F_BR 060	-	60	60	-	23
2nd F_Dining/Lounge Room	-	60	60	-	343
1st F_Foyer 2	-	60	60	-	35
2nd F_Foyer 1	-	60	60	-	28
stairs	-	60	60	-	48
Archive Store	60	-	-	-	205
Staff Room	60	-	-	-	351
Hairn and beauty	-	60	60	-	146
Training/Conference Room	60	-	-	-	697
Plant Room	60	-	-	-	213
WC	-	60	60	-	33
Cooms Room	60	-	-	-	122
Stairs	-	60	60	-	46
Entrance	-	60	60	22	180
Lift + DW	-	60	60	-	34
kitchen	-	60	60	-	578
store	60	-	-	-	40
Store	60	-	-	-	43
Female change	-	60	60	-	62
Male Change	-	60	60	-	62
Store	60	-	-	-	239
Stairs	-	60	60	-	48
Kitchen change	-	60	60	-	92
Laundry Room	-	60	60	-	517
Cinema	60	-	-	-	379
Lift	-	60	60	-	24
Private Family Room	60	-	-	-	332
Sensory Room	-	60	60	-	166
Activity Room	60	-	-	-	588
WC	-	60	60	-	34
Foyer 1	-	60	60	-	118
WC	-	60	60	-	30

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name	Standard value	Luminaire	Lamp	Display lamp	General lighting [W]
Office space	60	-	-	-	193
Meeting Room	60	-	-	-	408
Foyer 4	-	60	-	-	188
Foyer 2	-	60	-	-	20
Foyer 3	-	60	-	-	122

Criterion 3: The spaces in the building should have appropriate passive control measures to limit solar gains

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
Manager office	NO (-78.6%)	NO
Drugs Room	N/A	N/A
Admin Room	NO (-77.6%)	NO
Gf_BED 014	NO (-78.9%)	NO
Gf_BED 015	NO (-78.9%)	NO
GF_BED 016	NO (-78.9%)	NO
GF_BED 017	NO (-88.8%)	NO
Gf_BED 018	NO (-85.2%)	NO
Gf_BED 019	NO (-73%)	NO
Gf_BED 020	NO (-72.6%)	NO
Gf_BED 021	NO (-65%)	NO
GF_Dining/ Lounge Room	NO (-77.3%)	NO
Gf_BED 013	NO (-84.4%)	NO
Gf_BED 012	NO (-71.7%)	NO
Gf_BED 011	NO (-67.4%)	NO
Gf_BED 01	NO (-73.5%)	NO
Gf_BED 02	NO (-73%)	NO
Gf_BED 03	NO (-84.1%)	NO
Gf_BED 04	NO (-73%)	NO
Gf_BED 05	NO (-73%)	NO
Gf_BED 06	NO (-73.5%)	NO
Gf_BED 07	NO (-77%)	NO
Gf_BED 08	NO (-84.1%)	NO
Gf_BED 010	NO (-78.1%)	NO
Gf_BED 09	NO (-78.1%)	NO
Dining Room	NO (-59%)	NO
1st F_BED 022	NO (-73.5%)	NO
1st F_BED 023	NO (-73%)	NO
1st F_Sluice	NO (-63.7%)	NO
1st F_BED 024	NO (-84.1%)	NO
1st F_BED 025	NO (-73%)	NO
1st _BED 026	NO (-73%)	NO
1st F_BED 027	NO (-73.5%)	NO
1st F_BED 028	NO (-77%)	NO
1st F_BED 029	NO (-84.1%)	NO

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
1st F_BED 031	NO (-78.1%)	NO
1st F_BED 030	NO (-78.1%)	NO
1st F_Drugs Room	N/A	N/A
1st F_BED 033	NO (-60%)	NO
1st F_dining room extension	NO (-56.2%)	NO
1st F_BED 034	NO (-62.4%)	NO
1st F_BED 035	NO (-52.6%)	NO
1st f_BED 039	NO (-78.9%)	NO
1st F_BED 040	NO (-78.9%)	NO
1st f_BED 041	NO (-78.9%)	NO
1st F_BED 042	NO (-88.8%)	NO
1st F_BED 043	NO (-85.2%)	NO
1st_F 044	NO (-73%)	NO
1st F_BED 045	NO (-72.6%)	NO
1st F_BED 046	NO (-65.1%)	NO
1st F_BED 038	NO (-84.4%)	NO
1st f_BED 037	NO (-71.7%)	NO
1st f_BED 036	NO (-67.4%)	NO
1st F_BED 032	NO (-63.9%)	NO
1st F_Dning / Lounge room	NO (-73.3%)	NO
2nd F_BED 047	NO (-73.5%)	NO
2nd F_BED 048	NO (-73%)	NO
1st F_Sluice (1)	NO (-63.7%)	NO
2nd F_BED 049	NO (-84.1%)	NO
2nd F_BED 050	NO (-73%)	NO
2nd F_BED 051	NO (-73%)	NO
2nd F_BED 052	NO (-73.5%)	NO
2nd F_BED 053	NO (-77%)	NO
2nd F_BED 055	NO (-78.1%)	NO
2nd F_BED 054	NO (-78.1%)	NO
2nd F_BED 056	NO (-63.9%)	NO
2nd F_Drugs Room	N/A	N/A
2nd F_BED 057	NO (-62.5%)	NO
2nd F_BED 058	NO (-74.4%)	NO
2nd F_BED 059	NO (-66%)	NO
2nd F_BED 060	NO (-67.8%)	NO
2nd F_Dining/Lounge Room	NO (-80.1%)	NO
Staff Room	N/A	N/A
Training/Conference Room	N/A	N/A
Cooms Room	N/A	N/A
Entrance	N/A	N/A
Cinema	NO (-66%)	NO
Private Family Room	NO (-79.6%)	NO
Activity Room	NO (-86.8%)	NO
Office space	N/A	N/A
Meeting Room	NO (-79.5%)	NO

Criterion 4: The performance of the building, as built, should be consistent with the calculated BER

Separate submission

Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place

Separate submission

EPBD (Recast): Consideration of alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	YES
Is evidence of such assessment available as a separate submission?	YES
Are any such measures included in the proposed design?	YES

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters		Building Use	
	Actual	Notional	% Area
Area [m ²]	3624.4	3624.4	A1/A2 Retail/Financial and Professional services
External area [m ²]	3905.7	3905.7	A3/A4/A5 Restaurants and Cafes/Drinking Est./Takeaways
Weather	LON	LON	B1 Offices and Workshop businesses
Infiltration [m ³ /hm ² @ 50Pa]	1	3	B2 to B7 General Industrial and Special Industrial Groups
Average conductance [W/K]	832.96	1759.23	B8 Storage or Distribution
Average U-value [W/m ² K]	0.21	0.45	C1 Hotels
Alpha value* [%]	31.62	19.43	C2 Residential Institutions: Hospitals and Care Homes
			C2 Residential Institutions: Residential schools
			C2 Residential Institutions: Universities and colleges
			C2A Secure Residential Institutions
			Residential spaces
			D1 Non-residential Institutions: Community/Day Centre
			D1 Non-residential Institutions: Libraries, Museums, and Galleries
			D1 Non-residential Institutions: Education
			D1 Non-residential Institutions: Primary Health Care Building
			D1 Non-residential Institutions: Crown and County Courts
			D2 General Assembly and Leisure, Night Clubs, and Theatres
			Others: Passenger terminals
			Others: Emergency services
			Others: Miscellaneous 24hr activities
			Others: Car Parks 24 hrs
			Others: Stand alone utility block

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Energy Consumption by End Use [kWh/m²]

	Actual	Notional
Heating	7.94	14.46
Cooling	0	0
Auxiliary	4.02	2.2
Lighting	15.86	16.58
Hot water	22.54	33.71
Equipment*	60.53	60.53
TOTAL**	50.36	66.96

* Energy used by equipment does not count towards the total for consumption or calculating emissions.

** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

	Actual	Notional
Photovoltaic systems	1.71	0
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0

Energy & CO₂ Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m ²]	278.71	344.93
Primary energy* [kWh/m ²]	154.61	200.42
Total emissions [kg/m ²]	25.3	33.9

* Primary energy is net of any electrical energy displaced by CHP generators, if applicable.

HVAC Systems Performance

System Type	Heat dem MJ/m ²	Cool dem MJ/m ²	Heat con kWh/m ²	Cool con kWh/m ²	Aux con kWh/m ²	Heat SSEEF	Cool SSEER	Heat gen SEFF	Cool gen SEER
[ST] Central heating using water: radiators, [HS] Heat pump (electric): air source, [HFT] Electricity, [CFT] Electricity									
Actual	94	184.7	7.9	0	4	3.29	0	3.5	0
Notional	126.5	218.4	14.5	0	2.2	2.43	0	----	----

Key to terms

Heat dem [MJ/m ²]	= Heating energy demand
Cool dem [MJ/m ²]	= Cooling energy demand
Heat con [kWh/m ²]	= Heating energy consumption
Cool con [kWh/m ²]	= Cooling energy consumption
Aux con [kWh/m ²]	= Auxiliary energy consumption
Heat SSEEF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type

Key Features

The Building Control Body is advised to give particular attention to items whose specifications are better than typically expected.

Building fabric

Element	U _{i-Typ}	U _{i-Min}	Surface where the minimum value occurs*
Wall	0.23	0.13	"SL000000_W4"
Floor	0.2	0.08	"MN000000_F"
Roof	0.15	0.11	"MN000000_C"
Windows, roof windows, and rooflights	1.5	0.98	"SL000000_W4_O0"
Personnel doors	1.5	1.03	"ST000000_W3_O0"
Vehicle access & similar large doors	1.5	-	"No external vehicle access doors"
High usage entrance doors	1.5	-	"No external high usage entrance doors"

U_{i-Typ} = Typical individual element U-values [W/(m²K)] U_{i-Min} = Minimum individual element U-values [W/(m²K)]

* There might be more than one surface where the minimum U-value occurs.

Air Permeability	Typical value	This building
m ³ /(h.m ²) at 50 Pa	5	1

SBEM Main Calculation Output Document

Mon Apr 04 17:21:37 2022

v5.6.b.0


Building name

18 Pield Heath-Be Green ASHP+W

Building type: C2 Residential Institutions - Hospitals and Care Homes

SBEM is an energy calculation tool for the purpose of assessing and demonstrating compliance with Building Regulations (Part L for England and Wales, Section 6 for Scotland, Part F for Northern Ireland, and Building Bye-laws Jersey Part 11) and to produce Energy Performance Certificates and Building Energy Ratings. Although the data produced by the tool may be of use in the design process, **SBEM is not intended as a building design tool.**

Building Energy Performance and CO2 emissions





1 kgCO2/m² displaced by the use of renewable sources.



Building area is 3624.4 m²

Annual Energy Consumption

(Pie chart including Equipment end-use)





(Pie chart excluding Equipment end-use)



(*) Although energy consumption by equipment is shown in the graphs for information, this end-use has not been included in the total results of the building or the calculation of the ratings.

Annual Heating Demand



Annual Cooling Demand

