



EUROCLAD VIEO 0.9mm ARS ALUMINIUM ROOF SHEET
FIXED IN ACCORDANCE WITH MANUFACTURERS REQUIREMENTS
COLOUR TO BE CONFIRMED AS EITHER RAL 7016 or RAL 7012

VIEO STAINLESS STEEL 2-PART SLIDING CLIP

NOTE: THIS DETAIL IS NOT COMPLIANT WITH
EUROCLAD STANDARD DETAILS - PLEASE REFER TO
EURCLAD DRAWING "CD_SD_ECS_VWR_TD_17"
FOR APPROVED DETAIL.

BUGLER DEVELOPMENTS TO CONFIRM WITH NHBC
& BUILDING CONTROL THAT THIS DETAIL IS
ACCEPTABLE

MEMBRANE LINED GUTTER
Raintite 1.2/1.2 Steel

18mm PLYWOOD FASCIA
& ASSOCIATED TIMBER
SUPPORT BY OTHERS

TIMBER DECK BY OTHERS
(18mm PLYWOOD)

A2 FIRE RESISTANT VCL

205mm KNAUF ROCSLAB

25mm KNAUF ROCSLAB

ROCTBUE PLUS FIXINGS:
HTK50x185/TKE4.8x70

NOTE:
STRUCTURE SHOWN INDICATIVELY
INTERNAL INSULATION, AIR SEALS
& FINISHES BY OTHERS

DETAIL 4

PJB CLADDING SERVICES LTD
Unit 5, Wornal Park, Menmarsh Road, Worminghall, Bucks, HP18 9PH
T: 01844 338 416 F: 01844 339 139 E: info@pjbcladding.co.uk

Rev.	Description:	By:	Date:

Project: OTTERFIELD		Date: MAY '25		Scale: 1:4 @ A3		Drawn: AWT		Checked: -	
------------------------	--	------------------	--	--------------------	--	---------------	--	---------------	--

Title: VALLEY GUTTER		Drawing No: BUG-2507-104		Rev. -	
-------------------------	--	-----------------------------	--	-----------	--