

Notes

This drawing is the Copyright of blyth developments, and may not be reproduced or copied, in whole or in part, without express permission.

Figured dimensions shall be used in preference to scaled dimensions. All dimensions shall be checked on site before commencing works.


*All work shall comply with the latest Building Regulations and be to the satisfaction of the Local Authority.

*Workmanship and methods of construction shall be at least to the standard prescribed by the relevant Codes of Practice.


Materials shall be suitable for the purpose for which they are used and the quality shall not be lower than that defined in the relevant British or Continental Standard so designated.

General Specifications


1. All drainage shown on this drawing is assumed only and it is the contractors responsibility to check exact depths and locations prior to the commencement of the works. or proposed drains found under the proposed extension are to be surrounded in 150mm pea shingle and reinforced concrete bricks are to be provided in the walls above the drain run.
3. Existing sub-floor ventilation is to be maintained (if necessary) by providing 100mm dia PVC ducts extending from the existing air bricks to new 225 x 150mm uPVC ducts, to be double glazed and to be to BS6206 and any glazing within 800mm of the floor level is to be completed or laminated in accordance with Part C.
5. All new habitable rooms are to be provided with permanent ventilation of 600mm², and this is to be achieved by providing either trickle vents in the windows, or by providing mechanical extract fans, and all fans are to have a minimum and bearing of 150mm.
7. All steel beams are to be encased in 2 layers of 12.5mm plaster board and skim coat of plaster to achieve a fire rating of 12 hour.
9. All glazing is to be low E glass with 16mm air gaps between panes.
11. All electrical work required to meet the requirements of Part P (Electrical Safety) must be designed, installed, inspected and tested by a person competent to do so, prior to completion the Council should be notified by BS 7671 and a final inspection certificate to be issued for the work by a person competent to do so.




block plan



rear elevation




side elevation



side elevation



front elevation



scale bar 1:100

External walls: Cavity brickwork / blockwork: 100mm facing bricks to match existing. 100mm cavity filled with 100mm rigid fibre-glass insulation and 100mm Thermalite blocks with 13mm plaster internally.

Provide stainless steel twisted cavity wall ties at 750mm horizontal centres and 450mm staggered vertical centres. Ties to be doubled up at corners and reveals.

Provide insulated cavity closers to all new reveals.

Note - External walls to achieve a minimum U_v value of 0.28w/m²K.

Note - Provide insulated cavity closers to all new reveals.

Note - Please refer to Structural Engineers design for beam and associated supports.

Note - All new materials to match existing.

Note - Provide a self contained, mains operated, interlinked optical smoke detector system with battery back-up in accordance with BS 5839 or 5446 should be provided on each floor landing (ground floor and first floor landing levels) (B1).

While giving due consideration to providing an additional smoke detector on the opposite landing so that each wing of the property is fully protected.

Note - If gas or electric meters are located under the stair cupboards than the understair cupboards and cupboard doors should be lined with fire line plaster board.

Note - Electrical installation to be carried out by a member of an Electrical Competent Person Scheme (ECPs) who on completion of the work must register the installation with their ECPs in order that a completion certificate can be issued.

Note - All boiler installations to be carried out and certified by a member or a class of persons approved by the HSE; for the time being this means they must be registered with Gas Safe, the Council of Registered Gas Installers.

Note - The SEDBUK 2009 seasonal efficiency rating of any proposed boiler should not be less than 88%.

63mm rvp to connect to existing surface water drain or taken via 100mm heepsleeve drains laid on 150mm pea shingle to a soakaway located 5m away from any building.
Note - Soakaway to be designed 1m³ for every 16m² of roof area drained.

All new wastes to kitchen area be 40mm fitted with 75mm deep seal traps and cleaning eyes provided at changes of direction. 100mm b.i gully connected to existing manhole.

Note - New b.i gully taking sink waste and connect to new drain and existing drain run.

Note - Provide mechanical ventilation to kitchen's ducted to fresh air with an extract rate of 60 litres/sec or if a cooker hood is provided the rate can be reduced to 30 litres/sec.

Form all new timber stud partitions as shown on the drawing constructed in 100x50mm softwood timber at 400mm centres with 12.5mm plaster board and skim coat of plaster to both sides and infill with 100mm rockwool insulation.
All new studs to be built of double joists bolted together with M12 Bolts at 600mm centres.

Note - Provide mechanical ventilation ducted to fresh air to bathroom with an extract rate of 30 litres/sec operated by means of the light switch with a minimum of 15 minutes overrun.


All new wastes bathroom be 40mm fitted with 75mm deep seal traps and cleaning eyes provided at changes of direction and connected to existing s.v.p or new 100mm stub stack.

Note - Heated wholesome water or heated softened water to proposed wash hand basins and shower to be installed so as to resist the effects of temperature and pressure that may occur either in normal use or in the event of such malfunctions as may reasonably be anticipated, and must be adequately supported.

Note - All baths / showers to be fitted with thermostatic valves so that the hot supply does not exceed 48 deg C.

Note - Provide thermostatic radiator valves to new proposed radiators.

Note - The proposed habitable rooms are each to be provided with an operable window with an unobstructed area of minimum 0.33m² with a minimum 450mm dimension in either direction. (I.e. Clear unobstructed aperture to be minimum 750x450mm - with escape hinges). The cill height of these windows should fall between 800-1000mm. First floor windows with a cill height below 800mm are to provide adequate protection against falling - safety glass and child proof restrictors to be fitted.




ground floor plan


Note - Existing manhole depth 700mm - 750mm.
Remove walls as shown dotted and provide new steel beams over to engineer's detail - and cut back brickwork as required.
Note - Please refer to Structural Engineers design for beam and associated supports.

Bond new structure to existing using s/s profiles by cinctic or similar approved.

Note - Lower cill of window to new bedroom as shown of rear elevation.



first floor plan



scale bar 1:50

Notes

This drawing is the Copyright of blyth developments, and may not be reproduced or copied, in whole or in part, without express permission.

Figured dimensions shall be used in preference to scaled dimensions. All dimensions shall be checked on site before commencing works.


*All work shall comply with the latest Building Regulations and be to the satisfaction of the Local Authority.

*Workmanship and methods of construction shall be at least to the standard prescribed by the relevant Codes of Practice.

Materials shall be suitable for the purpose for which they are used and the quality shall not be lower than that defined in the relevant British or Continental Standard so designated.

General Specifications

1. All drainage shown on this drawing is assumed only and it is the contractors responsibility to check exact depths and locations prior to the commencement of the works. or proposed drains found under the proposed extension are to be surrounded in 150mm pea shingle and reinforced concrete bricks are to be provided in the walls above the drain run.
3. Existing sub-floor ventilation is to be maintained (if necessary) by providing 100mm dia PVC ducts extending from the existing air bricks to new 225 x 150mm uPVC ducts, to be double glazed and to be to BS6206 and any glazing within 800mm of the floor level is to be completed or laminated in accordance with Part C.
5. All new habitable rooms are to be provided with permanent ventilation of 600mm², and this is to be achieved by providing either trickle vents in the windows, or by providing mechanical extract fans, and all fans are to have a minimum and bearing of 150mm.
7. All steel beams are to be encased in 2 layers of 12.5mm plaster board and skim coat of plaster to achieve a fire rating of 12 hour.
9. All glazing is to be low E glass with 16mm air gaps between panes.
11. All electrical work required to meet the requirements of Part P (Electrical Safety) must be designed, installed, inspected and tested by a person competent to do so, prior to completion the Council should be notified by BS 7671 and a final inspection certificate to be issued for the work by a person competent to do so.



block plan

Notes

This drawing is the Copyright of blyth developments, and may not be reproduced or copied, in whole or in part, without express permission.

Figured dimensions shall be used in preference to scaled dimensions. All dimensions shall be checked on site before commencing works.


*All work shall comply with the latest Building Regulations and be to the satisfaction of the Local Authority.

*Workmanship and methods of construction shall be at least to the standard prescribed by the relevant Codes of Practice.

Materials shall be suitable for the purpose for which they are used and the quality shall not be lower than that defined in the relevant British or Continental Standard so designated.

General Specifications

1. All drainage shown on this drawing is assumed only and it is the contractors responsibility to check exact depths and locations prior to the commencement of the works. or proposed drains found under the proposed extension are to be surrounded in 150mm pea shingle and reinforced concrete bricks are to be provided in the walls above the drain run.
3. Existing sub-floor ventilation is to be maintained (if necessary) by providing 100mm dia PVC ducts extending from the existing air bricks to new 225 x 150mm uPVC ducts, to be double glazed and to be to BS6206 and any glazing within 800mm of the floor level is to be completed or laminated in accordance with Part C.
5. All new habitable rooms are to be provided with permanent ventilation of 600mm², and this is to be achieved by providing either trickle vents in the windows, or by providing mechanical extract fans, and all fans are to have a minimum and bearing of 150mm.
7. All steel beams are to be encased in 2 layers of 12.5mm plaster board and skim coat of plaster to achieve a fire rating of 12 hour.
9. All glazing is to be low E glass with 16mm air gaps between panes.
11. All electrical work required to meet the requirements of Part P (Electrical Safety) must be designed, installed, inspected and tested by a person competent to do so, prior to completion the Council should be notified by BS 7671 and a final inspection certificate to be issued for the work by a person competent to do so.



block plan

Notes

This drawing is the Copyright of blyth developments, and may not be reproduced or copied, in whole or in part, without express permission.

Figured dimensions shall be used in preference to scaled dimensions. All dimensions shall be checked on site before commencing works.


*All work shall comply with the latest Building Regulations and be to the satisfaction of the Local Authority.

*Workmanship and methods of construction shall be at least to the standard prescribed by the relevant Codes of Practice.

Materials shall be suitable for the purpose for which they are used and the quality shall not be lower than that defined in the relevant British or Continental Standard so designated.

General Specifications

1. All drainage shown on this drawing is assumed only and it is the contractors responsibility to check exact depths and locations prior to the commencement of the works. or proposed drains found under the proposed extension are to be surrounded in 150mm pea shingle and reinforced concrete bricks are to be provided in the walls above the drain run.
3. Existing sub-floor ventilation is to be maintained (if necessary) by providing 100mm dia PVC ducts extending from the existing air bricks to new 225 x 150mm uPVC ducts, to be double glazed and to be to BS6206 and any glazing within 800mm of the floor level is to be completed or laminated in accordance with Part C.
5. All new habitable rooms are to be provided with permanent ventilation of 600mm², and this is to be achieved by providing either trickle vents in the windows, or by providing mechanical extract fans, and all fans are to have a minimum and bearing of 150mm.
7. All steel beams are to be encased in 2 layers of 12.5mm plaster board and skim coat of plaster to achieve a fire rating of 12 hour.
9. All glazing is to be low E glass with 16mm air gaps between panes.
11. All electrical work required to meet the requirements of Part P (Electrical Safety) must be designed, installed, inspected and tested by a person competent to do so, prior to completion the Council should be notified by BS 7671 and a final inspection certificate to be issued for the work by a person competent to do so.



block plan

Notes

This drawing is the Copyright of blyth developments, and may not be reproduced or copied, in whole or in part, without express permission.

Figured dimensions shall be used in preference to scaled dimensions. All dimensions shall be checked on site before commencing works.


*All work shall comply with the latest Building Regulations and be to the satisfaction of the Local Authority.

*Workmanship and methods of construction shall be at least to the standard prescribed by the relevant Codes of Practice.

Materials shall be suitable for the purpose for which they are used and the quality shall not be lower than that defined in the relevant British or Continental Standard so designated.

General Specifications

1. All drainage shown on this drawing is assumed only and it is the contractors responsibility to check exact depths and locations prior to the commencement of the works. or proposed drains found under the proposed extension are to be surrounded in 150mm pea shingle and reinforced concrete bricks are to be provided in the walls above the drain run.
3. Existing sub-floor ventilation is to be maintained (if necessary) by providing 100mm dia PVC ducts extending from the existing air bricks to new 225 x 150mm uPVC ducts, to be double glazed and to be to BS6206 and any glazing within 800mm of the floor level is to be completed or laminated in accordance with Part C.
5. All new habitable rooms are to be provided with permanent ventilation of 600mm², and this is to be achieved by providing either trickle vents in the windows, or by providing mechanical extract fans, and all fans are to have a minimum and bearing of 150mm.
7. All steel beams are to be encased in 2 layers of 12.5mm plaster board and skim coat of plaster to achieve a fire rating of 12 hour.
9. All glazing is to be low E glass with 16mm air gaps between panes.
11. All electrical work required to meet the requirements of Part P (Electrical Safety) must be designed, installed, inspected and tested by a person competent to do so, prior to completion the Council should be notified by BS 7671 and a final inspection certificate to be issued for the work by a person competent to do so.



block plan

Notes

This drawing is the Copyright of blyth developments, and may not be reproduced or copied, in whole or in part, without express permission.

Figured dimensions shall be used in preference to scaled dimensions. All dimensions shall be checked on site before commencing works.


*All work shall comply with the latest Building Regulations and be to the satisfaction of the Local Authority.

*Workmanship and methods of construction shall be at least to the standard prescribed by the relevant Codes of Practice.

Materials shall be suitable for the purpose for which they are used and the quality shall not be lower than that defined in the relevant British or Continental Standard so designated.

General Specifications

1. All drainage shown on this drawing is assumed only and it is the contractors responsibility to check exact depths and locations prior to the commencement of the works. or proposed drains found under the proposed extension are to be surrounded in 150mm pea shingle and reinforced concrete bricks are to be provided in the walls above the drain run.
3. Existing sub-floor ventilation is to be maintained (if necessary) by providing 100mm dia PVC ducts extending from the existing air bricks to new 225 x 150mm uPVC ducts, to be double glazed and to be to BS6206 and any glazing within 800mm of the floor level is to be completed or laminated in accordance with Part C.
5. All new habitable rooms are to be provided with permanent ventilation of 600mm², and this is to be achieved by providing either trickle vents in the windows, or by providing mechanical extract fans, and all fans are to have a minimum and bearing of 150mm.
7. All steel beams are to be encased in 2 layers of 12.5mm plaster board and skim coat of plaster to achieve a fire rating of 12 hour.
9. All glazing is to be low E glass with 16mm air gaps between panes.
11. All electrical work required to meet the requirements of Part P (Electrical Safety) must be designed, installed, inspected and tested by a person competent to do so, prior to completion the Council should be notified by BS 7671 and a final inspection certificate to be issued for the work by a person competent to do so.



block plan

Notes

This drawing is the Copyright of blyth developments, and may not be reproduced or copied, in whole or in part, without express permission.

Figured dimensions shall be used in preference to scaled dimensions. All dimensions shall be checked on site before commencing works.


*All work shall comply with the latest Building Regulations and be to the satisfaction of the Local Authority.

*Workmanship and methods of construction shall be at least to the standard prescribed by the relevant Codes of Practice.

Materials shall be suitable for the purpose for which they are used and the quality shall not be lower than that defined in the relevant British or Continental Standard so designated.

General Specifications

1. All drainage shown on this drawing is assumed only and it is the contractors responsibility to check exact depths and locations prior to the commencement of the works. or proposed drains found under the proposed extension are to be surrounded in 150mm pea shingle and reinforced concrete bricks are to be provided in the walls above the drain run.
3. Existing sub-floor ventilation is to be maintained (if necessary) by providing 100mm dia PVC ducts extending from the existing air bricks to new 225 x 150mm uPVC ducts, to be double glazed and to be to BS6206 and any glazing within 800mm of the floor level is to be completed or laminated in accordance with Part C.
5. All new habitable rooms are to be provided with permanent ventilation of 600mm², and this is to be achieved by providing either trickle vents in the windows, or by providing mechanical extract fans, and all fans are to have a minimum and bearing of 150mm.
7. All steel beams are to be encased in 2 layers of 12.5mm plaster board and skim coat of plaster to achieve a fire rating of 12 hour.
9. All glazing is to be low E glass with 16mm air gaps between panes.
11. All electrical work required to meet the requirements of Part P (Electrical Safety) must be designed, installed, inspected and tested by a person competent to do so, prior to completion the Council should be notified by BS 7671 and a final inspection certificate to be issued for the work by a person competent to do so.



block plan

Notes

This drawing is the Copyright of blyth developments, and may not be reproduced or copied, in whole or in part, without express permission.

Figured dimensions shall be used in preference to scaled dimensions. All dimensions shall be checked on site before commencing works.


*All work shall comply with the latest Building Regulations and be to the satisfaction of the Local Authority.

*Workmanship and methods of construction shall be at least to the standard prescribed by the relevant Codes of Practice.

Materials shall be suitable for the purpose for which they are used and the quality shall not be lower than that defined in the relevant British or Continental Standard so designated.

General Specifications

1. All drainage shown on this drawing is assumed only and it is the contractors responsibility to check exact depths and locations prior to the commencement of the works. or proposed drains found under the proposed extension are to be surrounded in 150mm pea shingle and reinforced concrete bricks are to be provided in the walls above the drain run.
3. Existing sub-floor ventilation is to be maintained (if necessary) by providing 100mm dia PVC ducts extending from the existing air bricks to new 225 x 150mm uPVC ducts, to be double glazed and to be to BS6206 and any glazing within 800mm of the floor level is to be completed or laminated in accordance with Part C.
5. All new habitable rooms are to be provided with permanent ventilation of 600mm², and this is to be achieved by providing either trickle vents in the windows, or by providing mechanical extract fans, and all fans are to have a minimum and bearing of 150mm.
7. All steel beams are to be encased in 2 layers of 12.5mm plaster board and skim coat of plaster to achieve a fire rating of 12 hour.
9. All glazing is to be low E glass with 16mm air gaps between panes.
11. All electrical work required to meet the requirements of Part P (Electrical Safety) must be designed, installed, inspected and tested by a person competent to do so, prior to completion the Council should be notified by BS 7671 and a final inspection certificate to be issued for the work by a person competent to do so.



block plan

Notes

This drawing is the Copyright of blyth developments, and may not be reproduced or copied, in whole or in part, without express permission.

Figured dimensions shall be used in preference to scaled dimensions. All dimensions shall be checked on site before commencing works.


*All work shall comply with the latest Building Regulations and be to the satisfaction of the Local Authority.

*Workmanship and methods of construction shall be at least to the standard prescribed by the relevant Codes of Practice.

Materials shall be suitable for the purpose for which they are used and the quality shall not be lower than that defined in the relevant British or Continental Standard so designated.

General Specifications

1. All drainage shown on this drawing is assumed only and it is the contractors responsibility to check exact depths and locations prior to the commencement of the works. or proposed drains found under the proposed extension are to be surrounded in 150mm pea shingle and reinforced concrete bricks are to be provided in the walls above the drain run.
3. Existing sub-floor ventilation is to be maintained (if necessary) by providing 100mm dia PVC ducts extending from the existing air bricks to new 225 x 150mm uPVC ducts, to be double glazed and to be to BS6206 and any glazing within 800mm of the floor level is to be completed or laminated in accordance with Part C.
5. All new habitable rooms are to be provided with permanent ventilation of 600mm², and this is to be achieved by providing either trickle vents in the windows, or by providing mechanical extract fans, and all fans are to have a minimum and bearing of 150mm.
7. All steel beams are to be encased in 2 layers of 12.5mm plaster board and skim coat of plaster to achieve a fire rating of 12 hour.
9. All glazing is to be low E glass with 16mm air gaps between panes.
11. All electrical work required to meet the requirements of Part P (Electrical Safety) must be designed, installed, inspected and tested by a person competent to do so, prior to completion the Council should be notified by BS 7671 and a final inspection certificate to be issued for the work by a person competent to do so.



block plan

Notes

This drawing is the Copyright of blyth developments, and may not be reproduced or copied, in whole or in part, without express permission.

Figured dimensions shall be used in preference to scaled dimensions. All dimensions shall be checked on site before commencing works.


*All work shall comply with the latest Building Regulations and be to the satisfaction of the Local Authority.

*Workmanship and methods of construction shall be at least to the standard prescribed by the relevant Codes of Practice.

Materials shall be suitable for the purpose for which they are used and the quality shall not be lower than that defined in the relevant British or Continental Standard so designated.

General Specifications

1. All drainage shown on this drawing is assumed only and it is the contractors responsibility to check exact depths and locations prior to the commencement of the works. or proposed drains found under the proposed extension are to be surrounded in 150mm pea shingle and reinforced concrete bricks are to be provided in the walls above the drain run.
3. Existing sub-floor ventilation is to be maintained (if necessary) by providing 100mm dia PVC ducts extending from the existing air bricks to new 225 x 150mm uPVC ducts, to be double glazed and to be to BS6206 and any glazing within 800mm of the floor level is to be completed or laminated in accordance with Part C.
5. All new habitable rooms are to be provided with permanent ventilation of 600mm², and this is to be achieved by providing either trickle vents in the windows, or by providing mechanical extract fans, and all fans are to have a minimum and bearing of 150mm.
7. All steel beams are to be encased in 2 layers of 12.5mm plaster board and skim coat of plaster to achieve a fire rating of 12 hour.
9. All glazing is to be low E glass with 16mm air gaps between panes.
11. All electrical work required to meet the requirements of Part P (Electrical Safety) must be designed, installed, inspected and tested by a person competent to do so, prior to completion the Council should be notified by BS 7671 and a final inspection certificate to be issued for the work by a person competent to do so.



block plan

Notes

This drawing is the Copyright of blyth developments, and may not be reproduced or copied, in whole or in part, without express permission.

Figured dimensions shall be used in preference to scaled dimensions. All dimensions shall be checked on site before commencing works.


*All work shall comply with the latest Building Regulations and be to the satisfaction of the Local Authority.

*Workmanship and methods of construction shall be at least to the standard prescribed by the relevant Codes of Practice.

Materials shall be suitable for the purpose for which they are used and the quality shall not be lower than that defined in the relevant British or Continental Standard so designated.

General Specifications

1. All drainage shown on this drawing is assumed only and it is the contractors responsibility to check exact depths and locations prior to the commencement of the works. or proposed drains found under the proposed extension are to be surrounded in 150mm pea shingle and reinforced concrete bricks are to be provided in the walls above the drain run.
3. Existing sub-floor ventilation is to be maintained (if necessary) by providing 100mm dia PVC ducts extending from the existing air bricks to new 225 x 150mm uPVC ducts, to be double glazed and to be to BS6206 and any glazing within 800mm of the floor level is to be completed or laminated in accordance with Part C.
5. All new habitable rooms are to be provided with permanent ventilation of 600mm², and this is to be achieved by providing either trickle vents in the windows, or by providing mechanical extract fans, and all fans are to have a minimum and bearing of 150mm.
7. All steel beams are to be encased in 2 layers of 12.5mm plaster board and skim coat of plaster to achieve a fire rating of 12 hour.
9. All glazing is to be low E glass with 16mm air gaps between panes.
11. All electrical work required to meet the requirements of Part P (Electrical Safety) must be designed, installed, inspected and tested by a person competent to do so, prior to completion the Council should be notified by BS 7671 and a final inspection certificate to be issued for the work by a person competent to do so.



block plan

Notes

This drawing is the Copyright of blyth developments, and may not be reproduced or copied, in whole or in part, without express permission.

Figured dimensions shall be used in preference to scaled dimensions. All dimensions shall be checked on site before commencing works.

*All work shall comply with the latest Building Regulations and be to the satisfaction of the Local Authority.

*Workmanship and methods of construction shall be at least to the standard prescribed by the relevant Codes of Practice.

Materials shall be suitable for the purpose for which they are used and the quality shall not be lower than that defined in the relevant British or Continental Standard so designated.