

London Borough of Hillingdon, Civic Centre, , Uxbridge, Middlesex, UB8 1UW

31 October 2025

Our DTS Ref: 79929
Your Ref: 79689/APP/2025/2438

Dear Sir/Madam,

Re: HORTON ROAD INDUSTRIAL ESTATE , HORTON ROAD, WEST DRAYTON, LONDON, UB7 8JL

Waste Comments:

Waste Comments:Public sewers are crossing or close to your development. Build over agreements are required for any building works within 3 metres of a public sewer and, or within 1 metre of a public lateral drain. This is to prevent damage to the sewer network and ensures we have suitable and safe access to carry out maintenance and repairs. Please refer to our guide on working near or diverting our pipes:<https://www.thameswater.co.uk/developers/larger-scale-developments/planning-your-development/working-near-our-pipes> Please ensure to apply to determine if a build over agreement will be granted.

We would expect the developer to demonstrate what measures will be undertaken to minimise groundwater discharges into the public sewer. Groundwater discharges typically result from construction site dewatering, deep excavations, basement infiltration, borehole installation, testing and site remediation. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. Should the Local Planning Authority be minded to approve the planning application, Thames Water would like the following informative attached to the planning permission: "A Groundwater Risk Management Permit from Thames Water will be required for discharging groundwater into a public sewer. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 020 3577 9483 or by emailing trade.effluent@thameswater.co.uk . Application forms should be completed on line via www.thameswater.co.uk. Please refer to the Wholesale; Business customers; Groundwater discharges section.

With regard to SURFACE WATER drainage, Thames Water would advise that if the developer follows the sequential approach to the disposal of surface water we would have no objection. Management of surface water from new developments should follow Policy SI 13 Sustainable drainage of the London Plan 2021. Where the developer proposes to discharge to a public sewer, prior approval from Thames Water Developer Services will be required. Should you require further information please refer to our website. <https://www.thameswater.co.uk/help/home-improvements/how-to-connect-to-a-sewer/sewer-connection-design>

Thames Water would advise that with regard to WASTE WATER NETWORK and SEWAGE TREATMENT WORKS infrastructure capacity, we would not have any objection to the above planning application, based on the information provided.

Water Comments:

Water Comments:With regard to water supply, this comes within the area covered by the Affinity Water Company. For your information the address to write to is - Affinity Water Company The Hub,

Tamblin Way, Hatfield, Herts, AL10 9EZ - Tel - 0845 782 3333.

Supplementary Comments:

Yours faithfully,
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ,
Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk