



STRUCTURAL STEEL

STEEL TO BE INSTALLED AS STRUCTURAL ENGINEERS DESIGN

ALL STEELWORK TO BE ENCASED IN 2NO LAYERS OF 12.5MM FIRELINE PLASTERBOARD

WASTES AND DRAINAGE

100MM WC, 40MM SHOWER AND SINK, 32MM BASIN WASTES. WHERE WASTES ARE COMBINED THE PIPE TO BE INCREASED TO 50MM

100MM UPVC SVP TO EXTEND 900MM ABOVE ANY OPENABLE WINDOW
BELOW GROUND DRAINAGE TO BE 100MM UPVC LAID TO MIN 1 IN 40 FALL. NEW MANHOLES AND
ACCESS CHAMBERS TO BE 450MM DIAMETER UPVC